Job No.: McGough   **Address:** 1981 Te Rahu Road, Te Awamutu, New Zealand   **Date:** 02/12/2024

Latitude: -37.979644   **Longitude:** 175.352609   **Elevation:** 54.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	6 m
Wind Region	NZ1	Terrain Category	3.0	Design Wind Speed	34.86 m/s
Wind Pressure	0.73 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Medium	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Gable   Open

For roof $C_{p,i}$ = -0.3

For roof CP,e from 0 m To 5.40 m Cpe = -0.9 pe = -0.59 KPa $pnet$ = -0.59 KPa

For roof CP,e from 5.4 m To 10.80 m Cpe = -0.5 pe = -0.33 KPa $pnet$ = -0.33 KPa

For wall Windward $C_{p,i}$ = -0.3   side Wall $C_{p,i}$ = -0.3

For wall Windward and Leeward CP,e from 0 m To 12 m Cpe = 0.7 pe = 0.46 KPa $pnet$ = 0.68 KPa

For side wall CP,e from 0 m To 5.40 m Cpe = pe = -0.43 KPa $pnet$ = -0.43 KPa

Maximum Upward pressure used in roof member Design = 0.59 KPa

Maximum Downward pressure used in roof member Design = 0.29 KPa

Maximum Wall pressure used in Design = 0.68 KPa

Maximum Racking pressure used in Design = 0.66 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm   Purlin Span = 6000 mm   Try Purlin 250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.97

K8 Upward =0.53   S1 Downward =12.68   S1 Upward =23.05

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	1.37 Kn-m	Capacity	3.40 Kn-m	Passing Percentage	**248.18 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	2.87 Kn-m	Capacity	4.53 Kn-m	Passing Percentage	**157.84 %**
$M_{0.9D-WnUp}$	-1.48 Kn-m	Capacity	-3.09 Kn-m	Passing Percentage	**208.78 %**
$V_{1.35D}$	0.91 Kn	Capacity	12.06 Kn	Passing Percentage	**1325.27 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.82 Kn	Capacity	16.08 Kn	Passing Percentage	**883.52 %**
$V_{0.9D-WnUp}$	-0.99 Kn	Capacity	-20.10 Kn	Passing Percentage	**2030.30 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 20.20 mm   Limit by Woolcock et al, 1999 Span/240 = 24.79 mm

Deflection under Dead and Service Wind = 21.72 mm   Limit by Woolcock et al, 1999 Span/100 = 59.50 mm

Reactions

Second page

Maximum downward =1.82 kn   Maximum upward = -0.99 kn

Number of Blocking = 1   if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 6150 mm   Internal Rafter Span = 11850 mm   Try Rafter 2x450x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =6.68   S1 Upward =6.68

Shear Capacity of timber =5.3 MPa   Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	36.43 Kn-m	Capacity	91.56 Kn-m	Passing Percentage	**251.33 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	72.87 Kn-m	Capacity	122.08 Kn-m	Passing Percentage	**167.53 %**
$M_{0.9D-WnUp}$	-39.40 Kn-m	Capacity	-152.6 Kn-m	Passing Percentage	**387.31 %**
$V_{1.35D}$	12.30 Kn	Capacity	96.64 Kn	Passing Percentage	**785.69 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	24.60 Kn	Capacity	128.86 Kn	Passing Percentage	**523.82 %**
$V_{0.9D-WnUp}$	-13.30 Kn	Capacity	-161.08 Kn	Passing Percentage	**1211.13 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 42.595 mm   Limit by Woolcock et al, 1999 Span/240 = 50.00 mm
Deflection under Dead and Service Wind = 50.88 mm   Limit by Woolcock et al, 1999 Span/100 = 120.00 mm

Reactions

Maximum downward =24.60 kn   Maximum upward = -13.30 kn

Rafter to Pole Connection check

Bolt Size = M16 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 80 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 126 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 77.63 Kn > -13.30 Kn

Intermediate Design Front and Back

Intermediate Spacing = 3075 mm   Intermediate Span = 4640 mm   Try Intermediate 2x200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =11.27   S1 Upward =0.81

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	5.63 Kn-m	Capacity	7.46 Kn-m	Passing Percentage			**132.50 %**
$V_{0.9D-WnUp}$	4.85 Kn	Capacity	-32.16 Kn	Passing Percentage			**663.09 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 35.06 mm   Limit byWoolcock et al, 1999 Span/100 = 46.40 mm

Reactions

Maximum = 4.85 kn

Intermediate Design Sides

Intermediate Spacing = 3000 mm   Intermediate Span = 5245 mm   Try Intermediate 2x250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =0.97

K8 Upward =1.00   S1 Downward =12.68   S1 Upward =0.97

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	3.51 Kn-m	Capacity	11.66 Kn-m	Passing Percentage		**332.19 %**
$V_{0.9D-WnUp}$	2.67 Kn	Capacity	40.2 Kn	Passing Percentage		**1505.62 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 28.59 mm   Limit by Woolcock et al, 1999 Span/100 = 52.45 mm

Reactions

Maximum = 2.67 kn

Girt Design Front and Back

Girt's Spacing = 1300 mm   Girt's Span = 3075 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.78   S1 Downward =9.63   S1 Upward =17.81

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.04 Kn-m	Capacity	1.63 Kn-m	Passing Percentage		**156.73 %**
$V_{0.9D-WnUp}$	1.36 Kn	Capacity	12.06 Kn	Passing Percentage		**886.76 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 10.92 mm   Limit by Woolcock et al, 1999 Span/100 = 30.75 mm
Sag during installation = 5.42 mm

Reactions

Maximum = 1.36 kn

Girt Design Sides

Girt's Spacing = 1300 mm   Girt's Span = 3000 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.79   S1 Downward =9.63   S1 Upward =17.59

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

| $M_{Wind+Snow}$ | 0.99 Kn-m | Capacity | 1.65 Kn-m | Passing Percentage | **166.67 %** |
| $V_{0.9D-WnUp}$ | 1.33 Kn | Capacity | 12.06 Kn | Passing Percentage | **906.77 %** |

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 9.90 mm   Limit by Woolcock et al. 1999 Span/100 = 30.00 mm
Sag during installation =4.91 mm

Reactions

Maximum = 1.33 kn

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1600) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1600)

Skin Friction = 20.68 Kn

Weight of Pile + Pile Skin Friction = 23.89 Kn

Uplift on one Pile = 13.47 Kn

Uplift is ok

Last Page