Job No.: 2304005   **Address:** 224 Pomona Road, Ruby Bay, New Zealand **Date:** 11/30/2023

Latitude: -41.231767   **Longitude:** 173.069714   **Elevation:** 72.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N3	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	C
Importance Level	2	Ultimate wind & Earthquake ARI	500 Years	Max Height	4.2 m
Wind Region	NZ2	Terrain Category	2.5	Design Wind Speed	45.92 m/s
Wind Pressure	1.27 KPa	Lee Zone	NO	Ultimate Snow ARI	150 Years
Wind Category	Very High	Earthquake ARI	500		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono   Enclosed

For roof $C_{p,i}$ = -0.3

For roof $C_{P,e}$ from 0 m To 1.95 m Cpe = -0.9457   pe = -0.96 KPa   pnet = -0.96 KPa

For roof $C_{P,e}$ from 1.95 m To 3.90 m Cpe = -0.8771   pe = -0.89 KPa   pnet = -0.89 KPa

For wall Windward $C_{p,i}$ = -0.3   side Wall $C_{p,i}$ = -0.3

For wall Windward and Leeward $C_{P,e}$ from 0 m To 14.4 m Cpe = 0.7   pe = 0.71 KPa   pnet = 1.05 KPa

For side wall $C_{P,e}$ from 0 m To 3.90 m Cpe =   pe = -0.66 KPa   pnet = -0.66 KPa

Maximum Upward pressure used in roof member Design = 0.96 KPa

Maximum Downward pressure used in roof member Design = 0.54 KPa

Maximum Wall pressure used in Design = 1.05 KPa

Maximum Racking pressure used in Design = 1.22 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm   Purlin Span = 3450 mm   Try Purlin 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

First Page

condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.94

K8 Upward =0.40   S1 Downward =13.93   S1 Upward =27.08

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.45 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	**1048.89 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.35 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	**466.67 %**
$M_{0.9D-WnUp}$	-0.98 Kn-m	Capacity	-3.32 Kn-m	Passing Percentage	**338.78 %**
$V_{1.35D}$	0.52 Kn	Capacity	14.47 Kn	Passing Percentage	**2782.69 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.30 Kn	Capacity	19.30 Kn	Passing Percentage	**1484.62 %**
$V_{0.9D-WnUp}$	-1.14 Kn	Capacity	-24.12 Kn	Passing Percentage	**2115.79 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 1.25 mm   Limit by Woolcock et al, 1999 Span/360 = 9.44 mm

Deflection under Dead and Service Wind = 1.60 mm   Limit by Woolcock et al, 1999 Span/250 = 22.67 mm

Reactions

Maximum downward =1.30 kn   Maximum upward = -1.14 kn

Number of Blocking = 0   if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

 Internal Rafter Load Width = 3600 mm   Internal Rafter Span = 6850 mm   Try Rafter 2x300x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =7.61   S1 Upward =7.61

Shear Capacity of timber =5.3 MPa   Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

Second page

$M_{1.35D}$	7.13 Kn-m	Capacity	31.1 Kn-m	Passing Percentage	**436.19 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	17.74 Kn-m	Capacity	41.48 Kn-m	Passing Percentage	**233.82 %**
$M_{0.9D-WnUp}$	-15.52 Kn-m	Capacity	-51.84 Kn-m	Passing Percentage	**334.02 %**
$V_{1.35D}$	4.16 Kn	Capacity	46.02 Kn	Passing Percentage	**1106.25 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	10.36 Kn	Capacity	61.36 Kn	Passing Percentage	**592.28 %**
$V_{0.9D-WnUp}$	-9.06 Kn	Capacity	-76.7 Kn	Passing Percentage	**846.58 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 13.64 mm   Limit by Woolcock et al, 1999 Span/360 = 19.44 mm

Deflection under Dead and Service Wind = 19.455 mm   Limit by Woolcock et al, 1999 Span/250 = 46.67 mm

Reactions

Maximum downward =10.36 kn   Maximum upward = -9.06 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 29.11 Kn > -9.06 Kn

Rafter Design External

External Rafter Load Width = 1800 mm   External Rafter Span = 3313 mm   Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.94

K8 Upward =0.94   S1 Downward =13.93   S1 Upward =13.93

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.83 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	**568.67 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	2.07 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	**304.35 %**
$M_{0.9D-WnUp}$	-1.82 Kn-m	Capacity	-7.87 Kn-m	Passing Percentage	**432.42 %**
$V_{1.35D}$	1.01 Kn	Capacity	14.47 Kn	Passing Percentage	**1432.67 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	2.50 Kn	Capacity	19.30 Kn	Passing Percentage	**772.00 %**
$V_{0.9D-WnUp}$	-2.19 Kn	Capacity	-24.12 Kn	Passing Percentage	**1101.37 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 1.74 mm   Limit by Woolcock et al, 1999 Span/360= 9.72 mm
Deflection under Dead and Service Wind = 2.23 mm   Limit by Woolcock et al, 1999 Span/250 = 23.33 mm

Reactions

Maximum downward =2.50 kn   Maximum upward = -2.19 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds .... (Eq 4.12) = -25.20 kn > -2.19 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -2.19 Kn

Girt Design Front and Back

Girt's Spacing = 600 mm   Girt's Span = 3600 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.71   S1 Downward =9.63   S1 Upward =19.27

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.02 Kn-m	Capacity	1.48 Kn-m	Passing Percentage	**145.10 %**
$V_{0.9D-WnUp}$	1.13 Kn-m	Capacity	12.06 Kn-m	Passing Percentage	**1067.26 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 14.62 mm   Limit by Woolcock et al, 1999 Span/250 = 14.40 mm
Sag during installation = 10.18 mm

Reactions

Maximum = 1.13 kn

Girt Design Sides

Girt's Spacing = 600 mm   Girt's Span = 3500 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.72   S1 Downward =9.63   S1 Upward =19.00

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.96 Kn-m	Capacity	1.51 Kn-m	Passing Percentage	**157.29 %**

| $V_{0.9D-WnUp}$ | 1.10 Kn-m | Capacity | 12.06 Kn-m | Passing Percentage | **1096.36 %** |

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 13.07 mm   Limit by Woolcock et al. 1999 Span/100 = 14.00 mm
Sag during installation =9.10 mm

Reactions

Maximum = 1.10 kn

Middle Pole Design

Geometry

275 SED H5 (Minimum 300 dia. at Floor Level)	Dry Use		Height	3900 mm
Area	64885 mm2	As	48663.8671875 mm2	
Ix	335197731 mm4	Zx	2331810 mm3	
Iy	335197731 mm4	Zx	2331810 mm3	
Lateral Restraint	3900 mm c/c			

Loads

Total Area over Pole = 12.6 m2

Dead	3.15 Kn	Live	3.15 Kn
Wind Down	6.80 Kn	Snow	0.00 Kn
Moment wind	14.49 Kn-m		
Phi	0.8	K8	0.95
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

| PhiNcx Wind | 886.30 Kn | PhiMnx Wind | 64.23 Kn-m | PhiVnx Wind | 115.24 Kn |

PhiNcx Dead   531.78 Kn   PhiMnx Dead   38.54 Kn-m   PhiVnx Dead   69.14 Kn

Checks

$(Mx/PhiMnx)+(N/phiNcx) = 0.24 < 1$ OK

$(Mx/PhiMnx)^2+(N/phiNcx) = 0.07 < 1$ OK

Deflection at top under service lateral loads = 10.75 mm < 26.00 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma   18 Kn/m3   Friction angle   30 deg   Cohesion   0 Kn/m3

$K0 = (1-\sin(30)) / (1+\sin(30))$

$Kp = (1+\sin(30)) / (1-\sin(30))$

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1700 mm	Pile embedment length
f1 =	3150 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =   14.49 Kn-m

Shear Wind =   4.60 Kn

Pile Properties

Safety Factory	0.55	
Hu =	9.03 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	17.07 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.85 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)		Dry Use		Height	3900 mm
Area		35448 mm2		As	26585.7421875 mm2
Ix		100042702 mm4		Zx	941578 mm3
Iy		100042702 mm4		Zx	941578 mm3
Lateral Restraint		mm c/c			

Loads

Total Area over Pole = 6.3 m2

Dead	1.57 Kn	Live	1.57 Kn
Wind Down	3.40 Kn	Snow	0.00 Kn
Moment Wind	4.83 Kn-m		
Phi	0.8	K8	0.75
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
f_b =	36.3 MPa	f_s =	2.96 MPa
f_c =	18 MPa	f_p =	7.2 MPa
f_t =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	383.42 Kn	PhiMnx Wind	20.54 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	230.05 Kn	PhiMnx Dead	12.32 Kn-m	PhiVnx Dead	37.77 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.25 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.07 < 1 OK

Deflection at top under service lateral loads = 12.89 mm < 27.93 mm

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	3150 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 6.3 m2

Moment Wind =	4.83 Kn-m
Shear Wind =	1.53 Kn

Pile Properties

Safety Factory	0.55	
Hu =	4.40 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.11 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.60 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma   18 Kn/m3   Friction angle   30 deg   Cohesion   0 Kn/m3

$K0 =$ (1-sin(30)) / (1+sin(30))

$Kp =$ (1+sin(30)) / (1-sin(30))

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	3150 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	4.83 Kn-m
Shear Wind =	1.53 Kn

Pile Properties

Safety Factory	0.55	
Hu =	4.40 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.11 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.60 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1700) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1700)

Skin Friction = 23.34 Kn

Weight of Pile + Pile Skin Friction = 26.31 Kn

Uplift on one Pile = 9.26 Kn

Uplift is ok

Last Page