

Job Number:

Issue:

**BWhite
Consulting Ltd**

PRODUCER STATEMENT-PS1-DESIGN

ISSUED BY: **BWhite Consulting Ltd (Design Engineer: Bevan White)**

TO BE SUPPLIED TO: **Far North District Council** IN RESPECT OF: **Proposed NEW Farm Shed**

AT: **10 Arkles Way, Taipa, New Zealand**

LEGAL DESCRIPTION

We have been engaged by **Ezequote Pty Ltd** to provide **Specific Structural Engineering Design** services in respect of the requirements of Clause(s) **B1** of the Building Code for part only (as specified in the attachment to this statement), of the proposed building work.

☐ ALL ☒ Part only as specified: Purlins, Rafters, Girts, Poles, Columns, Pole embedment and all connections

The design has been prepared in accordance with compliance documents to NZ Building Code issued by Ministry of Business, Innovation & Employment Clauses **B1/VM1 and B1/VM4**

The proposed building work covered by the producer statement is described on **Ezequote** drawings title **509-100271C** and numbered **A101 - A114 Rev-1** dated **22/04/2025** together with the following specification, and other documents set out in the schedule attached to this statement: **Design Featured Report Dated 21/04/2025 and numbered "Second Page"**

On behalf of BWhite Consulting Ltd, and subject to:

1. Site verification of the following design assumptions: **an Ultimate foundation bearing pressure of 300 kPa in accordance with NZS3604:2011**
2. **The building has a design life of 50 years and an Importance Level 1**
3. **Unless specifically noted, compliance of the drawings to Non-Specific codes such as NZS3604 and NZS4229 have not been checked by this practice**
4. **This Certificate does not cover any other building code clause including weather tightness**
5. **Inspections of the building to be completed by Far North District Council. As BWhite Consulting Ltd are not undertaking inspections, we cannot issue a producer Statement-PS4- Construction Review.**
6. **This Producer Statement- Design is valid for a building consent issued within 1 year from the date of issue**
7. All proprietary products meeting their performance specification requirements

I believe on reasonable grounds that a) the building, if constructed in accordance with the drawings, specifications, and other documents provided or listed in the attached schedule, will comply with the relevant provisions of the Building Code and that b), the persons who have undertaken the design have the necessary competency to do so. I also recommend the follow level of construction monitoring/observation:

☒ CM1 ☐ CM2 ☐ CM3 ☐ CM4 ☐ CM5 or as per agreement with owner/developer (**stated above**)

I, **Bevan White** am CPEng **108276** I am Member of Engineering New Zealand and hold the following qualification: **BE Civil** and holds a current policy of Professional Indemnity Insurance no less than \$200,000

Signed by **Bevan White** on behalf of **BWhite Consulting Ltd** Dated: **21/04/2025**

Email: **bwhitecpeng@gmail.com** Phone: **0211-979786**

Note: This statement shall only be relied upon by the Building Consent Authority named above. Liability under this statement accrues to the Design Firm only. The total maximum amount of damages payable arising from this statement and all other statements provided to the Building Consent Authority in relation to this building work, whether in contract, tort or otherwise (including negligence), is limited to the sum of \$200,000.

This form is to accompany Form 2 of the Building (Forms) Regulations 2004 for the application of a Building Consent

Date: 21/04/2025

18B Jules Crescent,

Bell Block New Plymouth 4312

New Zealand

File No:

BWhite
Consulting Ltd

DESIGN FEATURES SUMMARY FOR PROPOSED NEW FARM SHED 10 ARKLES WAY, TAIPA, NEW ZEALAND

Site Specific Loads

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & EQ ARI	100 Years	Max Height	3.98 m
Wind Region	NZ1	Terrain Category	2.09	Design Wind Speed	47.33 m/s
Wind Pressure	1.34 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years

Timber

Sawn Timber to be graded to the properties of SG6 and SG8 or better as mentioned on plans, with moisture content of 18% or less for dry and 25% or less for wet.

The following standards have been used in the design of this structure

- NZS 3603:1993 Timber Structures Standard
- NZS 3604:2011 Timber Framed Buildings. Standards New Zealand, 2011
- NZS 3404:1997 Steel Structures
- AS/NZS 1170 2003 Structural Design Actions
- AS/NZS 1170.2 2021 Structural Design Actions-Wind Action
- Branz. "Engineering Basis of NZS 3604". April 2013

Yours Faithfully

BWhite CONSULTING LTD

Bevan White

Director | BE Civil . CMengNZ CPEng

Email: bwhitecpeng@gmail.com Contact: 0211 979 786

Pole Shed App Ver 01 2022

Job No.: 509-100271C

Address: 10 Arkles Way, Taipa, New Zealand

Date: 21/04/2025

Latitude: -34.997823

Longitude: 173.444011

Elevation: 51.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.98 m
Wind Region	NZ1	Terrain Category	2.09	Design Wind Speed	47.33 m/s
Wind Pressure	1.34 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Very High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Enclosed

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 3.49 m $C_{p,e} = -0.9$ $p_e = -1.09$ KPa $p_{net} = -1.09$ KPa

For roof $C_{p,e}$ from 3.49 m To 6.98 m $C_{p,e} = -0.5$ $p_e = -0.60$ KPa $p_{net} = -0.60$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 12 m $C_{p,e} = 0.7$ $p_e = 0.85$ KPa $p_{net} = 1.25$ KPa

For side wall $C_{p,e}$ from 0 m To 3.49 m $C_{p,e} =$ $p_e = -0.79$ KPa $p_{net} = -0.79$ KPa

Maximum Upward pressure used in roof member Design = 1.09 KPa

Maximum Downward pressure used in roof member Design = 0.64 KPa

Maximum Wall pressure used in Design = 1.25 KPa

Maximum Racking pressure used in Design = 1.45 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm

Purlin Span = 5850 mm

Try Purlin 290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.89

K8 Upward =0.56 S1 Downward =15.23 S1 Upward =22.33

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	1.3 Kn-m	Capacity	3.78 Kn-m	Passing Percentage	290.77 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	3.62 Kn-m	Capacity	5.04 Kn-m	Passing Percentage	139.23 %
M _{0.9D-W_nUp}	-3.33 Kn-m	Capacity	-3.96 Kn-m	Passing Percentage	118.92 %
V _{1.35D}	0.89 Kn	Capacity	12.59 Kn	Passing Percentage	1414.61 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	2.47 Kn	Capacity	16.79 Kn	Passing Percentage	679.76 %
V _{0.9D-W_nUp}	-2.28 Kn	Capacity	-20.98 Kn	Passing Percentage	920.18 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 18.12 mm Limit by Woolcock et al, 1999 Span/240 = 24.17 mm

Deflection under Dead and Service Wind = 17.75 mm Limit by Woolcock et al, 1999 Span/100 = 58.00 mm

Reactions

Maximum downward =2.47 kn Maximum upward = -2.28 kn

Number of Blocking = 2 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 6000 mm Internal Rafter Span = 6850 mm Try Rafter 2x360x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =8.40 S1 Upward =8.40

Shear Capacity of timber =5.3 MPa Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

Pole Shed App Ver 01 2022

M _{1.35D}	11.88 Kn-m	Capacity	43.44 Kn-m	Passing Percentage	365.66 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	33.08 Kn-m	Capacity	57.92 Kn-m	Passing Percentage	175.09 %
M _{0.9D-WnUp}	-30.44 Kn-m	Capacity	-72.42 Kn-m	Passing Percentage	237.91 %
V _{1.35D}	6.94 Kn	Capacity	55.22 Kn	Passing Percentage	795.68 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	19.32 Kn	Capacity	73.64 Kn	Passing Percentage	381.16 %
V _{0.9D-WnUp}	-17.78 Kn	Capacity	-92.04 Kn	Passing Percentage	517.66 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 13.16 mm Limit by Woolcock et al, 1999 Span/240 = 29.17 mm

Deflection under Dead and Service Wind = 19.98 mm Limit by Woolcock et al, 1999 Span/100 = 70.00 mm

Reactions

Maximum downward = 19.32 kn Maximum upward = -17.78 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K₁₁ = 12.6 f_{pj} = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K₁₁ = 2.0 f_{cj} = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -17.78 Kn

Rafter Design External

External Rafter Load Width = 3000 mm External Rafter Span = 6868 mm Try Rafter 360x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Pole Shed App Ver 01 2022

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 0.81

K8 Upward = 0.81 S1 Downward = 17.01 S1 Upward = 17.01

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	5.97 Kn-m	Capacity	17.70 Kn-m	Passing Percentage	296.48 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_{nDn}}	16.63 Kn-m	Capacity	23.60 Kn-m	Passing Percentage	141.91 %
M _{0.9D-W_{nUp}}	-15.30 Kn-m	Capacity	-29.50 Kn-m	Passing Percentage	192.81 %
V _{1.35D}	3.48 Kn	Capacity	27.61 Kn	Passing Percentage	793.39 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_{nDn}}	9.68 Kn	Capacity	36.82 Kn	Passing Percentage	380.37 %
V _{0.9D-W_{nUp}}	-8.91 Kn	Capacity	-46.02 Kn	Passing Percentage	516.50 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 14.62 mm Limit by Woolcock et al, 1999 Span/240 = 29.17 mm

Deflection under Dead and Service Wind = 19.98 mm Limit by Woolcock et al, 1999 Span/100 = 70.00 mm

Reactions

Maximum downward = 9.68 kn Maximum upward = -8.91 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K₁₁ = 12.6 f_{pj} = 22.7 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K₁₁ = 2.0 f_{cj} = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = $\phi \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s$ (Eq 4.12) = -50.09 kn > -8.91 Kn

Single Shear Capacity under short term loads = -21.83 Kn > -8.91 Kn

Intermediate Design Front and Back

Intermediate Spacing = 3000 mm Intermediate Span = 3830 mm Try Intermediate 2x240x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.94

K8 Upward =1.00 S1 Downward =13.82 S1 Upward =0.90

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	6.88 Kn-m	Capacity	9.68 Kn-m	Passing Percentage	140.70 %
V _{0.9D-WnUp}	7.18 Kn	Capacity	-34.74 Kn	Passing Percentage	483.84 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 18.765 mm Limit by Woolcock et al, 1999 Span/100 = 38.30 mm

Reactions

Maximum = 7.18 kn

Intermediate Design Sides

Intermediate Spacing = 3500 mm Intermediate Span = 3340 mm Try Intermediate 2x190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =1.00 S1 Downward =12.23 S1 Upward =0.74

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	3.05 Kn-m	Capacity	6.06 Kn-m	Passing Percentage	198.69 %
V _{0.9D-WnUp}	3.65 Kn	Capacity	27.5 Kn	Passing Percentage	753.42 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 25.52 mm Limit by Woolcock et al, 1999 Span/100 = 33.40 mm

Reactions

Maximum = 3.65 kn

Girt Design Front and Back

Girt's Spacing = 1100 mm

Girt's Span = 3000 mm

Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =0.56 S1 Downward =12.23 S1 Upward =22.32

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	1.55 Kn-m	Capacity	1.70 Kn-m	Passing Percentage	109.68 %
V _{0.9D-WnUp}	2.06 Kn	Capacity	13.75 Kn	Passing Percentage	667.48 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 8.42 mm Limit by Woolcock et al, 1999 Span/100 = 30.00 mm

Sag during installation = 6.06 mm

Reactions

Maximum = 2.06 kn

Girt Design Sides

Girt's Spacing = 1100 mm

Girt's Span = 3500 mm

Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.98

Pole Shed App Ver 01 2022

K8 Upward =0.81 S1 Downward =12.23 S1 Upward =17.05

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	2.11 Kn-m	Capacity	2.46 Kn-m	Passing Percentage	116.59 %
V _{0.9D-WnUp}	2.41 Kn	Capacity	13.75 Kn	Passing Percentage	570.54 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 15.59 mm Limit by Woolcock et al. 1999 Span/100 = 35.00 mm
Sag during installation =11.23 mm

Reactions

Maximum = 2.41 kn

Middle Pole Design

Geometry

250 SED H5 (Minimum 275 dia. at Floor Level)	Dry Use	Height	3620 mm
Area	54091 mm ²	As	40568.5546875 mm ²
I _x	232952248 mm ⁴	Z _x	1774874 mm ³
I _y	232952248 mm ⁴	Z _y	1774874 mm ³
Lateral Restraint	3620 mm c/c		

Loads

Total Area over Pole = 21 m²

Dead	5.25 Kn	Live	5.25 Kn
Wind Down	13.44 Kn	Snow	0.00 Kn
Moment wind	25.78 Kn-m		
Phi	0.8	K8	0.94
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
f _b =	36.3 MPa	f _s =	2.96 MPa

Pole Shed App Ver 01 2022

$f_c =$	18 MPa	$f_p =$	7.2 MPa
$f_t =$	22 MPa	$E =$	9257 MPa

Capacities

PhiNcx Wind	733.59 Kn	PhiMnx Wind	48.54 Kn-m	PhiVnx Wind	96.07 Kn
PhiNcx Dead	440.15 Kn	PhiMnx Dead	29.13 Kn-m	PhiVnx Dead	57.64 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.56 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.31 < 1$ OK

Deflection at top under service lateral loads = 24.20 mm < 36.20 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma 18 Kn/m³ Friction angle 30 deg Cohesion 0 Kn/m³

$K_0 = (1 - \sin(30)) / (1 + \sin(30))$

$K_p = (1 + \sin(30)) / (1 - \sin(30))$

Geometry For Middle Bay Pole

$D_s =$	0.6 mm	Pile Diameter
$L =$	2100 mm	Pile embedment length
$f_1 =$	2985 mm	Distance at which the shear force is applied
$f_2 =$	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind = 25.78 Kn-m

Shear Wind = 8.63 Kn

Pile Properties

Safety Factory	0.55	
$H_u =$	16.23 Kn	Ultimate Lateral Strength of the Pile, Short pile
$M_u =$	30.10 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.86 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3620 mm
Area	35448 mm ²	As	26585.7421875 mm ²
I _x	100042702 mm ⁴	Z _x	941578 mm ³
I _y	100042702 mm ⁴	Z _y	941578 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 21 m²

Dead	5.25 Kn	Live	5.25 Kn
Wind Down	13.44 Kn	Snow	0.00 Kn
Moment Wind	12.89 Kn-m		
Phi	0.8	K ₈	0.81
K ₁ snow	0.8	K ₁ Dead	0.6
K ₁ wind	1		

Material

Peeling	Steaming	Normal	Dry Use
f _b =	36.3 MPa	f _s =	2.96 MPa
f _c =	18 MPa	f _p =	7.2 MPa
f _t =	22 MPa	E =	9257 MPa

Capacities

PhiN _{cx} Wind	415.40 Kn	PhiM _{nx} Wind	22.25 Kn-m	PhiV _{nx} Wind	62.96 Kn
PhiN _{cx} Dead	249.24 Kn	PhiM _{nx} Dead	13.35 Kn-m	PhiV _{nx} Dead	37.77 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.64 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.39 < 1$ OK

Deflection at top under service lateral loads = 30.90 mm < 39.70 mm

Pole Shed App Ver 01 2022

Ds =	0.6 mm	Pile Diameter
L =	1600 mm	Pile embedment length
f1 =	2985 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 21 m²

Moment Wind =	12.89 Kn-m
Shear Wind =	4.32 Kn

Pile Properties

Safety Factory	0.55	
Hu =	7.96 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	14.25 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.90 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1600 mm	Pile embedment length
f1 =	2985 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	12.89 Kn-m
Shear Wind =	4.32 Kn

Pile Properties

Pole Shed App Ver 01 2022

Safety Factor	0.55	
Hu =	7.96 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	14.25 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.90 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(2100) x Ks(1.5) x $0.5 \times \tan(30) \times \pi \times \text{Dia of Pile}(0.6) \times \text{Height of Pile}(2100)$

Skin Friction = 35.62 Kn

Weight of Pile + Pile Skin Friction = 39.84 Kn

Uplift on one Pile = 18.17 Kn

Uplift is ok