



Pole Shed App Ver 01 2022

**Job No.:** PUHI PEAKS  
STATION

**Address:** 1695 Puhi Puhi Road,, Puhi Puhi, New  
Zealand

**Date:** 27/05/2025

**Latitude:** -42.188837

**Longitude:** 173.770736

**Elevation:** 556 m

**General Input**

|                  |            |                                   |           |                      |           |
|------------------|------------|-----------------------------------|-----------|----------------------|-----------|
| Roof Live Load   | 0.25 KPa   | Roof Dead Load                    | 0.25 KPa  | Roof Live Point Load | 1.1 Kn    |
| Snow Zone        | N3         | Ground Snow Load                  | 1.22 KPa  | Roof Snow Load       | 0.85 KPa  |
| Earthquake Zone  | 4          | Subsoil Category                  | D         | Exposure Zone        | B         |
| Importance Level | 1          | Ultimate wind &<br>Earthquake ARI | 100 Years | Max Height           | 5 m       |
| Wind Region      | NZ2        | Terrain Category                  | 3.0       | Design Wind Speed    | 50.99 m/s |
| Wind Pressure    | 1.56 KPa   | Lee Zone                          | YES       | Ultimate Snow ARI    | 50 Years  |
| Wind Category    | extra High | Earthquake ARI                    | 100       |                      |           |

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Mono Enclosed

For roof  $C_{p,i} = -0.3$

For roof  $C_{p,e}$  from 0 m To 2.50 m  $C_{p,e} = -0.9167$   $p_e = -1.29$  KPa  $p_{net} = -1.29$  KPa

For roof  $C_{p,e}$  from 2.50 m To 5.00 m  $C_{p,e} = -0.8917$   $p_e = -1.25$  KPa  $p_{net} = -1.25$  KPa

For wall Windward  $C_{p,i} = -0.3$  side Wall  $C_{p,i} = -0.3$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 9.6 m  $C_{p,e} = 0.7$   $p_e = 0.98$  KPa  $p_{net} = 1.45$  KPa

For side wall  $C_{p,e}$  from 0 m To 5 m  $C_{p,e} =$   $p_e = -0.91$  KPa  $p_{net} = -0.91$  KPa

Maximum Upward pressure used in roof member Design = 1.29 KPa

Maximum Downward pressure used in roof member Design = 0.47 KPa

Maximum Wall pressure used in Design = 1.45 KPa

Maximum Racking pressure used in Design = 1.67 KPa

**Design Summary**

**Purlin Design**

Purlin Spacing = 900 mm

Purlin Span = 4650 mm

Try Purlin 250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

Pole Shed App Ver 01 2022

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 0.97

K8 Upward = 0.66    S1 Downward = 12.68    S1 Upward = 20.27

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

|  |            |          |            |                    |                  |
|--|------------|----------|------------|--------------------|------------------|
| M <sub>1.35D</sub>                       | 0.82 Kn-m  | Capacity | 3.40 Kn-m  | Passing Percentage | <b>414.63 %</b>  |
| M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub> | 2.8 Kn-m   | Capacity | 4.53 Kn-m  | Passing Percentage | <b>161.79 %</b>  |
| M <sub>0.9D-WnUp</sub>                   | -2.59 Kn-m | Capacity | -3.83 Kn-m | Passing Percentage | <b>147.88 %</b>  |
| V <sub>1.35D</sub>                       | 0.71 Kn    | Capacity | 12.06 Kn   | Passing Percentage | <b>1698.59 %</b> |
| V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub> | 2.41 Kn    | Capacity | 16.08 Kn   | Passing Percentage | <b>667.22 %</b>  |
| V <sub>0.9D-WnUp</sub>                   | -2.23 Kn   | Capacity | -20.10 Kn  | Passing Percentage | <b>901.35 %</b>  |

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 11.13 mm    Limit by Woolcock et al, 1999 Span/240 = 19.17 mm

Deflection under Dead and Service Wind = 8.84 mm    Limit by Woolcock et al, 1999 Span/100 = 46.00 mm

**Reactions**

Maximum downward = 2.41 kn    Maximum upward = -2.23 kn

Number of Blocking = 1    if 0 then no blocking required, if 1 then one midspan blocking required

**Rafter Design Internal**

Internal Rafter Load Width = 4800 mm    Internal Rafter Span = 9850 mm    Try Rafter 2x400x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 1.00

K8 Upward = 1.00    S1 Downward = 6.26    S1 Upward = 6.26

Shear Capacity of timber = 5.3 MPa    Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

|  |            |          |            |                    |                 |
|--|------------|----------|------------|--------------------|-----------------|
| M <sub>1.35D</sub>                       | 19.65 Kn-m | Capacity | 73.78 Kn-m | Passing Percentage | <b>375.47 %</b> |
| M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub> | 66.95 Kn-m | Capacity | 98.38 Kn-m | Passing Percentage | <b>146.95 %</b> |

Pole Shed App Ver 01 2022

|  |             |          |              |                    |                  |
|--|-------------|----------|--------------|--------------------|------------------|
| M <sub>0.9D-WnUp</sub>                   | -62.00 Kn-m | Capacity | -122.98 Kn-m | Passing Percentage | <b>198.35 %</b>  |
| V <sub>1.35D</sub>                       | 7.98 Kn     | Capacity | 85.9 Kn      | Passing Percentage | <b>1076.44 %</b> |
| V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub> | 27.19 Kn    | Capacity | 114.54 Kn    | Passing Percentage | <b>421.26 %</b>  |
| V <sub>0.9D-WnUp</sub>                   | -25.18 Kn   | Capacity | -143.18 Kn   | Passing Percentage | <b>568.63 %</b>  |

**Deflections**

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 22.83 mm      Limit by Woolcock et al, 1999 Span/240 = 41.67 mm

Deflection under Dead and Service Wind = 31.07 mm      Limit by Woolcock et al, 1999 Span/100 = 100.00 mm

**Reactions**

Maximum downward = 27.19 kn    Maximum upward = -25.18 kn

**Rafter to Pole Connection check**

Bolt Size = M16 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 80 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K<sub>11</sub> = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 126 mm

For Parallel to grain loading

K<sub>11</sub> = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 77.63 Kn > -25.18 Kn

**Girt Design Front and Back**

Girt's Spacing = 650 mm

Girt's Span = 4800 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K<sub>1</sub> Short term = 1    K<sub>4</sub> = 1    K<sub>5</sub> = 1    K<sub>8</sub> Downward = 1.00

Pole Shed App Ver 01 2022

K8 Upward =0.75    S1 Downward =11.27    S1 Upward =18.41

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

|                        |           |          |           |                    |                 |
|------------------------|-----------|----------|-----------|--------------------|-----------------|
| M <sub>Wind+Snow</sub> | 2.71 Kn-m | Capacity | 2.79 Kn-m | Passing Percentage | <b>102.95 %</b> |
| V <sub>0.9D-WnUp</sub> | 2.26 Kn   | Capacity | 16.08 Kn  | Passing Percentage | <b>711.50 %</b> |

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 46.27 mm    Limit by Woolcock et al, 1999 Span/100 = 48.00 mm  
Sag during installation = 32.19 mm

**Reactions**

Maximum = 2.26 kn

**Girt Design Sides**

Girt's Spacing = 1300 mm                      Girt's Span = 2500 mm                      Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.73    S1 Downward =11.27    S1 Upward =18.79

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

|                        |           |          |           |                    |                 |
|------------------------|-----------|----------|-----------|--------------------|-----------------|
| M <sub>Wind+Snow</sub> | 1.47 Kn-m | Capacity | 2.72 Kn-m | Passing Percentage | <b>185.03 %</b> |
| V <sub>0.9D-WnUp</sub> | 2.36 Kn   | Capacity | 16.08 Kn  | Passing Percentage | <b>681.36 %</b> |

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 6.81 mm    Limit by Woolcock et al. 1999 Span/100 = 25.00 mm  
Sag during installation =2.37 mm

**Reactions**

Maximum = 2.36 kn

## Middle Pole Design

### Geometry

|  |                           |                |                               |
|--|---------------------------|----------------|-------------------------------|
| 275 SED H5 (Minimum 300 dia. at Floor Level) | Dry Use                   | Height         | 4600 mm                       |
| Area   | 64885 mm <sup>2</sup>     | As             | 48663.8671875 mm <sup>2</sup> |
| I <sub>x</sub>                               | 335197731 mm <sup>4</sup> | Z <sub>x</sub> | 2331810 mm <sup>3</sup>       |
| I <sub>y</sub>                               | 335197731 mm <sup>4</sup> | Z <sub>y</sub> | 2331810 mm <sup>3</sup>       |
| Lateral Restraint                            | 4600 mm c/c               |                |                               |

### Loads

Total Area over Pole = 24 m<sup>2</sup>

|                     |            |                     |           |
|---------------------|------------|---------------------|-----------|
| Dead                | 6.00 Kn    | Live                | 6.00 Kn   |
| Wind Down           | 11.28 Kn   | Snow                | 20.40 Kn  |
| Moment wind         | 37.48 Kn-m | Moment snow         | 7.30 Kn-m |
| Phi                 | 0.8        | K <sub>8</sub>      | 0.86      |
| K <sub>1</sub> snow | 0.8        | K <sub>1</sub> Dead | 0.6       |
| K <sub>1</sub> wind | 1          |                     |           |

### Material

|                  |          |                  |          |
|------------------|----------|------------------|----------|
| Peeling          | Steaming | Normal           | Dry Use  |
| f <sub>b</sub> = | 36.3 MPa | f <sub>s</sub> = | 2.96 MPa |
| f <sub>c</sub> = | 18 MPa   | f <sub>p</sub> = | 7.2 MPa  |
| f <sub>t</sub> = | 22 MPa   | E =              | 9257 MPa |

### Capacities

|                         |           |                         |            |                         |           |
|-------------------------|-----------|-------------------------|------------|-------------------------|-----------|
| PhiN <sub>cx</sub> Wind | 803.16 Kn | PhiM <sub>nx</sub> Wind | 58.21 Kn-m | PhiV <sub>nx</sub> Wind | 115.24 Kn |
| PhiN <sub>cx</sub> Dead | 481.90 Kn | PhiM <sub>nx</sub> Dead | 34.93 Kn-m | PhiV <sub>nx</sub> Dead | 69.14 Kn  |
| PhiN <sub>cx</sub> Snow | 642.53 Kn | PhiM <sub>nx</sub> Snow | 46.57 Kn-m | PhiV <sub>nx</sub> Snow | 92.19 Kn  |

### Checks

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.69 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.46 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 39.04 \text{ mm} < 46.00 \text{ mm}$$

## Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

### Assumed Soil Properties

Gamma 18 Kn/m<sup>3</sup> Friction angle 30 deg Cohesion 0 Kn/m<sup>3</sup>  
K<sub>0</sub> =  $(1 - \sin(30)) / (1 + \sin(30))$   
K<sub>p</sub> =  $(1 + \sin(30)) / (1 - \sin(30))$

### Geometry For Middle Bay Pole

D<sub>s</sub> = 0.6 mm Pile Diameter  
L = 2300 mm Pile embedment length  
f<sub>1</sub> = 3750 mm Distance at which the shear force is applied  
f<sub>2</sub> = 0 mm Distance of top soil at rest pressure

### Loads

Moment Wind = 37.48 Kn-m Moment Snow = Kn-m  
Shear Wind = 9.99 Kn Shear Snow = 7.30 Kn

### Pile Properties

Safety Factory 0.55  
H<sub>u</sub> = 17.92 Kn Ultimate Lateral Strength of the Pile, Short pile  
M<sub>u</sub> = 40.97 Kn-m Ultimate Moment Capacity of Pile

### Checks

Applied Forces/Capacities = 0.91 < 1 OK

## End Pole Design

### Geometry For End Bay Pole

#### Geometry

|  |                           |                |                               |
|--|---------------------------|----------------|-------------------------------|
| 200 SED H5 (Minimum 225 dia. at Floor Level) | Dry Use                   | Height         | 4700 mm                       |
| Area   | 35448 mm <sup>2</sup>     | A <sub>s</sub> | 26585.7421875 mm <sup>2</sup> |
| I <sub>x</sub>                               | 100042702 mm <sup>4</sup> | Z <sub>x</sub> | 941578 mm <sup>3</sup>        |
| I <sub>y</sub>                               | 100042702 mm <sup>4</sup> | Z <sub>y</sub> | 941578 mm <sup>3</sup>        |
| Lateral Restraint                            | mm c/c                    |                |                               |

### Loads

Pole Shed App Ver 01 2022

Total Area over Pole = 12 m<sup>2</sup>

|             |            |             |           |
|-------------|------------|-------------|-----------|
| Dead        | 3.00 Kn    | Live        | 3.00 Kn   |
| Wind Down   | 5.64 Kn    | Snow        | 10.20 Kn  |
| Moment Wind | 12.49 Kn-m | Moment snow | 2.43 Kn-m |
| Phi         | 0.8        | K8          | 0.57      |
| K1 snow     | 0.8        | K1 Dead     | 0.6       |
| K1 wind     | 1          |             |           |

**Material**

|         |          |        |          |
|---------|----------|--------|----------|
| Peeling | Steaming | Normal | Dry Use  |
| fb =    | 36.3 MPa | fs =   | 2.96 MPa |
| fc =    | 18 MPa   | fp =   | 7.2 MPa  |
| ft =    | 22 MPa   | E =    | 9257 MPa |

**Capacities**

|             |           |             |            |             |          |
|-------------|-----------|-------------|------------|-------------|----------|
| PhiNcx Wind | 291.05 Kn | PhiMnx Wind | 15.59 Kn-m | PhiVnx Wind | 62.96 Kn |
| PhiNcx Dead | 174.63 Kn | PhiMnx Dead | 9.35 Kn-m  | PhiVnx Dead | 37.77 Kn |
| PhiNcx Snow | 232.84 Kn | PhiMnx Snow | 12.47 Kn-m | PhiVnx Snow | 50.36 Kn |

**Checks**

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.87 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.71 < 1 \text{ OK}$$

Deflection at top under service lateral loads = 47.27 mm < 49.88 mm

|      |         |  |
|------|---------|--|
| Ds = | 0.6 mm  | Pile Diameter                                |
| L =  | 1700 mm | Pile embedment length                        |
| f1 = | 3750 mm | Distance at which the shear force is applied |
| f2 = | 0 mm    | Distance of top soil at rest pressure        |

**Loads**

Total Area over Pole = 12 m<sup>2</sup>

|               |            |               |           |
|---------------|------------|---------------|-----------|
| Moment Wind = | 12.49 Kn-m | Moment Snow = | 2.43 Kn-m |
| Shear Wind =  | 3.33 Kn    | Shear Snow =  | 2.43 Kn   |

**Pile Properties**



### Pole Shed App Ver 01 2022

|                |            |   |
|----------------|------------|---|
| Safety Factory | 0.55       |   |
| Hu =           | 8.03 Kn    | Ultimate Lateral Strength of the Pile, Short pile |
| Mu =           | 17.77 Kn-m | Ultimate Moment Capacity of Pile                  |

#### Checks

Applied Forces/Capacities = 0.70 < 1 OK

### **Drained Lateral Strength of End pile in cohesionless soils Free Head short pile**

#### Assumed Soil Properties

|       |                                   |                |        |          |         |
|-------|-----------------------------------|----------------|--------|----------|---------|
| Gamma | 18 Kn/m3                          | Friction angle | 30 deg | Cohesion | 0 Kn/m3 |
| K0 =  | $(1 - \sin(30)) / (1 + \sin(30))$ |                |        |          |         |
| Kp =  | $(1 + \sin(30)) / (1 - \sin(30))$ |                |        |          |         |

#### Geometry For End Bay Pole

|      |         |  |
|------|---------|--|
| Ds = | 0.6 mm  | Pile Diameter                                |
| L =  | 1700 mm | Pile embedment length                        |
| f1 = | 3750 mm | Distance at which the shear force is applied |
| f2 = | 0 mm    | Distance of top soil at rest pressure        |

#### Loads

|               |            |               |           |
|---------------|------------|---------------|-----------|
| Moment Wind = | 12.49 Kn-m | Moment Snow = | 2.43 Kn-m |
| Shear Wind =  | 3.33 Kn    | Shear Snow =  | 2.43 Kn   |

#### Pile Properties

|                |            |   |
|----------------|------------|---|
| Safety Factory | 0.55       |   |
| Hu =           | 8.03 Kn    | Ultimate Lateral Strength of the Pile, Short pile |
| Mu =           | 17.77 Kn-m | Ultimate Moment Capacity of Pile                  |

#### Checks

Applied Forces/Capacities = 0.70 < 1 OK

### **Uplift Check**

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between

Pole Shed App Ver 01 2022

both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(2300) x Ks(1.5) x  $0.5 \times \tan(30)$  x  $\pi$  x Dia of Pile(0.6) x Height of Pile(2300)

Skin Friction = 42.72 Kn

Weight of Pile + Pile Skin Friction = 46.75 Kn

Uplift on one Pile = 25.56 Kn

Uplift is ok