<u>Pole Shed App Ver 01 2022</u>

Job No.:	471 504655 - 1	**Address:**	227 Heard Road, Waihi 3681, New Zealand	**Date:**	3/2/2025
Latitude:	-37.384142	**Longitude:**	175.9183	**Elevation:**	278 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.5 m
Wind Region	NZ1	Terrain Category	3.0	Design Wind Speed	46.34 m/s
Wind Pressure	1.29 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Very High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono Enclosed

For roof Cp,i = -0.3

For roof CP,e from 0 m To 3.85 m Cpe = -0.9 pe = -1.04 KPa pnet = -1.04 KPa

For roof CP,e from 3.85 m To 7.70 m Cpe = -0.5 pe = -0.58 KPa pnet = -0.58 KPa

For wall Windward Cp,i = -0.3 side Wall Cp,i = -0.3

For wall Windward and Leeward CP,e from 0 m To 9 m Cpe = 0.7 pe = 0.81 KPa pnet = 1.20 KPa

For side wall CP,e from 0 m To 3.85 m Cpe = pe = -0.75 KPa pnet = -0.75 KPa

Maximum Upward pressure used in roof member Design = 1.04 KPa

Maximum Downward pressure used in roof member Design = 0.59 KPa

Maximum Wall pressure used in Design = 1.20 KPa

Maximum Racking pressure used in Design = 1.39 KPa

Design Summary

Rafter Design Internal

Internal Rafter Load Width = 4125 mm Internal Rafter Span = 8850 mm Try Rafter 2x360x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =5.90 S1 Upward =5.90

Shear Capacity of timber =5.3 MPa Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	13.63 Kn-m	Capacity	60.82 Kn-m	Passing Percentage	**446.22 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	35.94 Kn-m	Capacity	81.1 Kn-m	Passing Percentage	**225.65 %**
$M_{0.9D\text{-}WnUp}$	-32.91 Kn-m	Capacity	-101.38 Kn-m	Passing Percentage	**308.05 %**
$V_{1.35D}$	6.16 Kn	Capacity	77.32 Kn	Passing Percentage	**1255.19 %**

Second page

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	16.25 Kn	Capacity	103.08 Kn	Passing Percentage	**634.34 %**
$V_{0.9D-WnUp}$	-14.88 Kn	Capacity	-128.86 Kn	Passing Percentage	**865.99 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 17.655 mm	Limit by Woolcock et al, 1999 Span/240 = 37.50 mm
Deflection under Dead and Service Wind = 25.995 mm	Limit by Woolcock et al, 1999 Span/100 = 90.00 mm

Reactions

Maximum downward =16.25 kn Maximum upward = -14.88 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 126 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -14.88 Kn

Girt Design Front and Back

Girt's Spacing = 0 mm	Girt's Span = 2063 mm	Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =NaN

K8 Upward =NaN S1 Downward =NaN S1 Upward =NaN

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	**NaN %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	**NaN %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm	Limit by Woolcock et al, 1999 Span/100 = 20.63 mm
Sag during installation = NaN mm	

Reactions

Maximum = 0.00 kn

Girt Design Sides

Girt's Spacing = 0 mm	Girt's Span = 2250 mm	Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =NaN

K8 Upward =NaN S1 Downward =NaN S1 Upward =NaN

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	**NaN %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	**NaN %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm	Limit by Woolcock et al. 1999 Span/100 = 22.50 mm
Sag during installation =NaN mm	

Reactions

Maximum = 0.00 kn

Middle Pole Design

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3140 mm
Area	35448 mm2	As	26585.7421875 mm2
Ix	100042702 mm4	Zx	941578 mm3
Iy	100042702 mm4	Zx	941578 mm3
Lateral Restraint	3140 mm c/c		

Loads

Total Area over Pole = 18.5625 m2

Dead	4.64 Kn	Live	4.64 Kn
Wind Down	10.95 Kn	Snow	0.00 Kn
Moment wind	13.14 Kn-m		
Phi	0.8	K8	0.91
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use

fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	463.67 Kn	PhiMnx Wind	24.84 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	278.20 Kn	PhiMnx Dead	14.90 Kn-m	PhiVnx Dead	37.77 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.57 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.32 < 1 OK

Deflection at top under service lateral loads = 21.90 mm < 31.40 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1700 mm	Pile embedment length
f1 =	2625 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	13.14 Kn-m
Shear Wind =	5.00 Kn

Pile Properties

Safety Factory	0.55	
Hu =	10.12 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	16.31 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.81 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1700) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1700)

Skin Friction = 23.34 Kn

Weight of Pile + Pile Skin Friction = 27.76 Kn

Uplift on one Pile = 15.13 Kn

Uplift is ok