

Pole Shed App Ver 01 2022

Job No.: Jasmin Riceman - 1

Address: 69 Lauries Drive, Kauri, Whangarei, New Zealand

Date: 16/10/2024

Latitude: -35.654685

Longitude: 174.317582

Elevation: 188 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4.15 m
Wind Region	NZ1	Terrain Category	2.47	Design Wind Speed	42.18 m/s
Wind Pressure	1.07 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Gable Enclosed

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 4.15 m $C_{p,e} = -0.9$ $p_e = -0.86$ KPa $p_{net} = -0.86$ KPa

For roof $C_{p,e}$ from 4.15 m To 8.30 m $C_{p,e} = -0.5$ $p_e = -0.48$ KPa $p_{net} = -0.48$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 12 m $C_{p,e} = 0.7$ $p_e = 0.67$ KPa $p_{net} = 0.99$ KPa

For side wall $C_{p,e}$ from 0 m To 4.15 m $C_{p,e} =$ $p_e = -0.62$ KPa $p_{net} = -0.62$ KPa

Maximum Upward pressure used in roof member Design = 0.86 KPa

Maximum Downward pressure used in roof member Design = 0.42 KPa

Maximum Wall pressure used in Design = 0.99 KPa

Maximum Racking pressure used in Design = 0.96 KPa

Design Summary

Girt Design Front and Back

Girt's Spacing = 1300 mm

Girt's Span = 3000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.79 S1 Downward =9.63 S1 Upward =17.59

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.45 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	113.79 %
$V_{0.9D-WnUp}$	1.93 Kn	Capacity	12.06 Kn	Passing Percentage	624.87 %

Deflections

Pole Shed App Ver 01 2022

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 14.41 mm

Limit by Woolcock et al, 1999 Span/100 = 30.00 mm

Sag during installation = 4.91 mm

Reactions

Maximum = 1.93 kn

Girt Design Sides

Girt's Spacing = 1300 mm

Girt's Span = 4000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.65 S1 Downward =9.63 S1 Upward =20.31

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	2.57 Kn-m	Capacity	1.38 Kn-m	Passing Percentage	53.70 %
V _{0.9D-WnUp}	2.57 Kn	Capacity	12.06 Kn	Passing Percentage	469.26 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 45.53 mm

Limit by Woolcock et al. 1999 Span/100 = 40.00 mm

Sag during installation =15.52 mm

Reactions

Maximum = 2.57 kn

Middle Pole Design

Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3850 mm
Area	27598 mm ²	As	20698.2421875 mm ²
I _x	60639381 mm ⁴	Z _x	646820 mm ³
I _y	60639381 mm ⁴	Z _y	646820 mm ³
Lateral Restraint	3850 mm c/c		

Loads

Total Area over Pole = 12 m²

Dead	3.00 Kn	Live	3.00 Kn
Wind Down	5.04 Kn	Snow	0.00 Kn
Moment wind	9.28 Kn-m		
Phi	0.8	K8	0.64
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	255.93 Kn	PhiMnx Wind	12.10 Kn-m	PhiVnx Wind	49.01 Kn
PhiNcx Dead	153.56 Kn	PhiMnx Dead	7.26 Kn-m	PhiVnx Dead	29.41 Kn

Checks

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.81 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.63 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 37.10 \text{ mm} < 38.50 \text{ mm}$$

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	3113 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	9.28 Kn-m
Shear Wind =	2.98 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.42 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.94 Kn-m	Ultimate Moment Capacity of Pile

Checks

$$\text{Applied Forces/Capacities} = 0.93 < 1 \text{ OK}$$

End Pole Design

Geometry For End Bay Pole

Geometry

Pole Shed App Ver 01 2022

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3900 mm
Area	27598 mm ²	As	20698.2421875 mm ²
I _x	60639381 mm ⁴	Z _x	646820 mm ³
I _y	60639381 mm ⁴	Z _y	646820 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 12 m²

Dead	3.00 Kn	Live	3.00 Kn
Wind Down	5.04 Kn	Snow	0.00 Kn
Moment Wind	4.64 Kn-m		
Phi	0.8	K ₈	0.63
K ₁ snow	0.8	K ₁ Dead	0.6
K ₁ wind	1		

Material

Peeling	Steaming	Normal	Dry Use
f _b =	36.3 MPa	f _s =	2.96 MPa
f _c =	18 MPa	f _p =	7.2 MPa
f _t =	22 MPa	E =	9257 MPa

Capacities

PhiN _{cx} Wind	250.93 Kn	PhiM _{nx} Wind	11.86 Kn-m	PhiV _{nx} Wind	49.01 Kn
PhiN _{cx} Dead	150.56 Kn	PhiM _{nx} Dead	7.12 Kn-m	PhiV _{nx} Dead	29.41 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.44 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.20 < 1$ OK

Deflection at top under service lateral loads = 19.95 mm < 41.40 mm

D _s =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f ₁ =	3113 mm	Distance at which the shear force is applied
f ₂ =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 12 m²

Moment Wind =	4.64 Kn-m
Shear Wind =	1.49 Kn

Pile Properties

Safety Factory	0.55	
H _u =	5.42 Kn	Ultimate Lateral Strength of the Pile, Short pile
M _u =	9.94 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = $0.47 < 1$ OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	3113 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	4.64 Kn-m
Shear Wind =	1.49 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.42 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.94 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = $0.47 < 1$ OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 19.92 Kn

Uplift on one Pile = 7.62 Kn

Uplift is ok