Job No.: SHIELD Address: 60 LEAMINGTON STREET, CHEVIOT, Date: 17/04/2025

New Zealand

Latitude: -42.791204 **Longitude:** 173.144681 **Elevation:** 185.5 m

General Input

| Roof Live Load | 0.25 KPa | Roof Dead Load | 0.25 KPa | Roof Live Point Load | 1.1 Kn |
|------------------|----------|--------------------------------|-----------|----------------------|-----------|
| Snow Zone | N4 | Ground Snow Load | 1.03 KPa | Roof Snow Load | 0.7 KPa |
| Earthquake Zone | 3 | Subsoil Category | D | Exposure Zone | В |
| Importance Level | 1 | Ultimate wind & Earthquake ARI | 100 Years | Max Height | 3.6 m |
| Wind Region | NZ2 | Terrain Category | 2.67 | Design Wind Speed | 43.12 m/s |
| Wind Pressure | 1.12 KPa | Lee Zone | NO | Ultimate Snow ARI | 50 Years |
| Wind Category | High | Earthquake ARI | 100 | | |

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Gable Enclosed

For roof Cp, i = -0.3

For roof CP,e from 0 m To 3.30 m Cpe = -0.9 pe = -0.90 KPa pnet = -0.90 KPa

For roof CP,e from 3.30 m To 6.60 m Cpe = -0.50 KPa pnet = -0.50 KPa

For wall Windward Cp, i = -0.3 side Wall Cp, i = -0.3

For wall Windward and Leeward CP,e from 0 m To 6 m Cpe = 0.7 pe = 0.70 KPa pnet = 1.03 KPa

For side wall CP,e from 0 m To 3.30 m Cpe = pe = -0.65 KPa pnet = -0.65 KPa

Maximum Upward pressure used in roof member Design = 0.90 KPa

Maximum Downward pressure used in roof member Design = 0.53 KPa

Maximum Wall pressure used in Design = 1.03 KPa

Maximum Racking pressure used in Design = 1.0 KPa

Design Summary

Purlin Design

Purlin Spacing = 650 mm Purlin Span = 3350 mm Try Purlin 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

Second page

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward =0.75 S1 Downward =9.63 S1 Upward =18.44

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

| $M_{1.35D}$ | 0.31 Kn-m | Capacity | 1.26 Kn-m | Passing Percentage | 406.45 % |
|------------------------------|------------|----------|------------|--------------------|-----------|
| M1.2D+1.5L 1.2D+Sn 1.2D+WnDn | 1.66 Kn-m | Capacity | 1.68 Kn-m | Passing Percentage | 101.20 % |
| $M_{0.9D\text{-W}nUp}$ | -0.62 Kn-m | Capacity | -1.57 Kn-m | Passing Percentage | 253.23 % |
| V _{1.35D} | 0.37 Kn | Capacity | 7.24 Kn | Passing Percentage | 1956.76 % |
| V1.2D+1.5L 1.2D+Sn 1.2D+WnDn | 1.09 Kn | Capacity | 9.65 Kn | Passing Percentage | 885.32 % |
| $ m V_{0.9D	ext{-}WnUp}$ | -0.73 Kn | Capacity | -12.06 Kn | Passing Percentage | 1652.05 % |

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 14.07 mm

Limit by Woolcock et al, 1999 Span/240 = 13.75 mm

Deflection under Dead and Service Wind = 8.15 mm Limit by Woolcock et al, 1999 Span/100 = 33.00 mm

Reactions

Maximum downward = 1.09 kn Maximum upward = -0.73 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Intermediate Design Sides

Intermediate Spacing = 3000 mm Intermediate Span = 3450 mm Try Intermediate 2x200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 1.00 S1 Downward = 11.27 S1 Upward = 0.70

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

| $M_{Wind+Snow}$ | 2.30 Kn-m | Capacity | 7.46 Kn-m | Passing Percentage | 324.35 % |
|--------------------------|-----------|----------|-----------|--------------------|-----------|
| $ m V_{0.9D	ext{-}WnUp}$ | 2.67 Kn | Capacity | 32.16 Kn | Passing Percentage | 1204.49 % |

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 31.665 mm Limit by Woolcock et al, 1999 Span/100 = 34.50 mm

Reactions

Maximum = 2.67 kn

Girt Design Front and Back

Girt's Spacing = 900 mm Girt's Span = 3500 mm Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward =0.72 S1 Downward =9.63 S1 Upward =19.00

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

| $M_{Wind+Snow}$ | 1.42 Kn-m | Capacity | 1.51 Kn-m | Passing Percentage | 106.34 % |
|--------------------|-----------|----------|-----------|--------------------|----------|
| $ m V_{0.9D-WnUp}$ | 1.62 Kn | Capacity | 12.06 Kn | Passing Percentage | 744.44 % |

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 32.29 mm Limit by Woolcock et al, 1999 Span/100 = 35.00 mm Sag during installation = 9.10 mm

Reactions

Maximum = 1.62 kn

Girt Design Sides

Girt's Spacing = 900 mm Girt's Span = 3000 mm Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward =0.79 S1 Downward =9.63 S1 Upward =17.59

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

| $M_{Wind+Snow}$ | 1.04 Kn-m | Capacity | 1.65 Kn-m | Passing Percentage | 158.65 % |
|------------------------|-----------|----------|-----------|--------------------|----------|
| $V_{0.9D\text{-W}nUp}$ | 1.39 Kn | Capacity | 12.06 Kn | Passing Percentage | 867.63 % |

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 17.43 mm Limit by Woolcock et al. 1999 Span/100 = 30.00 mm Sag during installation =4.91 mm

Reactions

Maximum = 1.39 kn

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 19.92 Kn

Uplift on one Pile = 7.09 Kn

Uplift is ok