First Page

Job No.: 679525   **Address:** 47 Access Rd, Kerikeri, New Zealand   **Date:** 13/08/2024

Latitude: -35.238469   **Longitude:** 173.933487   **Elevation:** 102.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4 m
Wind Region	NZ1	Terrain Category	3.0	Design Wind Speed	37.15 m/s
Wind Pressure	0.83 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono   Open

For roof $C_{p,i} = 0.6927$

For roof $C_{P,e}$ from 0 m To 3.5 m Cpe = -0.9   pe = -0.53 KPa   pnet = -1.02 KPa

For roof $C_{P,e}$ from 3.5 m To 7.0 m Cpe = -0.5   pe = -0.30 KPa   pnet = -0.79 KPa

For wall Windward $C_{p,i} = 0.6927$ side Wall $C_{p,i} = -0.6364$

For wall Windward and Leeward $C_{P,e}$ from 0 m To 5 m Cpe = 0.7   pe = 0.48 KPa   pnet = 1.01 KPa

For side wall $C_{P,e}$ from 0 m To 3.50 m Cpe =   pe = -0.45 KPa   pnet = 0.08 KPa

Maximum Upward pressure used in roof member Design = 1.02 KPa

Maximum Downward pressure used in roof member Design = 0.45 KPa

Maximum Wall pressure used in Design = 1.01 KPa

Maximum Racking pressure used in Design = 0.82 KPa

Design Summary

Purlin Design

 Purlin Spacing = 650 mm   Purlin Span = 4850 mm   Try Purlin 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.98

K8 Upward =0.67   S1 Downward =12.23   S1 Upward =19.97

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.65 Kn-m	Capacity	1.79 Kn-m	Passing Percentage	**275.38 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.91 Kn-m	Capacity	2.38 Kn-m	Passing Percentage	**124.61 %**
$M_{0.9D-WnUp}$	-1.52 Kn-m	Capacity	-2.04 Kn-m	Passing Percentage	**272.00 %**
$V_{1.35D}$	0.53 Kn	Capacity	8.25 Kn	Passing Percentage	**1556.60 %**

Second page

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.18 Kn	Capacity	11.00 Kn	Passing Percentage	**932.20 %**
$V_{0.9D-WnUp}$	-1.25 Kn	Capacity	-13.75 Kn	Passing Percentage	**1100.00 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 15.64 mm   Limit by Woolcock et al, 1999 Span/240 = 20.00 mm
Deflection under Dead and Service Wind = 18.90 mm   Limit by Woolcock et al, 1999 Span/100 = 48.00 mm

Reactions

Maximum downward =1.18 kn   Maximum upward = -1.25 kn

Number of Blocking = 1   if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design External

External Rafter Load Width = 2500 mm   External Rafter Span = 3583 mm   Try Rafter 290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.89

K8 Upward =0.89   S1 Downward =15.23   S1 Upward =15.23

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	1.35 Kn-m	Capacity	3.78 Kn-m	Passing Percentage	**280.00 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	3.01 Kn-m	Capacity	5.04 Kn-m	Passing Percentage	**167.44 %**
$M_{0.9D-WnUp}$	-3.19 Kn-m	Capacity	-6.29 Kn-m	Passing Percentage	**197.18 %**
$V_{1.35D}$	1.51 Kn	Capacity	12.59 Kn	Passing Percentage	**833.77 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	3.36 Kn	Capacity	16.79 Kn	Passing Percentage	**499.70 %**
$V_{0.9D-WnUp}$	-3.56 Kn	Capacity	-20.98 Kn	Passing Percentage	**589.33 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 3.91 mm   Limit by Woolcock et al, 1999 Span/240= 15.63 mm
Deflection under Dead and Service Wind = 4.72 mm   Limit by Woolcock et al, 1999 Span/100 = 37.50 mm

Reactions

Maximum downward =3.36 kn   Maximum upward = -3.56 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds .... (Eq 4.12) = -21.73 kn > -3.56 Kn

Single Shear Capacity under short term loads = -9.75 Kn > -3.56 Kn

Intermediate Design Front and Back

Intermediate Spacing = 2500 mm   Intermediate Span = 2849 mm   Try Intermediate 2x140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =10.36   S1 Upward =0.58

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	2.56 Kn-m	Capacity	3.3 Kn-m	Passing Percentage	**128.91 %**
$V_{0.9D-WnUp}$	3.60 Kn	Capacity	-20.26 Kn	Passing Percentage	**562.78 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 19.5 mm   Limit byWoolcock et al, 1999 Span/100 = 28.49 mm

Reactions

Maximum = 3.60 kn

Girt Design Front and Back

Girt's Spacing = 1300 mm   Girt's Span = 2500 mm   Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.80   S1 Downward =10.36   S1 Upward =17.27

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.03 Kn-m	Capacity	1.32 Kn-m	Passing Percentage	**128.16 %**
$V_{0.9D-WnUp}$	1.64 Kn	Capacity	10.13 Kn	Passing Percentage	**617.68 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 9.69 mm   Limit by Woolcock et al, 1999 Span/100 = 25.00 mm

Sag during installation = 2.92 mm

Reactions

Maximum = 1.64 kn

Girt Design Sides

Girt's Spacing = 800 mm   Girt's Span = 3750 mm   Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.90   S1 Downward =10.36   S1 Upward =14.96

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.42 Kn-m	Capacity	1.48 Kn-m	Passing Percentage	**104.23 %**
$V_{0.9D-WnUp}$	1.51 Kn	Capacity	10.13 Kn	Passing Percentage	**670.86 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 30.18 mm   Limit by Woolcock et al. 1999 Span/100 = 37.50 mm

Sag during installation =14.80 mm

Reactions

Maximum = 1.51 kn

End Pole Design

Geometry For End Bay Pole

Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)		Dry Use	Height	3800 mm
Area		27598 mm2	As	20698.2421875 mm2
Ix		60639381 mm4	Zx	646820 mm3
Iy		60639381 mm4	Zx	646820 mm3
Lateral Restraint		mm c/c		

Loads

Total Area over Pole = 9.375 m2

Dead	2.34 Kn	Live	2.34 Kn
Wind Down	4.22 Kn	Snow	0.00 Kn
Moment Wind	4.09 Kn-m		
Phi	0.8	K8	0.66

| K1 snow | 0.8 | | K1 Dead | 0.6 |
| K1wind | 1 | | | |

Material

Peeling		Steaming	Normal		Dry Use
f_b =	36.3 MPa		f_s =		2.96 MPa
f_c =	18 MPa		f_p =		7.2 MPa
f_t =	22 MPa		E =		9257 MPa

Capacities

| PhiNcx Wind | 261.19 Kn | PhiMnx Wind | 12.35 Kn-m | PhiVnx Wind | 49.01 Kn |
| PhiNcx Dead | 156.71 Kn | PhiMnx Dead | 7.41 Kn-m | PhiVnx Dead | 29.41 Kn |

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.37 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.14 < 1 OK

Deflection at top under service lateral loads = 16.34 mm < 39.90 mm

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	3000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 9.375 m2

| Moment Wind = | 4.09 Kn-m |
| Shear Wind = | 1.36 Kn |

Pile Properties

Safety Factory	0.55	
Hu =	4.55 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.02 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.51 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3		Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))					
Kp =	(1+sin(30)) / (1-sin(30))					

Geometry For End Bay Pole

| Ds = | 0.6 mm | Pile Diameter |

L =	1300 mm	Pile embedment length
f1 =	3000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	4.09 Kn-m
Shear Wind =	1.36 Kn

Pile Properties

Safety Factory	0.55	
Hu =	4.55 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.02 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.51 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1300) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1300)

Skin Friction = 13.65 Kn

Weight of Pile + Pile Skin Friction = 17.45 Kn

Uplift on one Pile = 14.91 Kn

Uplift is ok

Last Page