Pole Shed App Ver 01 2022

First Page

Pole Shed App Ver 01 2022

Job No.: Buildright - 1 **Address:** 222 Maskells Road, Balcairn, New Zealand **Date:** 27/09/2024

Latitude: -43.178115 **Longitude:** 172.675338 **Elevation:** 95 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N4	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	3	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.6 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	41.3 m/s
Wind Pressure	1.02 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono Open

For roof Cp,i = 0.6941

For roof CP,e from 0 m To 1.65 m Cpe = -0.94 pe = -0.6 KPa pnet = -1.13 KPa

For roof CP,e from 1.65 m To 3.3 m Cpe = -0.88 pe = -0.56 KPa pnet = -1.09 KPa

For wall Windward Cp,i = 0.6941 side Wall Cp,i = -0.6389

For wall Windward and Leeward CP,e from 0 m To 6 m Cpe = 0.7 pe = 0.55 KPa pnet = 1.03 KPa

For side wall CP,e from 0 m To 3.3 m Cpe = pe = -0.51 KPa pnet = -0.03 KPa

Maximum Upward pressure used in roof member Design = 1.13 KPa

Maximum Downward pressure used in roof member Design = 0.64 KPa

Maximum Wall pressure used in Design = 1.03 KPa

Maximum Racking pressure used in Design = 0.94 KPa

Design Summary

Rafter Design Internal

Internal Rafter Load Width = 4800 mm Internal Rafter Span = 5850 mm Try Rafter 2x240x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =4.59 S1 Upward =4.59

Shear Capacity of timber =5.3 MPa Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	6.93 Kn-m	Capacity	27.86 Kn-m	Passing Percentage	**402.02 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	19.30 Kn-m	Capacity	37.16 Kn-m	Passing Percentage	**192.54 %**
$M_{0.9D-WnUp}$	-18.58 Kn-m	Capacity	-46.44 Kn-m	Passing Percentage	**249.95 %**
$V_{1.35D}$	4.74 Kn	Capacity	51.54 Kn	Passing Percentage	**1087.34 %**

Second page

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	13.20 Kn	Capacity	68.72 Kn	Passing Percentage	**520.61 %**
$V_{0.9D-WnUp}$	-12.71 Kn	Capacity	-85.9 Kn	Passing Percentage	**675.85 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 13.695 mm Limit by Woolcock et al, 1999 Span/240 = 25.00 mm

Deflection under Dead and Service Wind = 20.8 mm Limit by Woolcock et al, 1999 Span/100 = 60.00 mm

Reactions

Maximum downward =13.20 kn Maximum upward = -12.71 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 126 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 29.11 Kn > -12.71 Kn

Intermediate Design Front and Back

Intermediate Spacing = 2400 mm Intermediate Span = 2849 mm Try Intermediate 2x150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =9.63 S1 Upward =0.54

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	2.51 Kn-m	Capacity	4.2 Kn-m	Passing Percentage	**167.33 %**
$V_{0.9D-WnUp}$	3.52 Kn	Capacity	-24.12 Kn	Passing Percentage	**685.23 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 26.165 mm Limit byWoolcock et al, 1999 Span/100 = 28.49 mm

Reactions

Maximum = 3.52 kn

Girt Design Front and Back

Girt's Spacing = 1300 mm Girt's Span = 2400 mm Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.87 S1 Downward =9.63 S1 Upward =15.73

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.96 Kn-m	Capacity	1.83 Kn-m	Passing Percentage	**190.63 %**
$V_{0.9D-WnUp}$	1.61 Kn	Capacity	12.06 Kn	Passing Percentage	**749.07 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 9.89 mm Limit by Woolcock et al, 1999 Span/100 = 24.00 mm
Sag during installation = 2.01 mm

Reactions

Maximum = 1.61 kn

Girt Design Sides

Girt's Spacing = 1300 mm Girt's Span = 3000 mm Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.79 S1 Downward =9.63 S1 Upward =17.59

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.51 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	**109.27 %**
$V_{0.9D-WnUp}$	2.01 Kn	Capacity	12.06 Kn	Passing Percentage	**600.00 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 24.16 mm Limit by Woolcock et al. 1999 Span/100 = 30.00 mm
Sag during installation =4.91 mm

Reactions

Maximum = 2.01 kn

Middle Pole Design

Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3450 mm
Area	27598 mm2	As	20698.2421875 mm2
Ix	60639381 mm4	Zx	646820 mm3
Iy	60639381 mm4	Zx	646820 mm3
Lateral Restraint	3450 mm c/c		

Loads

Total Area over Pole = 14.4 m2

Dead	3.60 Kn	Live	3.60 Kn
Wind Down	9.22 Kn	Snow	9.07 Kn
Moment wind	10.94 Kn-m	Moment snow	3.88 Kn-m
Phi	0.8	K8	0.75
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	297.50 Kn	PhiMnx Wind	14.06 Kn-m	PhiVnx Wind	49.01 Kn
PhiNcx Dead	178.50 Kn	PhiMnx Dead	8.44 Kn-m	PhiVnx Dead	29.41 Kn
PhiNcx Snow	238.00 Kn	PhiMnx Snow	11.25 Kn-m	PhiVnx Snow	39.21 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.84 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.67 < 1 OK

Deflection at top under service lateral loads = 34.00 mm < 34.50 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied

f2 = 0 mm Distance of top soil at rest pressure

Loads

Moment Wind =	10.94 Kn-m	Moment Snow =	Kn-m
Shear Wind =	4.05 Kn	Shear Snow =	3.88 Kn

Pile Properties

Safety Factory	0.55	
Hu =	7.16 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	11.65 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.94 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1500) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1500)

Skin Friction = 18.17 Kn

Weight of Pile + Pile Skin Friction = 22.56 Kn

Uplift on one Pile = 13.03 Kn

Uplift is ok