First Page

Job No.: Jasmin Riceman - 1   **Address:** 69 Lauries Drive, Kauri, Whangarei, New Zealand   **Date:** 16/10/2024

Latitude: -35.654685   **Longitude:** 174.317582   **Elevation:** 188 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4.15 m
Wind Region	NZ1	Terrain Category	2.47	Design Wind Speed	42.18 m/s
Wind Pressure	1.07 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Gable   Enclosed

For roof $C_{p,i}$ = -0.3

For roof CP_e from 0 m To 4.15 m C_{pe} = -0.9 p_e = -0.86 KPa p_{net} = -0.86 KPa

For roof CP_e from 4.15 m To 8.30 m C_{pe} = -0.5 p_e = -0.48 KPa p_{net} = -0.48 KPa

For wall Windward $C_{p,i}$ = -0.3   side Wall $C_{p,i}$ = -0.3

For wall Windward and Leeward CP_e from 0 m To 12 m C_{pe} = 0.7 p_e = 0.67 KPa p_{net} = 0.99 KPa

For side wall CP_e from 0 m To 4.15 m C_{pe} = p_e = -0.62 KPa p_{net} = -0.62 KPa

Maximum Upward pressure used in roof member Design = 0.86 KPa

Maximum Downward pressure used in roof member Design = 0.42 KPa

Maximum Wall pressure used in Design = 0.99 KPa

Maximum Racking pressure used in Design = 0.96 KPa

Design Summary

Rafter Design Internal

Internal Rafter Load Width = 3000 mm   Internal Rafter Span = 7850 mm   Try Rafter 2x300x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =7.61   S1 Upward =7.61

Shear Capacity of timber =5.3 MPa   Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	7.80 Kn-m	Capacity	31.1 Kn-m	Passing Percentage	**398.72 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	16.64 Kn-m	Capacity	41.48 Kn-m	Passing Percentage	**249.28 %**
$M_{0.9D-WnUp}$	-14.67 Kn-m	Capacity	-51.84 Kn-m	Passing Percentage	**353.37 %**
$V_{1.35D}$	3.97 Kn	Capacity	46.02 Kn	Passing Percentage	**1159.19 %**

Second page

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	8.48 Kn	Capacity	61.36 Kn	Passing Percentage	**723.58 %**
$V_{0.9D-WnUp}$	-7.48 Kn	Capacity	-76.7 Kn	Passing Percentage	**1025.40 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 19.395 mm   Limit by Woolcock et al, 1999 Span/240 = 33.33 mm

Deflection under Dead and Service Wind = 25.5 mm   Limit by Woolcock et al, 1999 Span/100 = 80.00 mm

Reactions

Maximum downward =8.48 kn   Maximum upward = -7.48 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 29.11 Kn > -7.48 Kn

Rafter Design External

External Rafter Load Width = 1500 mm   External Rafter Span = 2496 mm   Try Rafter 300x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.88

K8 Upward =0.88   S1 Downward =15.50   S1 Upward =15.50

Shear Capacity of timber =5.3 MPa   Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.39 Kn-m	Capacity	13.69 Kn-m	Passing Percentage	**3510.26 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.04 Kn-m	Capacity	18.26 Kn-m	Passing Percentage	**1755.77 %**
$M_{0.9D-WnUp}$	-0.74 Kn-m	Capacity	-22.82 Kn-m	Passing Percentage	**3083.78 %**
$V_{1.35D}$	0.63 Kn	Capacity	23.01 Kn	Passing Percentage	**3652.38 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.35 Kn	Capacity	30.68 Kn	Passing Percentage	**2272.59 %**
$V_{0.9D-WnUp}$	-1.19 Kn	Capacity	-38.35 Kn	Passing Percentage	**3222.69 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

$k2$ for Long Term Loads = 2

Deflection under Dead and Live Load = 0.24 mm   Limit by Woolcock et al, 1999 Span/240= 10.83 mm

Deflection under Dead and Service Wind = 0.28 mm   Limit by Woolcock et al, 1999 Span/100 = 26.00 mm

Reactions

Maximum downward =1.35 kn   Maximum upward = -1.19 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

$K11$ = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

$K11$ = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x $k1$ x $k4$ x $k5$ x fs x b x ds .... (Eq 4.12) = -40.07 kn > -1.19 Kn

Single Shear Capacity under short term loads = -14.56 Kn > -1.19 Kn

Girt Design Front and Back

Girt's Spacing = 0 mm   Girt's Span = 3000 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

$K1$ Short term = 1 $K4$ =1 $K5$ =1 $K8$ Downward =1.00

$K8$ Upward =0.79 $S1$ Downward =9.63 $S1$ Upward =17.59

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	**Infinity %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	12.06 Kn	Passing Percentage	**Infinity %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 0.00 mm   Limit by Woolcock et al, 1999 Span/100 = 30.00 mm

Sag during installation = 4.91 mm

Reactions

Maximum = 0.00 kn

Girt Design Sides

Girt's Spacing = 1300 mm   Girt's Span = 2600 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.84   S1 Downward =9.63   S1 Upward =16.37

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.09 Kn-m	Capacity	1.77 Kn-m	Passing Percentage	**162.39 %**
$V_{0.9D-WnUp}$	1.67 Kn	Capacity	12.06 Kn	Passing Percentage	**722.16 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 8.13 mm   Limit by Woolcock et al. 1999 Span/100 = 26.00 mm
Sag during installation =2.77 mm

Reactions

Maximum = 1.67 kn

Middle Pole Design

Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3850 mm
Area	27598 mm2	As	20698.2421875 mm2
Ix	60639381 mm4	Zx	646820 mm3
Iy	60639381 mm4	Zx	646820 mm3
Lateral Restraint	3850 mm c/c		

Loads

Total Area over Pole = 12 m2

Dead	3.00 Kn	Live	3.00 Kn
Wind Down	5.04 Kn	Snow	0.00 Kn
Moment wind	9.28 Kn-m		
Phi	0.8	K8	0.64
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

| PhiNcx Wind | 255.93 Kn | PhiMnx Wind | 12.10 Kn-m | PhiVnx Wind | 49.01 Kn |
| PhiNcx Dead | 153.56 Kn | PhiMnx Dead | 7.26 Kn-m | PhiVnx Dead | 29.41 Kn |

Checks

$(Mx/PhiMnx)+(N/phiNcx) = 0.81 < 1$ OK

$(Mx/PhiMnx)^2+(N/phiNcx) = 0.63 < 1$ OK

Deflection at top under service lateral loads = 37.10 mm < 38.50 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

| Gamma | 18 Kn/m3 | | Friction angle | 30 deg | Cohesion | 0 Kn/m3 |

$K_0 =$ (1-sin(30)) / (1+sin(30))

$K_p =$ (1+sin(30)) / (1-sin(30))

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	3113 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

| Moment Wind = | 9.28 Kn-m |
| Shear Wind = | 2.98 Kn |

Pile Properties

Safety Factory	0.55	
Hu =	5.42 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.94 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.93 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)		Dry Use		Height	3850 mm
Area		27598 mm2	As	20698.2421875 mm2
Ix		60639381 mm4	Zx	646820 mm3
Iy		60639381 mm4	Zx	646820 mm3
Lateral Restraint		mm c/c		

Loads

Total Area over Pole = 3.90000000117 m2

Dead	0.98 Kn		Live	0.98 Kn	
Wind Down	1.64 Kn		Snow	0.00 Kn	
Moment Wind	2.28 Kn-m				
Phi	0.8		K8	0.64	
K1 snow	0.8		K1 Dead	0.6	
K1wind	1				

Material

Peeling	Steaming	Normal	Dry Use
$f_b =$	36.3 MPa	$f_s =$	2.96 MPa
$f_c =$	18 MPa	$f_p =$	7.2 MPa
$f_t =$	22 MPa	$E =$	9257 MPa

Capacities

PhiNcx Wind	256.04 Kn	PhiMnx Wind	12.10 Kn-m	PhiVnx Wind	49.01 Kn
PhiNcx Dead	153.62 Kn	PhiMnx Dead	7.26 Kn-m	PhiVnx Dead	29.41 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.20 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.05 < 1 OK

Deflection at top under service lateral loads = 9.78 mm < 41.40 mm

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	3113 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 3.90000000117 m2

Moment Wind =	2.28 Kn-m
Shear Wind =	0.73 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.42 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.94 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.23 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				

$Kp =$ $(1+\sin(30)) / (1-\sin(30))$

Geometry For End Bay Pole

$Ds =$	0.6 mm	Pile Diameter
$L =$	1400 mm	Pile embedment length
$f1 =$	3113 mm	Distance at which the shear force is applied
$f2 =$	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	2.28 Kn-m
Shear Wind =	0.73 Kn

Pile Properties

Safety Factory	0.55	
$Hu =$	5.42 Kn	Ultimate Lateral Strength of the Pile, Short pile
$Mu =$	9.94 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.23 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 19.92 Kn

Uplift on one Pile = 7.62 Kn

Uplift is ok

Last Page