

Job Number:

Issue:

**BWhite  
Consulting Ltd**

**PRODUCER STATEMENT-PS1-DESIGN**

ISSUED BY: **BWhite Consulting Ltd (Design Engineer: Bevan White)**

TO BE SUPPLIED TO: **Westland District Council** IN RESPECT OF: **Proposed NEW Farm Shed**

AT: **1 Harrison Place, Greymouth, New Zealand**

**LEGAL DESCRIPTION**

We have been engaged by **Ezequote Pty Ltd** to provide **Specific Structural Engineering Design** services in respect of the requirements of Clause(s) **B1** of the Building Code for part only (as specified in the attachment to this statement), of the proposed building work.

☐ ALL ☒ Part only as specified: Purlins, Rafters, Girts, Poles, Columns, Pole embedment and all connections

The design has been prepared in accordance with compliance documents to NZ Building Code issued by Ministry of Business, Innovation & Employment Clauses **B1/VM1 and B1/VM4**

The proposed building work covered by the producer statement is described on **Ezequote** drawings title **2502005** and numbered **A101 - A114 Rev-1** dated **23/04/2025** together with the following specification, and other documents set out in the schedule attached to this statement: **Design Featured Report Dated 21/04/2025 and numbered "Second Page"**

On behalf of **BWhite Consulting Ltd**, and subject to:

1. Site verification of the following design assumptions: **an Ultimate foundation bearing pressure of 300 kPa in accordance with NZS3604:2011**
2. **The building has a design life of 50 years and an Importance Level 1**
3. **Unless specifically noted, compliance of the drawings to Non-Specific codes such as NZS3604 and NZS4229 have not been checked by this practice**
4. **This Certificate does not cover any other building code clause including weather tightness**
5. **Inspections of the building to be completed by Westland District Council. As BWhite Consulting Ltd are not undertaking inspections, we cannot issue a producer Statement-PS4- Construction Review.**
6. **This Producer Statement- Design is valid for a building consent issued within 1 year from the date of issue**
7. All proprietary products meeting their performance specification requirements

**I believe on reasonable grounds** that a) the building, if constructed in accordance with the drawings, specifications, and other documents provided or listed in the attached schedule, will comply with the relevant provisions of the Building Code and that b), the persons who have undertaken the design have the necessary competency to do so. I also recommend the follow level of construction monitoring/observation:

☒ CM1 ☐ CM2 ☐ CM3 ☐ CM4 ☐ CM5 or as per agreement with owner/developer (**stated above**)

I, **Bevan White** am CPEng **108276** I am Member of Engineering New Zealand and hold the following qualification: **BE Civil** and holds a current policy of Professional Indemnity Insurance no less than \$200,000

Signed by **Bevan White** on behalf of **BWhite Consulting Ltd** Dated: **21/04/2025**

Email: **bwhitecpeng@gmail.com** Phone: **0211-979786**

Note: This statement shall only be relied upon by the Building Consent Authority named above. Liability under this statement accrues to the Design Firm only. The total maximum amount of damages payable arising from this statement and all other statements provided to the Building Consent Authority in relation to this building work, whether in contract, tort or otherwise (including negligence), is limited to the sum of \$200,000.

This form is to accompany Form 2 of the Building (Forms) Regulations 2004 for the application of a Building Consent

**Date:** 21/04/2025

18B Jules Crescent,

Bell Block New Plymouth 4312

New Zealand

File No:

**BWhite  
Consulting Ltd**

**DESIGN FEATURES SUMMARY FOR PROPOSED NEW FARM SHED 1 HARRISON PLACE, GREYMOUTH, NEW ZEALAND**

**Site Specific Loads**

|                  |          |                        |           |                      |           |
|------------------|----------|------------------------|-----------|----------------------|-----------|
| Roof Live Load   | 0.25 KPa | Roof Dead Load         | 0.25 KPa  | Roof Live Point Load | 1.1 Kn    |
| Snow Zone        | N0       | Ground Snow Load       | 0 KPa     | Roof Snow Load       | 0 KPa     |
| Earthquake Zone  | 3        | Subsoil Category       | D         | Exposure Zone        | D         |
| Importance Level | 1        | Ultimate wind & EQ ARI | 100 Years | Max Height           | 4 m       |
| Wind Region      | NZ2      | Terrain Category       | 3.0       | Design Wind Speed    | 35.23 m/s |
| Wind Pressure    | 0.74 KPa | Lee Zone               | NO        | Ultimate Snow ARI    | 50 Years  |

**Timber**

Sawn Timber to be graded to the properties of SG6 and SG8 or better as mentioned on plans, with moisture content of 18% or less for dry and 25% or less for wet.

The following standards have been used in the design of this structure

- NZS 3603:1993 Timber Structures Standard
- NZS 3604:2011 Timber Framed Buildings. Standards New Zealand, 2011
- NZS 3404:1997 Steel Structures
- AS/NZS 1170 2003 Structural Design Actions
- AS/NZS 1170.2 2021 Structural Design Actions-Wind Action
- Branz. "Engineering Basis of NZS 3604". April 2013

Yours Faithfully

**BWhite CONSULTING LTD**

**Bevan White**

Director | BE Civil . CMengNZ CPEng

Email: bwhitecpeng@gmail.com Contact: 0211 979 786

Pole Shed App Ver 01 2022

**Job No.:** 2502005

**Address:** 1 Harrison Place, Greymouth, New Zealand

**Date:** 21/04/2025

**Latitude:** -42.575822

**Longitude:** 171.13506

**Elevation:** 33.5 m

**General Input**

|                  |          |                                |           |                      |           |
|------------------|----------|--------------------------------|-----------|----------------------|-----------|
| Roof Live Load   | 0.25 KPa | Roof Dead Load                 | 0.25 KPa  | Roof Live Point Load | 1.1 Kn    |
| Snow Zone        | N0       | Ground Snow Load               | 0 KPa     | Roof Snow Load       | 0 KPa     |
| Earthquake Zone  | 3        | Subsoil Category               | D         | Exposure Zone        | D         |
| Importance Level | 1        | Ultimate wind & Earthquake ARI | 100 Years | Max Height           | 4 m       |
| Wind Region      | NZ2      | Terrain Category               | 3.0       | Design Wind Speed    | 35.23 m/s |
| Wind Pressure    | 0.74 KPa | Lee Zone                       | NO        | Ultimate Snow ARI    | 50 Years  |
| Wind Category    | Medium   | Earthquake ARI                 | 100       |                      |           |

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Mono Open

For roof  $C_{p,i} = 0.6624$

For roof  $C_{p,e}$  from 0 m To 1.91 m  $C_{p,e} = -0.845$   $p_e = -0.47$  KPa  $p_{net} = -0.91$  KPa

For roof  $C_{p,e}$  from 1.91 m To 3.83 m  $C_{p,e} = -0.845$   $p_e = -0.47$  KPa  $p_{net} = -0.91$  KPa

For wall Windward  $C_{p,i} = 0.6624$  side Wall  $C_{p,i} = -0.5802$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 9 m  $C_{p,e} = 0.7$   $p_e = 0.47$  KPa  $p_{net} = 0.94$  KPa

For side wall  $C_{p,e}$  from 0 m To 3.83 m  $C_{p,e} =$   $p_e = -0.44$  KPa  $p_{net} = 0.03$  KPa

Maximum Upward pressure used in roof member Design = 0.91 KPa

Maximum Downward pressure used in roof member Design = 0.54 KPa

Maximum Wall pressure used in Design = 0.94 KPa

Maximum Racking pressure used in Design = 0.81 KPa

**Design Summary**

**Purlin Design**

Purlin Spacing = 900 mm

Purlin Span = 4350 mm

Try Purlin 240x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

condition after installation)

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 0.94

K8 Upward = 0.60    S1 Downward = 13.82    S1 Upward = 21.36

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

|   |            |          |            |                    |                  |
|---|------------|----------|------------|--------------------|------------------|
| M <sub>1.35D</sub>  | 0.72 Kn-m  | Capacity | 2.73 Kn-m  | Passing Percentage | <b>379.17 %</b>  |
| M <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub> | 2.43 Kn-m  | Capacity | 3.64 Kn-m  | Passing Percentage | <b>149.79 %</b>  |
| M <sub>0.9D-W<sub>n</sub>Up</sub>   | -1.46 Kn-m | Capacity | -2.93 Kn-m | Passing Percentage | <b>200.68 %</b>  |
| V <sub>1.35D</sub>  | 0.66 Kn    | Capacity | 10.42 Kn   | Passing Percentage | <b>1578.79 %</b> |
| V <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub> | 1.64 Kn    | Capacity | 13.89 Kn   | Passing Percentage | <b>846.95 %</b>  |
| V <sub>0.9D-W<sub>n</sub>Up</sub>   | -1.34 Kn   | Capacity | -17.37 Kn  | Passing Percentage | <b>1296.27 %</b> |

#### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 11.01 mm    Limit by Woolcock et al, 1999 Span/240 = 17.92 mm

Deflection under Dead and Service Wind = 8.88 mm    Limit by Woolcock et al, 1999 Span/100 = 43.00 mm

#### Reactions

Maximum downward = 1.64 kn    Maximum upward = -1.34 kn

Number of Blocking = 1    if 0 then no blocking required, if 1 then one midspan blocking required

#### Rafter Design Internal

Internal Rafter Load Width = 4500 mm    Internal Rafter Span = 5850 mm    Try Rafter 2x300x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 1.00

K8 Upward = 1.00    S1 Downward = 7.61    S1 Upward = 7.61

Shear Capacity of timber = 5.3 MPa    Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

Pole Shed App Ver 01 2022

|  |             |          |             |                    |                  |
|--|-------------|----------|-------------|--------------------|------------------|
| M <sub>1.35D</sub>                       | 6.50 Kn-m   | Capacity | 31.1 Kn-m   | Passing Percentage | <b>478.46 %</b>  |
| M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub> | 16.17 Kn-m  | Capacity | 41.48 Kn-m  | Passing Percentage | <b>256.52 %</b>  |
| M <sub>0.9D-WnUp</sub>                   | -13.19 Kn-m | Capacity | -51.84 Kn-m | Passing Percentage | <b>393.03 %</b>  |
| V <sub>1.35D</sub>                       | 4.44 Kn     | Capacity | 46.02 Kn    | Passing Percentage | <b>1036.49 %</b> |
| V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub> | 11.06 Kn    | Capacity | 61.36 Kn    | Passing Percentage | <b>554.79 %</b>  |
| V <sub>0.9D-WnUp</sub>                   | -9.02 Kn    | Capacity | -76.7 Kn    | Passing Percentage | <b>850.33 %</b>  |

**Deflections**

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 9.205 mm      Limit by Woolcock et al, 1999 Span/240 = 25.00 mm

Deflection under Dead and Service Wind = 13.125 mm      Limit by Woolcock et al, 1999 Span/100 = 60.00 mm

**Reactions**

Maximum downward = 11.06 kn    Maximum upward = -9.02 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K<sub>11</sub> = 12.6 f<sub>pj</sub> = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K<sub>11</sub> = 2.0 f<sub>cj</sub> = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 29.11 Kn > -9.02 Kn

**Intermediate Design Sides**

Intermediate Spacing = 3000 mm      Intermediate Span = 3675 mm      Try Intermediate 2x190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Pole Shed App Ver 01 2022

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =0.98

K8 Upward =1.00    S1 Downward =12.23    S1 Upward =0.78

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

|                        |           |          |           |                    |                  |
|------------------------|-----------|----------|-----------|--------------------|------------------|
| M <sub>Wind+Snow</sub> | 2.38 Kn-m | Capacity | 6.06 Kn-m | Passing Percentage | <b>254.62 %</b>  |
| V <sub>0.9D-WnUp</sub> | 2.59 Kn   | Capacity | 27.5 Kn   | Passing Percentage | <b>1061.78 %</b> |

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 24.11 mm    Limit by Woolcock et al, 1999 Span/100 = 36.75 mm

**Reactions**

Maximum = 2.59 kn

**Girt Design Front and Back**

Girt's Spacing = 800 mm                      Girt's Span = 4500 mm                      Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =0.98

K8 Upward =0.70    S1 Downward =12.23    S1 Upward =19.33

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

|                        |           |          |           |                    |                 |
|------------------------|-----------|----------|-----------|--------------------|-----------------|
| M <sub>Wind+Snow</sub> | 1.90 Kn-m | Capacity | 2.13 Kn-m | Passing Percentage | <b>112.11 %</b> |
| V <sub>0.9D-WnUp</sub> | 1.69 Kn   | Capacity | 13.75 Kn  | Passing Percentage | <b>813.61 %</b> |

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 23.30 mm    Limit by Woolcock et al, 1999 Span/100 = 45.00 mm

Sag during installation = 30.70 mm

**Reactions**

Maximum = 1.69 kn

### Girt Design Sides

Girt's Spacing = 1300 mm

Girt's Span = 3000 mm

Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =0.98

K8 Upward =0.56    S1 Downward =12.23    S1 Upward =22.32

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

|                        |           |          |           |                    |                 |
|------------------------|-----------|----------|-----------|--------------------|-----------------|
| M <sub>Wind+Snow</sub> | 1.37 Kn-m | Capacity | 1.70 Kn-m | Passing Percentage | <b>124.09 %</b> |
| V <sub>0.9D-WnUp</sub> | 1.83 Kn   | Capacity | 13.75 Kn  | Passing Percentage | <b>751.37 %</b> |

### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 7.48 mm    Limit by Woolcock et al. 1999 Span/100 = 30.00 mm  
Sag during installation =6.06 mm

### Reactions

Maximum = 1.83 kn

### Middle Pole Design

#### Geometry

|  |                           |                |                               |
|--|---------------------------|----------------|-------------------------------|
| 200 SED H5 (Minimum 225 dia. at Floor Level) | Dry Use                   | Height         | 3710 mm                       |
| Area   | 35448 mm <sup>2</sup>     | As             | 26585.7421875 mm <sup>2</sup> |
| I <sub>x</sub>                               | 100042702 mm <sup>4</sup> | Z <sub>x</sub> | 941578 mm <sup>3</sup>        |
| I <sub>y</sub>                               | 100042702 mm <sup>4</sup> | Z <sub>y</sub> | 941578 mm <sup>3</sup>        |
| Lateral Restraint                            | 1300 mm c/c               |                |                               |

### Loads

Total Area over Pole = 13.5 m<sup>2</sup>

|      |         |      |         |
|------|---------|------|---------|
| Dead | 3.38 Kn | Live | 3.38 Kn |
|------|---------|------|---------|

Pole Shed App Ver 01 2022

|             |            |         |         |
|-------------|------------|---------|---------|
| Wind Down   | 7.29 Kn    | Snow    | 0.00 Kn |
| Moment wind | 10.91 Kn-m |         |         |
| Phi         | 0.8        | K8      | 1.00    |
| K1 snow     | 0.8        | K1 Dead | 0.6     |
| K1 wind     | 1          |         |         |

**Material**

|         |          |        |          |
|---------|----------|--------|----------|
| Peeling | Steaming | Normal | Dry Use  |
| fb =    | 36.3 MPa | fs =   | 2.96 MPa |
| fc =    | 18 MPa   | fp =   | 7.2 MPa  |
| ft =    | 22 MPa   | E =    | 9257 MPa |

**Capacities**

|             |           |             |            |             |          |
|-------------|-----------|-------------|------------|-------------|----------|
| PhiNcx Wind | 510.45 Kn | PhiMnx Wind | 27.34 Kn-m | PhiVnx Wind | 62.96 Kn |
| PhiNcx Dead | 306.27 Kn | PhiMnx Dead | 16.41 Kn-m | PhiVnx Dead | 37.77 Kn |

**Checks**

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.43 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.19 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 24.56 \text{ mm} < 37.10 \text{ mm}$$

**Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

|       |                                   |                |        |          |                     |
|-------|-----------------------------------|----------------|--------|----------|---------------------|
| Gamma | 18 Kn/m <sup>3</sup>              | Friction angle | 30 deg | Cohesion | 0 Kn/m <sup>3</sup> |
| K0 =  | $(1 - \sin(30)) / (1 + \sin(30))$ |                |        |          |                     |
| Kp =  | $(1 + \sin(30)) / (1 - \sin(30))$ |                |        |          |                     |

**Geometry For Middle Bay Pole**

|      |         |  |
|------|---------|--|
| Ds = | 0.6 mm  | Pile Diameter                                |
| L =  | 1600 mm | Pile embedment length                        |
| f1 = | 3000 mm | Distance at which the shear force is applied |
| f2 = | 0 mm    | Distance of top soil at rest pressure        |

**Loads**

|               |            |
|---------------|------------|
| Moment Wind = | 10.91 Kn-m |
|---------------|------------|



Pole Shed App Ver 01 2022

Shear Wind = 3.64 Kn

**Pile Properties**

|                |            |   |
|----------------|------------|---|
| Safety Factory | 0.55       |   |
| Hu =           | 7.93 Kn    | Ultimate Lateral Strength of the Pile, Short pile |
| Mu =           | 14.27 Kn-m | Ultimate Moment Capacity of Pile                  |

**Checks**

Applied Forces/Capacities = 0.76 < 1 OK

**End Pole Design**

**Geometry For End Bay Pole**

**Geometry**

|  |                          |        |                               |
|--|--------------------------|--------|-------------------------------|
| 175 SED H5 (Minimum 200 dia. at Floor Level) | Dry Use                  | Height | 3800 mm                       |
| Area   | 27598 mm <sup>2</sup>    | As     | 20698.2421875 mm <sup>2</sup> |
| Ix   | 60639381 mm <sup>4</sup> | Zx     | 646820 mm <sup>3</sup>        |
| Iy   | 60639381 mm <sup>4</sup> | Zx     | 646820 mm <sup>3</sup>        |
| Lateral Restraint                            | mm c/c                   |        |                               |

**Loads**

Total Area over Pole = 13.5 m<sup>2</sup>

|             |           |         |         |
|-------------|-----------|---------|---------|
| Dead        | 3.38 Kn   | Live    | 3.38 Kn |
| Wind Down   | 7.29 Kn   | Snow    | 0.00 Kn |
| Moment Wind | 5.45 Kn-m |         |         |
| Phi         | 0.8       | K8      | 0.66    |
| K1 snow     | 0.8       | K1 Dead | 0.6     |
| K1 wind     | 1         |         |         |

**Material**

|         |          |        |          |
|---------|----------|--------|----------|
| Peeling | Steaming | Normal | Dry Use  |
| fb =    | 36.3 MPa | fs =   | 2.96 MPa |
| fc =    | 18 MPa   | fp =   | 7.2 MPa  |
| ft =    | 22 MPa   | E =    | 9257 MPa |

**Capacities**

Pole Shed App Ver 01 2022

|             |           |             |            |             |          |
|-------------|-----------|-------------|------------|-------------|----------|
| PhiNcx Wind | 261.19 Kn | PhiMnx Wind | 12.35 Kn-m | PhiVnx Wind | 49.01 Kn |
| PhiNcx Dead | 156.71 Kn | PhiMnx Dead | 7.41 Kn-m  | PhiVnx Dead | 29.41 Kn |

**Checks**

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.50 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.25 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 21.79 \text{ mm} < 39.90 \text{ mm}$$

|      |         |  |
|------|---------|--|
| Ds = | 0.6 mm  | Pile Diameter                                |
| L =  | 1300 mm | Pile embedment length                        |
| f1 = | 3000 mm | Distance at which the shear force is applied |
| f2 = | 0 mm    | Distance of top soil at rest pressure        |

**Loads**

$$\text{Total Area over Pole} = 13.5 \text{ m}^2$$

|               |           |
|---------------|-----------|
| Moment Wind = | 5.45 Kn-m |
| Shear Wind =  | 1.82 Kn   |

**Pile Properties**

|                |           |   |
|----------------|-----------|---|
| Safety Factory | 0.55      |   |
| Hu =           | 4.55 Kn   | Ultimate Lateral Strength of the Pile, Short pile |
| Mu =           | 8.02 Kn-m | Ultimate Moment Capacity of Pile                  |

**Checks**

$$\text{Applied Forces/Capacities} = 0.68 < 1 \text{ OK}$$

**Drained Lateral Strength of End pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

|       |                                   |                |        |          |                     |
|-------|-----------------------------------|----------------|--------|----------|---------------------|
| Gamma | 18 Kn/m <sup>3</sup>              | Friction angle | 30 deg | Cohesion | 0 Kn/m <sup>3</sup> |
| K0 =  | $(1 - \sin(30)) / (1 + \sin(30))$ |                |        |          |                     |
| Kp =  | $(1 + \sin(30)) / (1 - \sin(30))$ |                |        |          |                     |

**Geometry For End Bay Pole**

|      |         |                       |
|------|---------|-----------------------|
| Ds = | 0.6 mm  | Pile Diameter         |
| L =  | 1300 mm | Pile embedment length |

Pole Shed App Ver 01 2022

f1 = 3000 mm Distance at which the shear force is applied  
f2 = 0 mm Distance of top soil at rest pressure

**Loads**

Moment Wind = 5.45 Kn-m  
Shear Wind = 1.82 Kn

**Pile Properties**

Safety Factory 0.55  
Hu = 4.55 Kn Ultimate Lateral Strength of the Pile, Short pile  
Mu = 8.02 Kn-m Ultimate Moment Capacity of Pile

**Checks**

Applied Forces/Capacities = 0.68 < 1 OK

**Uplift Check**

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1600) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1600)

Skin Friction = 20.68 Kn

Weight of Pile + Pile Skin Friction = 24.83 Kn

Uplift on one Pile = 9.25 Kn

Uplift is ok