



Pole Shed App Ver 01 2022

**Job No.:** Smith Rd (Ed) - 1      **Address:** 130 Smith Road, Matakana 0985, New Zealand      **Date:** 3/19/2025  
**Latitude:** -36.32632      **Longitude:** 174.690857      **Elevation:** 56.5 m

**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	500 Years	Max Height	5.38 m
Wind Region	NZ1	Terrain Category	2.7	Design Wind Speed	41.63 m/s
Wind Pressure	1.04 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Gable Enclosed

For roof  $C_{p,i} = -0.3$

For roof  $C_{p,e}$  from 0 m To 5.38 m  $C_{p,e} = -0.9$   $p_e = -0.84$  KPa  $p_{net} = -0.84$  KPa

For roof  $C_{p,e}$  from 5.38 m To 10.75 m  $C_{p,e} = -0.5$   $p_e = -0.47$  KPa  $p_{net} = -0.47$  KPa

For wall Windward  $C_{p,i} = -0.3$  side Wall  $C_{p,i} = -0.3$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 16 m  $C_{p,e} = 0.7$   $p_e = 0.66$  KPa  $p_{net} = 0.97$  KPa

For side wall  $C_{p,e}$  from 0 m To 5.38 m  $C_{p,e} =$   $p_e = -0.61$  KPa  $p_{net} = -0.61$  KPa

Maximum Upward pressure used in roof member Design = 0.84 KPa

Maximum Downward pressure used in roof member Design = 0.40 KPa

Maximum Wall pressure used in Design = 0.97 KPa

Maximum Racking pressure used in Design = 1.31 KPa

**Design Summary**

**Rafter Design Internal**

Internal Rafter Load Width = 4000 mm      Internal Rafter Span = 9850 mm      Try Rafter 2x360x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

### Pole Shed App Ver 01 2022

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 1.00

K8 Upward = 1.00    S1 Downward = 5.90    S1 Upward = 5.90

Shear Capacity of timber = 5.3 MPa    Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>1.35D</sub>	16.37 Kn-m	Capacity	60.82 Kn-m	Passing Percentage	<b>371.53 %</b>
M <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	33.96 Kn-m	Capacity	81.1 Kn-m	Passing Percentage	<b>238.81 %</b>
M <sub>0.9D-W<sub>n</sub>Up</sub>	-29.83 Kn-m	Capacity	-101.38 Kn-m	Passing Percentage	<b>339.86 %</b>
V <sub>1.35D</sub>	6.65 Kn	Capacity	77.32 Kn	Passing Percentage	<b>1162.71 %</b>
V <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	13.79 Kn	Capacity	103.08 Kn	Passing Percentage	<b>747.50 %</b>
V <sub>0.9D-W<sub>n</sub>Up</sub>	-12.12 Kn	Capacity	-128.86 Kn	Passing Percentage	<b>1063.20 %</b>

#### **Deflections**

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 26.095 mm    Limit by Woolcock et al, 1999 Span/240 = 41.67 mm

Deflection under Dead and Service Wind = 33.83 mm    Limit by Woolcock et al, 1999 Span/100 = 100.00 mm

#### **Reactions**

Maximum downward = 13.79 kn    Maximum upward = -12.12 kn

#### **Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K<sub>11</sub> = 12.6 f<sub>pj</sub> = 22.7 Mpa for Rafter with effective thickness = 126 mm

For Parallel to grain loading

K<sub>11</sub> = 2.0 f<sub>cj</sub> = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 29.11 Kn > -12.12 Kn

## Girt Design Front and Back

Girt's Spacing = 0 mm

Girt's Span = 4000 mm

Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =NaN

K8 Upward =NaN    S1 Downward =NaN    S1 Upward =NaN

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	NaN %
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	NaN %

### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm    Limit by Woolcock et al, 1999 Span/100 = 40.00 mm

Sag during installation = NaN mm

### Reactions

Maximum = 0.00 kn

## Girt Design Sides

Girt's Spacing = 0 mm

Girt's Span = 2500 mm

Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =NaN

K8 Upward =NaN    S1 Downward =NaN    S1 Upward =NaN

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	NaN %
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	NaN %

## Pole Shed App Ver 01 2022

### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm      Limit by Woolcock et al. 1999 Span/100 = 25.00 mm

Sag during installation = NaN mm

### Reactions

Maximum = 0.00 kn

### Middle Pole Design

#### Geometry

250 SED H5 (Minimum 275 dia. at Floor Level)	Dry Use	Height	5020 mm
Area	54091 mm <sup>2</sup>	As	40568.5546875 mm <sup>2</sup>
Ix	232952248 mm <sup>4</sup>	Zx	1774874 mm <sup>3</sup>
Iy	232952248 mm <sup>4</sup>	Zx	1774874 mm <sup>3</sup>
Lateral Restraint	5020 mm c/c		

#### Loads

Total Area over Pole = 20 m<sup>2</sup>

Dead	5.00 Kn	Live	5.00 Kn
Wind Down	8.00 Kn	Snow	0.00 Kn
Moment wind	28.37 Kn-m		
Phi	0.8	K8	0.71
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

#### Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

#### Capacities

PhiNcx Wind	555.45 Kn	PhiMnx Wind	36.76 Kn-m	PhiVnx Wind	96.07 Kn
PhiNcx Dead	333.27 Kn	PhiMnx Dead	22.05 Kn-m	PhiVnx Dead	57.64 Kn

#### Checks

$$(M_x/\phi M_{nx}) + (N/\phi N_c) = 0.80 < 1 \text{ OK}$$

$$(M_x/\phi M_{nx})^2 + (N/\phi N_c) = 0.63 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 49.92 \text{ mm} < 50.20 \text{ mm}$$

### **Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile**

#### Assumed Soil Properties

Gamma 18 Kn/m<sup>3</sup> Friction angle 30 deg Cohesion 0 Kn/m<sup>3</sup>

$$K_0 = (1 - \sin(30)) / (1 + \sin(30))$$

$$K_p = (1 + \sin(30)) / (1 - \sin(30))$$

#### Geometry For Middle Bay Pole

Ds = 0.6 mm Pile Diameter

L = 2100 mm Pile embedment length

f1 = 4035 mm Distance at which the shear force is applied

f2 = 0 mm Distance of top soil at rest pressure

#### Loads

Moment Wind = 28.37 Kn-m

Shear Wind = 7.03 Kn

#### Pile Properties

Safety Factory 0.55

Hu = 13.45 Kn Ultimate Lateral Strength of the Pile, Short pile

Mu = 32.46 Kn-m Ultimate Moment Capacity of Pile

#### Checks

$$\text{Applied Forces/Capacities} = 0.87 < 1 \text{ OK}$$

### **Uplift Check**

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Pole Shed App Ver 01 2022

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(2100) x Ks(1.5) x  $0.5 \times \tan(30)$  x  $\pi$  x Dia of Pile(0.6) x Height of Pile(2100)

Skin Friction = 35.62 Kn

Weight of Pile + Pile Skin Friction = 39.84 Kn

Uplift on one Pile = 12.30 Kn

Uplift is ok