<u>Pole Shed App Ver 01 2022</u>

Pole Shed App Ver 01 2022

| | | |
|---|---|---|
| **Job No.:** Wither Hills Farm Park Woolshed-Training Bay 6000 | **Address:** Lot 1 DP 8914, Redwood Street, Witherlea, New Zealand | **Date:** 25/06/2025 |
| **Latitude:** -41.544902 | **Longitude:** 173.963463 | **Elevation:** 48.5 m |

**General Input**

| | | | | | |
|---|---|---|---|---|---|
| Roof Live Load | 0.25 KPa | Roof Dead Load | 0.25 KPa | Roof Live Point Load | 1.1 Kn |
| Snow Zone | N3 | Ground Snow Load | 0 KPa | Roof Snow Load | 0 KPa |
| Earthquake Zone | 3 | Subsoil Category | D | Exposure Zone | B |
| Importance Level | 1 | Ultimate wind & Earthquake ARI | 100 Years | Max Height | 6.8 m |
| Wind Region | NZ2 | Terrain Category | 1.91 | Design Wind Speed | 40.36 m/s |
| Wind Pressure | 0.98 KPa | Lee Zone | NO | Ultimate Snow ARI | 50 Years |
| Wind Category | High | Earthquake ARI | 100 | | |

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressues**

Shed Type = Gable Enclosed

For roof Cp,i = -0.3

For roof CP,e from 0 m To 4.5 m Cpe = -1.0689 pe = -0.94 KPa pnet = -0.94 KPa

For roof CP,e from 4.5 m To 9 m Cpe = -0.5844 pe = -0.51 KPa pnet = -0.51 KPa

For wall Windward Cp,i = -0.3 side Wall Cp,i = -0.3

For wall Windward and Leeward CP,e from 0 m To 25.13 m Cpe = 0.7 pe = 0.62 KPa pnet = 0.91 KPa

For side wall CP,e from 0 m To 6.40 m Cpe = pe = -0.57 KPa pnet = -0.57 KPa

Maximum Upward pressure used in roof member Design = 0.94 KPa

Maximum Downward pressure used in roof member Design = 0.47 KPa

Maximum Wall pressure used in Design = 0.91 KPa

Maximum Racking pressure used in Design = 0.88 KPa

**Design Summary**

**Purlin Design**

Purlin Spacing = 900 mm Purlin Span = 5850 mm Try Purlin 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

Second page

condition after installation)

K1 Short term = 1  K1 Medium term = 0.8  K1 Long term = 0.6  K4 =1  K5 =1  K8 Downward =0.94

K8 Upward =0.46  S1 Downward =13.93  S1 Upward =25.01

Shear Capacity of timber =3 MPa  Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

| | | | | | |
|---|---|---|---|---|---|
| $M_{1.35D}$ | 1.3 Kn-m | Capacity | 4.72 Kn-m | Passing Percentage | **363.08 %** |
| $M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 3.57 Kn-m | Capacity | 6.30 Kn-m | Passing Percentage | **176.47 %** |
| $M_{0.9D-WnUp}$ | -2.75 Kn-m | Capacity | -3.87 Kn-m | Passing Percentage | **140.73 %** |
| $V_{1.35D}$ | 0.89 Kn | Capacity | 14.47 Kn | Passing Percentage | **1625.84 %** |
| $V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 2.03 Kn | Capacity | 19.30 Kn | Passing Percentage | **950.74 %** |
| $V_{0.9D-WnUp}$ | -1.88 Kn | Capacity | -24.12 Kn | Passing Percentage | **1282.98 %** |

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 14.73 mm  Limit by Woolcock et al, 1999 Span/240 = 24.17 mm
Deflection under Dead and Service Wind = 12.93 mm  Limit by Woolcock et al, 1999 Span/100 = 58.00 mm

**Reactions**

Maximum downward =2.03 kn  Maximum upward = -1.88 kn

Number of Blocking = 1  if 0 then no blocking required, if 1 then one midspan blocking required

## Rafter Design Internal

Internal Rafter Load Width = 5935 mm  Internal Rafter Span = 8850 mm  Try Rafter 2x360x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1  K1 Medium term = 0.8  K1 Long term = 0.6  K4 =1  K5 =1  K8 Downward =1.00

K8 Upward =1.00  S1 Downward =5.90  S1 Upward =5.90

Shear Capacity of timber =5.3 MPa  Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

| | | | | | |
|---|---|---|---|---|---|
| $M_{1.35D}$ | 19.61 Kn-m | Capacity | 60.82 Kn-m | Passing Percentage | **310.15 %** |
| $M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 44.74 Kn-m | Capacity | 81.1 Kn-m | Passing Percentage | **181.27 %** |
| $M_{0.9D-WnUp}$ | -41.55 Kn-m | Capacity | -101.38 Kn-m | Passing Percentage | **244.00 %** |
| $V_{1.35D}$ | 8.86 Kn | Capacity | 77.32 Kn | Passing Percentage | **872.69 %** |
| $V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 20.22 Kn | Capacity | 103.08 Kn | Passing Percentage | **509.79 %** |
| $V_{0.9D-WnUp}$ | -18.78 Kn | Capacity | -128.86 Kn | Passing Percentage | **686.16 %** |

**Deflections**

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 25.405 mm  Limit by Woolcock et al, 1999 Span/240 = 37.50 mm

Deflection under Dead and Service Wind = 34.58 mm  Limit by Woolcock et al, 1999 Span/100 = 90.00 mm

**Reactions**

Maximum downward =20.22 kn  Maximum upward = -18.78 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 126 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -18.78 Kn

## Rafter Design External

External Rafter Load Width = 3000 mm  External Rafter Span = 4371 mm  Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

# Pole Shed App Ver 01 2022

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.94

K8 Upward =0.94 S1 Downward =13.93 S1 Upward =13.93

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

| | | | | | |
|---|---|---|---|---|---|
| $M_{1.35D}$ | 2.42 Kn-m | Capacity | 4.72 Kn-m | Passing Percentage | **195.04 %** |
| $M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 5.52 Kn-m | Capacity | 6.30 Kn-m | Passing Percentage | **114.13 %** |
| $M_{0.9D-WnUp}$ | -5.12 Kn-m | Capacity | -7.87 Kn-m | Passing Percentage | **153.71 %** |
| $V_{1.35D}$ | 2.21 Kn | Capacity | 14.47 Kn | Passing Percentage | **654.75 %** |
| $V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 5.05 Kn | Capacity | 19.30 Kn | Passing Percentage | **382.18 %** |
| $V_{0.9D-WnUp}$ | -4.69 Kn | Capacity | -24.12 Kn | Passing Percentage | **514.29 %** |

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

| | |
|---|---|
| Deflection under Dead and Live Load = 7.91 mm | Limit by Woolcock et al, 1999 Span/240= 18.75 mm |
| Deflection under Dead and Service Wind = 9.69 mm | Limit by Woolcock et al, 1999 Span/100 = 45.00 mm |

**Reactions**

Maximum downward =5.05 kn Maximum upward = -4.69 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds ........... (Eq 4.12) = -25.20 kn > -4.69 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -4.69 Kn

## Intermediate Design Front and Back

Intermediate Spacing = 3000 mm  Intermediate Span = 5849 mm  Try Intermediate 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1  K4 =1  K5 =1  K8 Downward =0.94

K8 Upward =1.00  S1 Downward =13.93  S1 Upward =1.12

Shear Capacity of timber =3 MPa  Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

| | | | | | |
|---|---|---|---|---|---|
| $M_{Wind+Snow}$ | 11.68 Kn-m | Capacity | 16.8 Kn-m | Passing Percentage | **143.84 %** |
| $V_{0.9D-WnUp}$ | 7.98 Kn | Capacity | -48.24 Kn | Passing Percentage | **604.51 %** |

#### Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 34.245 mm  Limit byWoolcock et al, 1999 Span/100 = 58.49 mm

#### Reactions

Maximum = 7.98 kn

## Intermediate Design Sides

Intermediate Spacing = 2250 mm  Intermediate Span = 6250 mm  Try Intermediate 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1  K4 =1  K5 =1  K8 Downward =0.94

K8 Upward =1.00  S1 Downward =13.93  S1 Upward =1.16

Shear Capacity of timber =3 MPa  Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

| | | | | | |
|---|---|---|---|---|---|
| $M_{Wind+Snow}$ | 5.00 Kn-m | Capacity | 16.8 Kn-m | Passing Percentage | **336.00 %** |
| $V_{0.9D-WnUp}$ | 3.20 Kn | Capacity | 48.24 Kn | Passing Percentage | **1507.50 %** |

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 33.475 mm    Limit by Woolcock et al, 1999 Span/100 = 62.50 mm

**Reactions**

Maximum = 3.20 kn

## Girt Design Front and Back

Girt's Spacing = 900 mm    Girt's Span = 3000 mm    Try Girt 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =0.94

K8 Upward =0.45    S1 Downward =13.93    S1 Upward =25.43

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

| | | | | | |
|---|---|---|---|---|---|
| $M_{Wind+Snow}$ | 0.92 Kn-m | Capacity | 3.75 Kn-m | Passing Percentage | **407.61 %** |
| $V_{0.9D-WnUp}$ | 1.23 Kn | Capacity | 24.12 Kn | Passing Percentage | **1960.98 %** |

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 1.15 mm    Limit by Woolcock et al, 1999 Span/100 = 30.00 mm
Sag during installation = 4.91 mm

**Reactions**

Maximum = 1.23 kn

## Girt Design Sides

Girt's Spacing = 900 mm    Girt's Span = 2250 mm    Try Girt 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =0.94

K8 Upward =0.57     S1 Downward =13.93     S1 Upward =22.03

Shear Capacity of timber =3 MPa     Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

| | | | | | |
|---|---|---|---|---|---|
| $M_{Wind+Snow}$ | 0.52 Kn-m | Capacity | 4.82 Kn-m | Passing Percentage | **926.92 %** |
| $V_{0.9D-WnUp}$ | 0.92 Kn | Capacity | 24.12 Kn | Passing Percentage | **2621.74 %** |

#### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 0.36 mm     Limit by Woolcock et al. 1999 Span/100 = 22.50 mm
Sag during installation =1.55 mm

#### Reactions

Maximum = 0.92 kn

### Middle Pole Design

#### Geometry

| | | | |
|---|---|---|---|
| 300 SED H5 (Minimum 325 dia. at Floor Level) | Dry Use | Height | 6440 mm |
| Area | 76660 mm2 | As | 57495.1171875 mm2 |
| Ix | 467896461 mm4 | Zx | 2994537 mm3 |
| Iy | 467896461 mm4 | Zx | 2994537 mm3 |
| Lateral Restraint | 6440 mm c/c | | |

#### Loads

Total Area over Pole = 26.7075 m2

| | | | |
|---|---|---|---|
| Dead | 6.68 Kn | Live | 6.68 Kn |
| Wind Down | 12.55 Kn | Snow | 0.00 Kn |
| Moment wind | 45.17 Kn-m | | |
| Phi | 0.8 | K8 | 0.64 |
| K1 snow | 0.8 | K1 Dead | 0.6 |
| K1wind | 1 | | |

#### Material

| | | | |
|---|---|---|---|
| Peeling | Steaming | Normal | Dry Use |
| fb = | 36.3 MPa | fs = | 2.96 MPa |

| | | | |
|---|---|---|---|
| fc = | 18 MPa | fp = | 7.2 MPa |
| ft = | 22 MPa | E = | 9257 MPa |

**Capacities**

| | | | | | |
|---|---|---|---|---|---|
| PhiNcx Wind | 706.94 Kn | PhiMnx Wind | 55.69 Kn-m | PhiVnx Wind | 136.15 Kn |
| PhiNcx Dead | 424.17 Kn | PhiMnx Dead | 33.41 Kn-m | PhiVnx Dead | 81.69 Kn |

**Checks**

(Mx/PhiMnx)+(N/phiNcx) = 0.85 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.69 < 1 OK

Deflection at top under service lateral loads = 64.17 mm < 64.40 mm

## Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

**Assumed Soil Properties**

| | | | | | |
|---|---|---|---|---|---|
| Gamma | 18 Kn/m3 | Friction angle | 30 deg | Cohesion | 0 Kn/m3 |
| K0 = | (1-sin(30)) / (1+sin(30)) | | | | |
| Kp = | (1+sin(30)) / (1-sin(30)) | | | | |

**Geometry For Middle Bay Pole**

| | | |
|---|---|---|
| Ds = | 0.6 mm | Pile Diameter |
| L = | 2400 mm | Pile embedment length |
| f1 = | 5100 mm | Distance at which the shear force is applied |
| f2 = | 0 mm | Distance of top soil at rest pressure |

**Loads**

| | |
|---|---|
| Moment Wind = | 45.17 Kn-m |
| Shear Wind = | 8.86 Kn |

**Pile Properties**

| | | |
|---|---|---|
| Safety Factory | 0.55 | |
| Hu = | 16.42 Kn | Ultimate Lateral Strength of the Pile, Short pile |
| Mu = | 49.58 Kn-m | Ultimate Moment Capacity of Pile |

**Checks**

Applied Forces/Capacities = 0.91 < 1 OK

## End Pole Design

#### Geometry For End Bay Pole

#### Geometry

| | | | |
|---|---|---|---|
| 275 SED H5 (Minimum 300 dia. at Floor Level) | Dry Use | Height | 6500 mm |
| Area | 64885 mm2 | As | 48663.8671875 mm2 |
| Ix | 335197731 mm4 | Zx | 2331810 mm3 |
| Iy | 335197731 mm4 | Zx | 2331810 mm3 |
| Lateral Restraint | mm c/c | | |

#### Loads

Total Area over Pole = 6.75 m2

| | | | |
|---|---|---|---|
| Dead | 1.69 Kn | Live | 1.69 Kn |
| Wind Down | 3.17 Kn | Snow | 0.00 Kn |
| Moment Wind | 15.22 Kn-m | | |
| Phi | 0.8 | K8 | 0.55 |
| K1 snow | 0.8 | K1 Dead | 0.6 |
| K1wind | 1 | | |

#### Material

| | | | |
|---|---|---|---|
| Peeling | Steaming | Normal | Dry Use |
| fb = | 36.3 MPa | fs = | 2.96 MPa |
| fc = | 18 MPa | fp = | 7.2 MPa |
| ft = | 22 MPa | E = | 9257 MPa |

#### Capacities

| | | | | | |
|---|---|---|---|---|---|
| PhiNcx Wind | 512.68 Kn | PhiMnx Wind | 37.16 Kn-m | PhiVnx Wind | 115.24 Kn |
| PhiNcx Dead | 307.61 Kn | PhiMnx Dead | 22.29 Kn-m | PhiVnx Dead | 69.14 Kn |

#### Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.42 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.18 < 1 OK

Deflection at top under service lateral loads = 31.79 mm < 67.83 mm

| | | |
|---|---|---|
| Ds = | 0.6 mm | Pile Diameter |
| L = | 1700 mm | Pile embedment length |
| f1 = | 5100 mm | Distance at which the shear force is applied |
| f2 = | 0 mm | Distance of top soil at rest pressure |

**Loads**

Total Area over Pole = 6.75 m2

| | |
|---|---|
| Moment Wind = | 15.22 Kn-m |
| Shear Wind = | 2.98 Kn |

**Pile Properties**

| | | |
|---|---|---|
| Safety Factory | 0.55 | |
| Hu = | 6.44 Kn | Ultimate Lateral Strength of the Pile, Short pile |
| Mu = | 18.92 Kn-m | Ultimate Moment Capacity of Pile |

**Checks**

Applied Forces/Capacities = 0.80 < 1 OK

## Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

**Assumed Soil Properties**

| | | | | | |
|---|---|---|---|---|---|
| Gamma | 18 Kn/m3 | Friction angle | 30 deg | Cohesion | 0 Kn/m3 |
| K0 = | (1-sin(30)) / (1+sin(30)) | | | | |
| Kp = | (1+sin(30)) / (1-sin(30)) | | | | |

**Geometry For End Bay Pole**

| | | |
|---|---|---|
| Ds = | 0.6 mm | Pile Diameter |
| L = | 1700 mm | Pile embedment length |
| f1 = | 5100 mm | Distance at which the shear force is applied |
| f2 = | 0 mm | Distance of top soil at rest pressure |

**Loads**

| | |
|---|---|
| Moment Wind = | 15.22 Kn-m |
| Shear Wind = | 2.98 Kn |

**Pile Properties**

| | | |
|---|---|---|
| Safety Factory | 0.55 | |
| Hu = | 6.44 Kn | Ultimate Lateral Strength of the Pile, Short pile |
| Mu = | 18.92 Kn-m | Ultimate Moment Capacity of Pile |

**Checks**

Applied Forces/Capacities = 0.80 < 1 OK

## Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(2400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(2400)

Skin Friction = 46.52 Kn

Weight of Pile + Pile Skin Friction = 50.15 Kn

Uplift on one Pile = 19.10 Kn

Uplift is ok