

Job No.: EHB 248-1
Latitude: -46.373161

Address: 94 Brookdale Road, Kaka Point 9271, New Zealand
Longitude: 169.765452

Date: 09/07/2024
Elevation: 35 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N5	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	2	Ultimate wind & Earthquake ARI	500 Years	Max Height	5.2 m
Wind Region	NZ2	Terrain Category	2.32	Design Wind Speed	45.28 m/s
Wind Pressure	1.23 KPa	Lee Zone	NO	Ultimate Snow ARI	150 Years
Wind Category	Very High	Earthquake ARI	500		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Gable Open

For roof $C_{p,i} = 0.5616$

For roof $C_{p,e}$ from 0 m To 3.47 m $C_{p,e} = -0.9$ $p_e = -0.74$ KPa $p_{net} = -1.25$ KPa

For roof $C_{p,e}$ from 3.47 m To 6.94 m $C_{p,e} = -0.5$ $p_e = -0.41$ KPa $p_{net} = -0.92$ KPa

For wall Windward $C_{p,i} = 0.5616$ side Wall $C_{p,i} = -0.5771$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 12 m $C_{p,e} = 0.7$ $p_e = 0.78$ KPa $p_{net} = 1.49$ KPa

For side wall $C_{p,e}$ from 0 m To 3.47 m $C_{p,e} =$ $p_e = -0.72$ KPa $p_{net} = -0.01$ KPa

Maximum Upward pressure used in roof member Design = 1.25 KPa

Maximum Downward pressure used in roof member Design = 0.93 KPa

Maximum Wall pressure used in Design = 1.49 KPa

Maximum Racking pressure used in Design = 1.26 KPa

Design Summary

Purlin Design

Purlin Spacing = 850 mm

Purlin Span = 5850 mm

Try Purlin 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 0.94

K8 Upward = 0.46 S1 Downward = 13.93 S1 Upward = 25.01

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	1.23 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	383.74 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_{nDn}}	4.47 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	140.94 %
M _{0.9D-W_{nUp}}	-3.73 Kn-m	Capacity	-3.87 Kn-m	Passing Percentage	103.75 %
V _{1.35D}	0.84 Kn	Capacity	14.47 Kn	Passing Percentage	1722.62 %

Pole Shed App Ver 01 2022

V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	3.06 Kn	Capacity	19.30 Kn	Passing Percentage	630.72 %
V _{0.9D-WnUp}	-2.55 Kn	Capacity	-24.12 Kn	Passing Percentage	945.88 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 9.97 mm Limit by Woolcock et al, 1999 Span/360 = 16.11 mm

Deflection under Dead and Service Wind = 16.04 mm Limit by Woolcock et al, 1999 Span/250 = 38.67 mm

Reactions

Maximum downward = 3.06 kn Maximum upward = -2.55 kn

Number of Blocking = 1 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 6000 mm Internal Rafter Span = 5150 mm Try Rafter 2x300x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K₁ Short term = 1 K₁ Medium term = 0.8 K₁ Long term = 0.6 K₄ = 1 K₅ = 1 K₈ Downward = 1.00

K₈ Upward = 1.00 S₁ Downward = 7.61 S₁ Upward = 7.61

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	6.71 Kn-m	Capacity	31.1 Kn-m	Passing Percentage	463.49 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	24.47 Kn-m	Capacity	41.48 Kn-m	Passing Percentage	169.51 %
M _{0.9D-WnUp}	-20.39 Kn-m	Capacity	-51.84 Kn-m	Passing Percentage	254.24 %
V _{1.35D}	5.21 Kn	Capacity	46.02 Kn	Passing Percentage	883.30 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	19.00 Kn	Capacity	61.36 Kn	Passing Percentage	322.95 %
V _{0.9D-WnUp}	-15.84 Kn	Capacity	-76.7 Kn	Passing Percentage	484.22 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 7.47 mm Limit by Woolcock et al, 1999 Span/360 = 14.72 mm

Deflection under Dead and Service Wind = 13.355 mm Limit by Woolcock et al, 1999 Span/250 = 35.33 mm

Reactions

Maximum downward = 19.00 kn Maximum upward = -15.84 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6$ fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

$K_{11} = 2.0$ fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -15.84 Kn

Rafter Design External

External Rafter Load Width = 3000 mm

External Rafter Span = 5137 mm

Try Rafter 300x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_1 Medium term = 0.8 K_1 Long term = 0.6 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 0.88

K_8 Upward = 0.88 S_1 Downward = 15.50 S_1 Upward = 15.50

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.34 Kn-m	Capacity	13.69 Kn-m	Passing Percentage	409.88 %
$M_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	12.17 Kn-m	Capacity	18.26 Kn-m	Passing Percentage	150.04 %
$M_{0.9D-W_nUp}$	-10.14 Kn-m	Capacity	-22.82 Kn-m	Passing Percentage	225.05 %
$V_{1.35D}$	2.60 Kn	Capacity	23.01 Kn	Passing Percentage	885.00 %
$V_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	9.48 Kn	Capacity	30.68 Kn	Passing Percentage	323.63 %
$V_{0.9D-W_nUp}$	-7.90 Kn	Capacity	-38.35 Kn	Passing Percentage	485.44 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k_2 for Long Term Loads = 2

Deflection under Dead and Live Load = 8.30 mm

Limit by Woolcock et al, 1999 Span/360 = 14.72 mm

Deflection under Dead and Service Wind = 13.35 mm

Limit by Woolcock et al, 1999 Span/250 = 35.33 mm

Reactions

Maximum downward = 9.48 kn Maximum upward = -7.90 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6$ fpj = 22.7 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

$K_{11} = 2.0$ $f_{c,j} = 36.1$ Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

$V = \phi_i \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s \dots\dots\dots$ (Eq 4.12) = -40.07 kn > -7.90 Kn

Single Shear Capacity under short term loads = -21.83 Kn > -7.90 Kn

Girt Design Front and Back

Girt's Spacing = 1150 mm

Girt's Span = 3000 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 0.64 S_1 Downward = 11.27 S_1 Upward = 20.58

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.93 Kn-m	Capacity	2.40 Kn-m	Passing Percentage	124.35 %
$V_{0.9D-WnUp}$	2.57 Kn	Capacity	16.08 Kn	Passing Percentage	625.68 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 11.51 mm

Limit by Woolcock et al, 1999 Span/250 = 12.00 mm

Sag during installation = 4.91 mm

Reactions

Maximum = 2.57 kn

Girt Design Sides

Girt's Spacing = 700 mm

Girt's Span = 2650 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 0.84 S_1 Downward = 9.63 S_1 Upward = 16.53

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.92 Kn-m	Capacity	1.76 Kn-m	Passing Percentage	191.30 %
$V_{0.9D-WnUp}$	1.38 Kn	Capacity	12.06 Kn	Passing Percentage	873.91 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 10.11 mm

Limit by Woolcock et al. 1999 Span/100 = 10.60 mm

Sag during installation = 2.99 mm

Reactions

Maximum = 1.38 kn

Middle Pole Design

Geometry

250 SED H5 (Minimum 275 dia. at Floor Level)	Dry Use	Height	4900 mm
Area	54091 mm ²	As	40568.5546875 mm ²
Ix	232952248 mm ⁴	Zx	1774874 mm ³
Iy	232952248 mm ⁴	Zx	1774874 mm ³
Lateral Restraint	1300 mm c/c		

Loads

Total Area over Pole = 31.8 m²

Dead	7.95 Kn	Live	7.95 Kn
Wind Down	29.57 Kn	Snow	20.03 Kn
Moment wind	19.12 Kn-m	Moment snow	3.50 Kn-m
Phi	0.8	K8	1.00
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	778.92 Kn	PhiMnx Wind	51.54 Kn-m	PhiVnx Wind	96.07 Kn
PhiNcx Dead	467.35 Kn	PhiMnx Dead	30.93 Kn-m	PhiVnx Dead	57.64 Kn
PhiNcx Snow	623.13 Kn	PhiMnx Snow	41.23 Kn-m	PhiVnx Snow	76.85 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.43 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.20 < 1$ OK

Deflection at top under service lateral loads = 31.74 mm < 32.67 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Pole Shed App Ver 01 2022

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	2000 mm	Pile embedment length
f1 =	3900 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	19.12 Kn-m	Moment Snow =	Kn-m
Shear Wind =	4.90 Kn	Shear Snow =	3.50 Kn

Pile Properties

Safety Factory	0.55	
Hu =	12.08 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	28.13 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.68 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	4900 mm
Area	20729 mm ²	As	15546.6796875 mm ²
Ix	34210793 mm ⁴	Zx	421056 mm ³
Iy	34210793 mm ⁴	Zx	421056 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 15.9 m²

Dead	3.98 Kn	Live	3.98 Kn
Wind Down	14.79 Kn	Snow	10.02 Kn
Moment Wind	9.56 Kn-m	Moment snow	1.75 Kn-m
Phi	0.8	K8	0.32
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	95.87 Kn	PhiMnx Wind	3.93 Kn-m	PhiVnx Wind	36.81 Kn
-------------	----------	-------------	-----------	-------------	----------

Pole Shed App Ver 01 2022

PhiNcx Dead	57.52 Kn	PhiMnx Dead	2.36 Kn-m	PhiVnx Dead	22.09 Kn
PhiNcx Snow	76.69 Kn	PhiMnx Snow	3.14 Kn-m	PhiVnx Snow	29.45 Kn

Checks

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 2.67 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 6.16 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 114.38 \text{ mm} < 34.58 \text{ mm}$$

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	3900 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

$$\text{Total Area over Pole} = 15.9 \text{ m}^2$$

Moment Wind =	9.56 Kn-m	Moment Snow =	1.75 Kn-m
Shear Wind =	2.45 Kn	Shear Snow =	1.75 Kn

Pile Properties

Safety Factory	0.55	
Hu =	3.76 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.46 Kn-m	Ultimate Moment Capacity of Pile

Checks

$$\text{Applied Forces/Capacities} = 1.13 < 1 \text{ OK}$$

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	3900 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	9.56 Kn-m	Moment Snow =	1.75 Kn-m
Shear Wind =	2.45 Kn	Shear Snow =	1.75 Kn

Pile Properties

Safety Factory	0.55
----------------	------

Hu =	3.76 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.46 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 1.13 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(2000) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(2000)

Skin Friction = 32.31 Kn

Weight of Pile + Pile Skin Friction = 36.32 Kn

Uplift on one Pile = 32.59 Kn

Uplift is ok