



Pole Shed App Ver 01 2022

**Job No.:** Southern Pastures  
Mamaku-Training

**Address:** 142 Mamaku South Road Kineith New  
Zealand, Tokoroa, New Zealand

**Date:** 16/06/2025

**Latitude:** -38.251015

**Longitude:** 176.054543

**Elevation:** 608 m

**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.75 m
Wind Region	NZ2	Terrain Category	2.27	Design Wind Speed	45.85 m/s
Wind Pressure	1.26 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Very High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Mono Open

For roof  $C_{p,i} = 0.656$

For roof  $C_{p,e}$  from 0 m To 3.75 m  $C_{p,e} = -0.9$   $p_e = -1.00$  KPa  $p_{net} = -1.88$  KPa

For roof  $C_{p,e}$  from 3.75 m To 7.50 m  $C_{p,e} = -0.5$   $p_e = -0.56$  KPa  $p_{net} = -1.44$  KPa

For wall Windward  $C_{p,i} = 0.656$  side Wall  $C_{p,i} = -0.5682$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 13.5 m  $C_{p,e} = 0.7$   $p_e = 0.79$  KPa  $p_{net} = 1.57$  KPa

For side wall  $C_{p,e}$  from 0.0 m To 3.75 m  $C_{p,e} =$   $p_e = -0.74$  KPa  $p_{net} = 0.04$  KPa

Maximum Upward pressure used in roof member Design = 1.88 KPa

Maximum Downward pressure used in roof member Design = 1.01 KPa

Maximum Wall pressure used in Design = 1.57 KPa

Maximum Racking pressure used in Design = 1.34 KPa

**Design Summary**

**Purlin Design**

Purlin Spacing = 900 mm

Purlin Span = 4350 mm

Try Purlin 250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

Pole Shed App Ver 01 2022

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 0.97

K8 Upward = 0.69    S1 Downward = 12.68    S1 Upward = 19.59

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

M <sub>1.35D</sub>	0.72 Kn-m	Capacity	3.40 Kn-m	Passing Percentage	<b>472.22 %</b>
M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	2.79 Kn-m	Capacity	4.53 Kn-m	Passing Percentage	<b>162.37 %</b>
M <sub>0.9D-WnUp</sub>	-3.52 Kn-m	Capacity	-4.02 Kn-m	Passing Percentage	<b>418.75 %</b>
V <sub>1.35D</sub>	0.66 Kn	Capacity	12.06 Kn	Passing Percentage	<b>1827.27 %</b>
V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	2.56 Kn	Capacity	16.08 Kn	Passing Percentage	<b>628.12 %</b>
V <sub>0.9D-WnUp</sub>	-3.24 Kn	Capacity	-20.10 Kn	Passing Percentage	<b>620.37 %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 8.77 mm      Limit by Woolcock et al, 1999 Span/240 = 17.92 mm

Deflection under Dead and Service Wind = 9.23 mm      Limit by Woolcock et al, 1999 Span/100 = 43.00 mm

**Reactions**

Maximum downward = 2.56 kn    Maximum upward = -3.24 kn

Number of Blocking = 1    if 0 then no blocking required, if 1 then one midspan blocking required

**Rafter Design Internal**

Internal Rafter Load Width = 4500 mm    Internal Rafter Span = 3850 mm    Try Rafter 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 1.00

K8 Upward = 1.00    S1 Downward = 6.81    S1 Upward = 6.81

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

M <sub>1.35D</sub>	2.81 Kn-m	Capacity	10.08 Kn-m	Passing Percentage	<b>358.72 %</b>
M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	10.92 Kn-m	Capacity	13.44 Kn-m	Passing Percentage	<b>123.08 %</b>

Pole Shed App Ver 01 2022

M <sub>0.9D-WnUp</sub>	-13.80 Kn-m	Capacity	-16.8 Kn-m	Passing Percentage	<b>121.74 %</b>
V <sub>1.35D</sub>	2.92 Kn	Capacity	28.94 Kn	Passing Percentage	<b>991.10 %</b>
V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	11.35 Kn	Capacity	38.6 Kn	Passing Percentage	<b>340.09 %</b>
V <sub>0.9D-WnUp</sub>	-14.34 Kn	Capacity	-48.24 Kn	Passing Percentage	<b>336.40 %</b>

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 3.335 mm      Limit by Woolcock et al, 1999 Span/240 = 16.67 mm

Deflection under Dead and Service Wind = 6.205 mm      Limit by Woolcock et al, 1999 Span/100 = 40.00 mm

**Reactions**

Maximum downward = 11.35 kn    Maximum upward = -14.34 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K<sub>11</sub> = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 100 mm

For Parallel to grain loading

K<sub>11</sub> = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 32.51 Kn > -14.34 Kn

**Rafter Design External**

External Rafter Load Width = 2250 mm      External Rafter Span = 3808 mm      Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K<sub>1</sub> Short term = 1    K<sub>1</sub> Medium term = 0.8    K<sub>1</sub> Long term = 0.6    K<sub>4</sub> = 1    K<sub>5</sub> = 1    K<sub>8</sub> Downward = 0.94

Pole Shed App Ver 01 2022

K8 Upward =0.94    S1 Downward =13.93    S1 Upward =13.93

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

M <sub>1.35D</sub>	1.38 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	<b>342.03 %</b>
M <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	5.34 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	<b>117.98 %</b>
M <sub>0.9D-W<sub>n</sub>Up</sub>	-6.75 Kn-m	Capacity	-7.87 Kn-m	Passing Percentage	<b>116.59 %</b>
V <sub>1.35D</sub>	1.45 Kn	Capacity	14.47 Kn	Passing Percentage	<b>997.93 %</b>
V <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	5.61 Kn	Capacity	19.30 Kn	Passing Percentage	<b>344.03 %</b>
V <sub>0.9D-W<sub>n</sub>Up</sub>	-7.09 Kn	Capacity	-24.12 Kn	Passing Percentage	<b>340.20 %</b>

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 3.70 mm      Limit by Woolcock et al, 1999 Span/240= 16.67 mm

Deflection under Dead and Service Wind = 6.20 mm      Limit by Woolcock et al, 1999 Span/100 = 40.00 mm

**Reactions**

Maximum downward =5.61 kn    Maximum upward = -7.09 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K<sub>11</sub> = 14.9 f<sub>pj</sub> = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

K<sub>11</sub> = 2.0 f<sub>cj</sub> = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k<sub>1</sub> x k<sub>4</sub> x k<sub>5</sub> x f<sub>s</sub> x b x d<sub>s</sub> ..... (Eq 4.12) = -25.20 kn > -7.09 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -7.09 Kn

### Girt Design Front and Back

Girt's Spacing = 800 mm

Girt's Span = 4500 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.92    S1 Downward =11.27    S1 Upward =14.55

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

M <sub>Wind+Snow</sub>	3.18 Kn-m	Capacity	3.42 Kn-m	Passing Percentage	<b>107.55 %</b>
V <sub>0.9D-WnUp</sub>	2.83 Kn	Capacity	16.08 Kn	Passing Percentage	<b>568.20 %</b>

#### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 30.03 mm    Limit by Woolcock et al, 1999 Span/100 = 45.00 mm

Sag during installation = 24.86 mm

#### Reactions

Maximum = 2.83 kn

### Girt Design Sides

Girt's Spacing = 800 mm

Girt's Span = 4000 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.82    S1 Downward =11.27    S1 Upward =16.80

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

M <sub>Wind+Snow</sub>	2.51 Kn-m	Capacity	3.08 Kn-m	Passing Percentage	<b>122.71 %</b>
V <sub>0.9D-WnUp</sub>	2.51 Kn	Capacity	16.08 Kn	Passing Percentage	<b>640.64 %</b>

## Pole Shed App Ver 01 2022

### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 18.75 mm      Limit by Woolcock et al. 1999 Span/100 = 40.00 mm

Sag during installation = 15.52 mm

### Reactions

Maximum = 2.51 kn

### Middle Pole Design

#### Geometry

250 SED H5 (Minimum 275 dia. at Floor Level)	Dry Use	Height	3700 mm
Area	13125 mm <sup>2</sup>	As	9843.75 mm <sup>2</sup>
I <sub>x</sub>	75366211 mm <sup>4</sup>	Z <sub>x</sub>	574219 mm <sup>3</sup>
I <sub>y</sub>	75366211 mm <sup>4</sup>	Z <sub>y</sub>	574219 mm <sup>3</sup>
Lateral Restraint	3700 mm c/c		

#### Loads

Total Area over Pole = 18 m<sup>2</sup>

Dead	4.50 Kn	Live	4.50 Kn
Wind Down	18.18 Kn	Snow	0.00 Kn
Moment wind	10.57 Kn-m		
Phi	0.8	K <sub>8</sub>	0.93
K <sub>1</sub> snow	0.8	K <sub>1</sub> Dead	0.6
K <sub>1</sub> wind	1		

#### Material

Peeling	Steaming	Normal	Dry Use
f <sub>b</sub> =	36.3 MPa	f <sub>s</sub> =	2.96 MPa
f <sub>c</sub> =	18 MPa	f <sub>p</sub> =	7.2 MPa
f <sub>t</sub> =	22 MPa	E =	9257 MPa

#### Capacities

PhiN <sub>cx</sub> Wind	176.17 Kn	PhiM <sub>nx</sub> Wind	15.54 Kn-m	PhiV <sub>nx</sub> Wind	23.31 Kn
PhiN <sub>cx</sub> Dead	105.70 Kn	PhiM <sub>nx</sub> Dead	9.33 Kn-m	PhiV <sub>nx</sub> Dead	13.99 Kn

**Checks**

$$(M_x/\phi M_{nx}) + (N/\phi N_{cx}) = 0.83 < 1 \text{ OK}$$

$$(M_x/\phi M_{nx})^2 + (N/\phi N_{cx}) = 0.62 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 29.55 \text{ mm} < 37.00 \text{ mm}$$

**Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

Gamma 18 Kn/m<sup>3</sup> Friction angle 30 deg Cohesion 0 Kn/m<sup>3</sup>

$$K_0 = (1 - \sin(30)) / (1 + \sin(30))$$

$$K_p = (1 + \sin(30)) / (1 - \sin(30))$$

**Geometry For Middle Bay Pole**

Ds = 0.6 mm Pile Diameter  
L = 1900 mm Pile embedment length  
f1 = 2813 mm Distance at which the shear force is applied  
f2 = 0 mm Distance of top soil at rest pressure

**Loads**

Moment Wind = 10.57 Kn-m  
Shear Wind = 3.76 Kn

**Pile Properties**

Safety Factory 0.55  
Hu = 12.97 Kn Ultimate Lateral Strength of the Pile, Short pile  
Mu = 22.53 Kn-m Ultimate Moment Capacity of Pile

**Checks**

$$\text{Applied Forces/Capacities} = 0.47 < 1 \text{ OK}$$

**End Pole Design**

**Geometry For End Bay Pole**

**Geometry**

200 SED H5 (Minimum 225 dia. at Floor Level) Dry Use Height 3450 mm



Pole Shed App Ver 01 2022

Area	10625 mm <sup>2</sup>	As	7968.75 mm <sup>2</sup>
Ix	39982096 mm <sup>4</sup>	Zx	376302 mm <sup>3</sup>
Iy	39982096 mm <sup>4</sup>	Zy	376302 mm <sup>3</sup>
Lateral Restraint	mm c/c		

**Loads**

Total Area over Pole = 4.5 m<sup>2</sup>

Dead	1.13 Kn	Live	1.13 Kn
Wind Down	4.54 Kn	Snow	0.00 Kn
Moment Wind	5.29 Kn-m		
Phi	0.8	K8	0.85
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

**Material**

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

**Capacities**

PhiNcx Wind	130.00 Kn	PhiMnx Wind	9.28 Kn-m	PhiVnx Wind	18.87 Kn
PhiNcx Dead	78.00 Kn	PhiMnx Dead	5.57 Kn-m	PhiVnx Dead	11.32 Kn

**Checks**

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.62 < 1$  OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.38 < 1$  OK

Deflection at top under service lateral loads = 28.15 mm < 37.41 mm

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2813 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

Total Area over Pole = 4.5 m<sup>2</sup>

### Pole Shed App Ver 01 2022

Moment Wind = 5.29 Kn-m  
Shear Wind = 1.88 Kn

#### **Pile Properties**

Safety Factory 0.55  
Hu = 5.80 Kn Ultimate Lateral Strength of the Pile, Short pile  
Mu = 9.72 Kn-m Ultimate Moment Capacity of Pile

#### **Checks**

Applied Forces/Capacities = 0.54 < 1 OK

### **Drained Lateral Strength of End pile in cohesionless soils Free Head short pile**

#### **Assumed Soil Properties**

Gamma 18 Kn/m<sup>3</sup> Friction angle 30 deg Cohesion 0 Kn/m<sup>3</sup>  
K0 =  $(1 - \sin(30)) / (1 + \sin(30))$   
Kp =  $(1 + \sin(30)) / (1 - \sin(30))$

#### **Geometry For End Bay Pole**

Ds = 0.6 mm Pile Diameter  
L = 1400 mm Pile embedment length  
f1 = 2813 mm Distance at which the shear force is applied  
f2 = 0 mm Distance of top soil at rest pressure

#### **Loads**

Moment Wind = 5.29 Kn-m  
Shear Wind = 1.88 Kn

#### **Pile Properties**

Safety Factory 0.55  
Hu = 5.80 Kn Ultimate Lateral Strength of the Pile, Short pile  
Mu = 9.72 Kn-m Ultimate Moment Capacity of Pile

#### **Checks**

Applied Forces/Capacities = 0.54 < 1 OK

### **Uplift Check**

Pole Shed App Ver 01 2022

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1900) x Ks(1.5) x  $0.5 \times \tan(30)$  x  $\pi$  x Dia of Pile(0.6) x Height of Pile(1900)

Skin Friction = 29.16 Kn

Weight of Pile + Pile Skin Friction = 32.97 Kn

Uplift on one Pile = 29.79 Kn

Uplift is ok