

Pole Shed App Ver 01 2022

Job No.: 2310035 - 2

Address: 6 Glenview Road, Takaka, New Zealand

Date: 11/13/2023

Latitude: -40.886661

Longitude: 172.833037

Elevation: 81 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N3	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	5 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	40.5 m/s
Wind Pressure	0.98 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Open

For roof $C_{p,i} = 0.63$

For roof $C_{p,e}$ from 0 m To 5 m $C_{p,e} = -0.9$ $p_e = -0.60$ KPa $p_{net} = -1.10$ KPa

For roof $C_{p,e}$ from 5 m To 10 m $C_{p,e} = -0.5$ $p_e = -0.33$ KPa $p_{net} = -0.83$ KPa

For wall Windward $C_{p,i} = 0.63$ side Wall $C_{p,i} = -0.52$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 18 m $C_{p,e} = 0.7$ $p_e = 0.58$ KPa $p_{net} = 1.05$ KPa

For side wall $C_{p,e}$ from 0 m To 5 m $C_{p,e} =$ $p_e = -0.53$ KPa $p_{net} = -0.06$ KPa

Maximum Upward pressure used in roof member Design = 1.10 KPa

Maximum Downward pressure used in roof member Design = 0.68 KPa

Maximum Wall pressure used in Design = 1.13 KPa

Maximum Racking pressure used in Design = 1.06 KPa

Design Summary

Girt Design Front and Back

Girt's Spacing = 0 mm

Girt's Span = 4800 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.00 S1 Downward =11.27 S1 Upward =Infinity

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	0.00 Kn-m	Capacity	0.00 Kn-m	Passing Percentage	NaN %
V _{0.9D-WnUp}	0.00 Kn-m	Capacity	16.08 Kn-m	Passing Percentage	Infinity %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 0.00 mm Limit by Woolcock et al, 1999 Span/100 = 48.00 mm
Sag during installation = 32.19 mm

Reactions

Maximum = 0.00 kn

Girt Design Sides

Girt's Spacing = 0 mm Girt's Span = 4615 mm Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.00 S1 Downward =11.27 S1 Upward =Infinity

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	0.00 Kn-m	Capacity	0.00 Kn-m	Passing Percentage	NaN %
V _{0.9D-WnUp}	0.00 Kn-m	Capacity	16.08 Kn-m	Passing Percentage	Infinity %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 0.00 mm Limit by Woolcock et al. 1999 Span/100 = 46.15 mm

Pole Shed App Ver 01 2022

Sag during installation = 27.51 mm

Reactions

Maximum = 0.00 kn

Middle Pole Design

Geometry

225 SED H5 (Minimum 250 dia. at Floor Level)	Dry Use	Height	5700 mm
Area	44279 mm ²	As	33209.1796875 mm ²
Ix	156100441 mm ⁴	Zx	1314530 mm ³
Iy	156100441 mm ⁴	Zx	1314530 mm ³
Lateral Restraint	5700 mm c/c		

Loads

Total Area over Pole = 44.30769230769231 m²

Dead	11.08 Kn	Live	11.08 Kn
Wind Down	30.13 Kn	Snow	0.00 Kn
Moment wind	13.22 Kn-m		
Phi	0.8	K8	0.49
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	314.47 Kn	PhiMnx Wind	18.83 Kn-m	PhiVnx Wind	78.64 Kn
PhiNcx Dead	188.68 Kn	PhiMnx Dead	11.30 Kn-m	PhiVnx Dead	47.18 Kn

Checks

$$(M_x/\Phi M_{nx}) + (N/\phi N_{cx}) = 0.87 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\phi N_{cx}) = 0.66 < 1 \text{ OK}$$

Deflection at top under service lateral loads = 36.63 mm < 57.00 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma 18 Kn/m³ Friction angle 30 deg Cohesion 0 Kn/m³
K₀ = $(1 - \sin(30)) / (1 + \sin(30))$
K_p = $(1 + \sin(30)) / (1 - \sin(30))$

Geometry For Middle Bay Pole

D_s = 0.6 mm Pile Diameter
L = 2500 mm Pile embedment length
f₁ = 3750 mm Distance at which the shear force is applied
f₂ = 0 mm Distance of top soil at rest pressure

Loads

Moment Wind = 13.22 Kn-m
Shear Wind = 3.52 Kn

Pile Properties

Safety Factory 0.55
H_u = 22.27 Kn Ultimate Lateral Strength of the Pile, Short pile
M_u = 51.50 Kn-m Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.26 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

K_s (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(2500) x K_s(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(2500)

Skin Friction = 50.48 Kn

Weight of Pile + Pile Skin Friction = 56.21 Kn

Uplift on one Pile = 38.77 Kn

Uplift is ok