



**Job No.:** 2711**Address:** 10 Butchers Lane, Waimate, New Zealand**Date:** 25/09/2024**Latitude:** -44.726455**Longitude:** 171.040708**Elevation:** 68 m**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N4	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.6 m
Wind Region	NZ2	Terrain Category	2.61	Design Wind Speed	38.46 m/s
Wind Pressure	0.89 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Mono Enclosed

For roof  $C_{p,i} = -0.3$

For roof  $C_{p,e}$  from 0 m To 3.15 m  $C_{p,e} = -0.9$   $p_e = -0.72$  KPa  $p_{net} = -0.72$  KPa

For roof  $C_{p,e}$  from 3.15 m To 6.30 m  $C_{p,e} = -0.5$   $p_e = -0.4$  KPa  $p_{net} = -0.4$  KPa

For wall Windward  $C_{p,i} = -0.3$  side Wall  $C_{p,i} = -0.3$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 9 m  $C_{p,e} = 0.7$   $p_e = 0.56$  KPa  $p_{net} = 0.83$  KPa

For side wall  $C_{p,e}$  from 0 m To 3.15 m  $C_{p,e} =$   $p_e = -0.52$  KPa  $p_{net} = -0.52$  KPa

Maximum Upward pressure used in roof member Design = 0.72 KPa

Maximum Downward pressure used in roof member Design = 0.43 KPa

Maximum Wall pressure used in Design = 0.83 KPa

Maximum Racking pressure used in Design = 0.96 KPa

**Design Summary****Purlin Design**

Purlin Spacing = 900 mm

Purlin Span = 4050 mm

Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.50 S1 Downward = 11.27 S1 Upward = 23.76

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

$M_{1.35D}$	0.62 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	<b>359.68 %</b>
$M_{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}$	1.72 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	<b>172.67 %</b>
$M_{0.9D-W_nUp}$	-0.91 Kn-m	Capacity	-1.87 Kn-m	Passing Percentage	<b>205.49 %</b>
$V_{1.35D}$	0.62 Kn	Capacity	9.65 Kn	Passing Percentage	<b>1556.45 %</b>

### Pole Shed App Ver 01 2022

V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	1.69 Kn	Capacity	12.86 Kn	Passing Percentage	<b>760.95 %</b>
V <sub>0.9D-WnUp</sub>	-0.90 Kn	Capacity	-16.08 Kn	Passing Percentage	<b>1786.67 %</b>

#### **Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 8.06 mm                      Limit by Woolcock et al, 1999 Span/240 = 16.67 mm

Deflection under Dead and Service Wind = 9.60 mm                      Limit by Woolcock et al, 1999 Span/100 = 40.00 mm

#### **Reactions**

Maximum downward = 1.69 kn    Maximum upward = -0.90 kn

Number of Blocking = 0    if 0 then no blocking required, if 1 then one midspan blocking required

#### **Rafter Design Internal**

Internal Rafter Load Width = 4200 mm                      Internal Rafter Span = 8850 mm                      Try Rafter 2x360x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K<sub>1</sub> Short term = 1    K<sub>1</sub> Medium term = 0.8    K<sub>1</sub> Long term = 0.6    K<sub>4</sub> = 1    K<sub>5</sub> = 1    K<sub>8</sub> Downward = 1.00

K<sub>8</sub> Upward = 1.00    S<sub>1</sub> Downward = 8.40    S<sub>1</sub> Upward = 8.40

Shear Capacity of timber = 5.3 MPa    Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>1.35D</sub>	13.88 Kn-m	Capacity	43.44 Kn-m	Passing Percentage	<b>312.97 %</b>
M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	38.24 Kn-m	Capacity	57.92 Kn-m	Passing Percentage	<b>151.46 %</b>
M <sub>0.9D-WnUp</sub>	-20.35 Kn-m	Capacity	-72.42 Kn-m	Passing Percentage	<b>355.87 %</b>
V <sub>1.35D</sub>	6.27 Kn	Capacity	55.22 Kn	Passing Percentage	<b>880.70 %</b>
V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	17.28 Kn	Capacity	73.64 Kn	Passing Percentage	<b>426.16 %</b>
V <sub>0.9D-WnUp</sub>	-9.20 Kn	Capacity	-92.04 Kn	Passing Percentage	<b>1000.43 %</b>

#### **Deflections**

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 25.17 mm                      Limit by Woolcock et al, 1999 Span/240 = 37.50 mm

Deflection under Dead and Service Wind = 33.325 mm                      Limit by Woolcock et al, 1999 Span/100 = 90.00 mm

#### **Reactions**

Maximum downward = 17.28 kn    Maximum upward = -9.20 kn

#### **Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6$  fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

$K_{11} = 2.0$  fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -9.20 Kn

### Rafter Design External

External Rafter Load Width = 2100 mm

External Rafter Span = 4323 mm

Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

$K_1$  Short term = 1     $K_1$  Medium term = 0.8     $K_1$  Long term = 0.6     $K_4 = 1$      $K_5 = 1$      $K_8$  Downward = 0.94

$K_8$  Upward = 0.94     $S_1$  Downward = 13.93     $S_1$  Upward = 13.93

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

$M_{1.35D}$	1.66 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	<b>284.34 %</b>
$M_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	4.56 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	<b>138.16 %</b>
$M_{0.9D-W_nUp}$	-2.43 Kn-m	Capacity	-7.87 Kn-m	Passing Percentage	<b>323.87 %</b>
$V_{1.35D}$	1.53 Kn	Capacity	14.47 Kn	Passing Percentage	<b>945.75 %</b>
$V_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	4.22 Kn	Capacity	19.30 Kn	Passing Percentage	<b>457.35 %</b>
$V_{0.9D-W_nUp}$	-2.25 Kn	Capacity	-24.12 Kn	Passing Percentage	<b>1072.00 %</b>

### Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

$k_2$  for Long Term Loads = 2

Deflection under Dead and Live Load = 5.54 mm

Limit by Woolcock et al, 1999 Span/240 = 18.75 mm

Deflection under Dead and Service Wind = 6.60 mm

Limit by Woolcock et al, 1999 Span/100 = 45.00 mm

### Reactions

Maximum downward = 4.22 kn    Maximum upward = -2.25 kn

### Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 14.9$  fpj = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

$K_{11} = 2.0$   $f_{c,j} = 36.1$  Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

$V = \phi_i \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s \dots\dots\dots$  (Eq 4.12) = -25.20 kn > -2.25 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -2.25 Kn

### Intermediate Design Front and Back

Intermediate Spacing = 2100 mm

Intermediate Span = 2549 mm

Try Intermediate 2x150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

$K_1$  Short term = 1     $K_4 = 1$      $K_5 = 1$      $K_8$  Downward = 1.00

$K_8$  Upward = 1.00     $S_1$  Downward = 9.63     $S_1$  Upward = 0.51

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

$M_{Wind+Snow}$	1.53 Kn-m	Capacity	4.2 Kn-m	Passing Percentage	<b>274.51 %</b>
$V_{0.9D-WnUp}$	2.41 Kn	Capacity	-24.12 Kn	Passing Percentage	<b>1000.83 %</b>

#### Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 13.14 mm

Limit by Woolcock et al, 1999 Span/100 = 25.49 mm

#### Reactions

Maximum = 2.41 kn

### Intermediate Design Sides

Intermediate Spacing = 2250 mm

Intermediate Span = 3225 mm

Try Intermediate 2x200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

$K_1$  Short term = 1     $K_4 = 1$      $K_5 = 1$      $K_8$  Downward = 1.00

$K_8$  Upward = 1.00     $S_1$  Downward = 11.27     $S_1$  Upward = 0.67

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

$M_{Wind+Snow}$	1.32 Kn-m	Capacity	7.46 Kn-m	Passing Percentage	<b>565.15 %</b>
$V_{0.9D-WnUp}$	1.63 Kn	Capacity	32.16 Kn	Passing Percentage	<b>1973.01 %</b>

#### Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 15.22 mm

Limit by Woolcock et al, 1999 Span/100 = 32.25 mm

**Reactions**

Maximum = 1.63 kn

**Girt Design Front and Back**

Girt's Spacing = 1050 mm

Girt's Span = 2100 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.91    S1 Downward =9.63    S1 Upward =14.71

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

$M_{Wind+Snow}$	0.48 Kn-m	Capacity	1.91 Kn-m	Passing Percentage	<b>397.92 %</b>
$V_{0.9D-WnUp}$	0.92 Kn	Capacity	12.06 Kn	Passing Percentage	<b>1310.87 %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 4.12 mm

Limit by Woolcock et al, 1999 Span/100 = 21.00 mm

Sag during installation = 1.18 mm

**Reactions**

Maximum = 0.92 kn

**Girt Design Sides**

Girt's Spacing = 1050 mm

Girt's Span = 2250 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.89    S1 Downward =9.63    S1 Upward =15.23

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

$M_{Wind+Snow}$	0.55 Kn-m	Capacity	1.87 Kn-m	Passing Percentage	<b>340.00 %</b>
$V_{0.9D-WnUp}$	0.98 Kn	Capacity	12.06 Kn	Passing Percentage	<b>1230.61 %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 5.43 mm

Limit by Woolcock et al. 1999 Span/100 = 22.50 mm

Sag during installation =1.55 mm

**Reactions**

Maximum = 0.98 kn

## Middle Pole Design

### Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3240 mm
Area	35448 mm <sup>2</sup>	As	26585.7421875 mm <sup>2</sup>
I <sub>x</sub>	100042702 mm <sup>4</sup>	Z <sub>x</sub>	941578 mm <sup>3</sup>
I <sub>y</sub>	100042702 mm <sup>4</sup>	Z <sub>y</sub>	941578 mm <sup>3</sup>
Lateral Restraint	3240 mm c/c		

### Loads

Total Area over Pole = 18.9 m<sup>2</sup>

Dead	4.72 Kn	Live	4.72 Kn
Wind Down	8.13 Kn	Snow	11.91 Kn
Moment wind	9.77 Kn-m	Moment snow	3.39 Kn-m
Phi	0.8	K <sub>s</sub>	0.89
K <sub>1</sub> snow	0.8	K <sub>1</sub> Dead	0.6
K <sub>1</sub> wind	1		

### Material

Peeling	Steaming	Normal	Dry Use
f <sub>b</sub> =	36.3 MPa	f <sub>s</sub> =	2.96 MPa
f <sub>c</sub> =	18 MPa	f <sub>p</sub> =	7.2 MPa
f <sub>t</sub> =	22 MPa	E =	9257 MPa

### Capacities

PhiN <sub>c</sub> Wind	454.53 Kn	PhiM <sub>n</sub> Wind	24.35 Kn-m	PhiV <sub>n</sub> Wind	62.96 Kn
PhiN <sub>c</sub> Dead	272.72 Kn	PhiM <sub>n</sub> Dead	14.61 Kn-m	PhiV <sub>n</sub> Dead	37.77 Kn
PhiN <sub>c</sub> Snow	363.62 Kn	PhiM <sub>n</sub> Snow	19.48 Kn-m	PhiV <sub>n</sub> Snow	50.36 Kn

### Checks

$$(M_x/\Phi M_n) + (N/\Phi N_c) = 0.45 < 1 \text{ OK}$$

$$(M_x/\Phi M_n)^2 + (N/\Phi N_c) = 0.21 < 1 \text{ OK}$$

Deflection at top under service lateral loads = 17.30 mm < 32.40 mm

## Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

### Assumed Soil Properties

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K <sub>0</sub> =	(1-sin(30)) / (1+sin(30))				
K <sub>p</sub> =	(1+sin(30)) / (1-sin(30))				

### Geometry For Middle Bay Pole

D <sub>s</sub> =	0.6 mm	Pile Diameter
L =	1450 mm	Pile embedment length
f <sub>l</sub> =	2700 mm	Distance at which the shear force is applied

Pole Shed App Ver 01 2022

$f_2 =$  0 mm Distance of top soil at rest pressure

**Loads**

Moment Wind =	9.77 Kn-m	Moment Snow =	Kn-m
Shear Wind =	3.62 Kn	Shear Snow =	3.39 Kn

**Pile Properties**

Safety Factory	0.55		
$H_u =$	6.55 Kn	Ultimate Lateral Strength of the Pile, Short pile	
$M_u =$	10.61 Kn-m	Ultimate Moment Capacity of Pile	

**Checks**

Applied Forces/Capacities = 0.92 < 1 OK

**End Pole Design**

**Geometry For End Bay Pole**

**Geometry**

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	3300 mm
Area	20729 mm <sup>2</sup>	$A_s$	15546.6796875 mm <sup>2</sup>
$I_x$	34210793 mm <sup>4</sup>	$Z_x$	421056 mm <sup>3</sup>
$I_y$	34210793 mm <sup>4</sup>	$Z_y$	421056 mm <sup>3</sup>
Lateral Restraint	mm c/c		

**Loads**

Total Area over Pole = 9.45 m<sup>2</sup>

Dead	2.36 Kn	Live	2.36 Kn
Wind Down	4.06 Kn	Snow	5.95 Kn
Moment Wind	3.26 Kn-m	Moment snow	1.13 Kn-m
$\Phi$	0.8	K <sub>8</sub>	0.66
K <sub>1</sub> snow	0.8	K <sub>1</sub> Dead	0.6
K <sub>1</sub> wind	1		

**Material**

Peeling	Steaming	Normal	Dry Use
$f_b =$	36.3 MPa	$f_s =$	2.96 MPa
$f_c =$	18 MPa	$f_p =$	7.2 MPa
$f_t =$	22 MPa	E =	9257 MPa

**Capacities**

$\Phi H_{Ncx}$ Wind	195.59 Kn	$\Phi H_{Mnx}$ Wind	8.01 Kn-m	$\Phi V_{Ncx}$ Wind	36.81 Kn
$\Phi H_{Ncx}$ Dead	117.35 Kn	$\Phi H_{Mnx}$ Dead	4.81 Kn-m	$\Phi V_{Ncx}$ Dead	22.09 Kn
$\Phi H_{Ncx}$ Snow	156.47 Kn	$\Phi H_{Mnx}$ Snow	6.41 Kn-m	$\Phi V_{Ncx}$ Snow	29.45 Kn

**Checks**



$$(M_x/\phi M_{nx}) + (N/\phi N_{cx}) = 0.47 < 1 \text{ OK}$$

$$(M_x/\phi M_{nx})^2 + (N/\phi N_{cx}) = 0.23 < 1 \text{ OK}$$

Deflection at top under service lateral loads = 18.69 mm < 35.91 mm

Ds =	0.6 mm	Pile Diameter
L =	1450 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

#### Loads

Total Area over Pole = 9.45 m<sup>2</sup>

Moment Wind =	3.26 Kn-m	Moment Snow =	1.13 Kn-m
Shear Wind =	1.21 Kn	Shear Snow =	1.13 Kn

#### Pile Properties

Safety Factory	0.55	
Hu =	6.55 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	10.61 Kn-m	Ultimate Moment Capacity of Pile

#### Checks

Applied Forces/Capacities = 0.31 < 1 OK

### Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

#### Assumed Soil Properties

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

#### Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1450 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

#### Loads

Moment Wind =	3.26 Kn-m	Moment Snow =	1.13 Kn-m
Shear Wind =	1.21 Kn	Shear Snow =	1.13 Kn

#### Pile Properties

Safety Factory	0.55	
Hu =	6.55 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	10.61 Kn-m	Ultimate Moment Capacity of Pile

#### Checks

Applied Forces/Capacities =  $0.31 < 1$  OK

### **Uplift Check**

Density of Concrete =  $24 \text{ Kn/m}^3$

Density of Timber Pole =  $5 \text{ Kn/m}^3$

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

$K_s$  (Lateral Earth Pressure Coefficient) for cast into place concrete piles =  $1.5$

Formula to calculate Skin Friction = Safety factor ( $0.55$ )  $\times$  Density of Soil ( $18$ )  $\times$  Height of Pile ( $1450$ )  $\times$   $K_s$  ( $1.5$ )  $\times$   $0.5 \times \tan(30)$   $\times$   $\pi \times$  Dia of Pile ( $0.6$ )  $\times$  Height of Pile ( $1450$ )

Skin Friction =  $16.98 \text{ Kn}$

Weight of Pile + Pile Skin Friction =  $20.75 \text{ Kn}$

Uplift on one Pile =  $9.36 \text{ Kn}$

Uplift is ok