

Job No.: 2409027 - 1**Address:** 81 McGowen Street, Puponga, New Zealand**Date:** 31/10/2024**Latitude:** -40.528814**Longitude:** 172.715831**Elevation:** 44 m**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N2	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	500 Years	Max Height	3.6 m
Wind Region	NZ2	Terrain Category	3.0	Design Wind Speed	39.3 m/s
Wind Pressure	0.93 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Enclosed

For roof $C_{p,i} = -0.5808$

For roof $C_{p,e}$ from 0 m To 1.65 m $C_{p,e} = -0.94$ $p_e = -0.58$ KPa $p_{net} = -0.90$ KPa

For roof $C_{p,e}$ from 1.65 m To 3.30 m $C_{p,e} = -0.88$ $p_e = -0.54$ KPa $p_{net} = -0.86$ KPa

For wall Windward $C_{p,i} = 0.4639$ side Wall $C_{p,i} = -0.5808$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 6 m $C_{p,e} = 0.7$ $p_e = 0.51$ KPa $p_{net} = 0.92$ KPa

For side wall $C_{p,e}$ from 0 m To 3.30 m $C_{p,e} =$ $p_e = -0.48$ KPa $p_{net} = -0.07$ KPa

Maximum Upward pressure used in roof member Design = 0.90 KPa

Maximum Downward pressure used in roof member Design = 0.62 KPa

Maximum Wall pressure used in Design = 0.92 KPa

Maximum Racking pressure used in Design = 0.88 KPa

Design Summary**Purlin Design**

Purlin Spacing = 900 mm

Purlin Span = 3850 mm

Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.53 S1 Downward = 11.27 S1 Upward = 23.16

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.56 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	398.21 %
$M_{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}$	1.56 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	190.38 %
$M_{0.9D-W_nUp}$	-1.13 Kn-m	Capacity	-1.96 Kn-m	Passing Percentage	210.75 %
$V_{1.35D}$	0.58 Kn	Capacity	9.65 Kn	Passing Percentage	1663.79 %

Pole Shed App Ver 01 2022

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.59 Kn	Capacity	12.86 Kn	Passing Percentage	808.81 %
$V_{0.9D-WnUp}$	-1.17 Kn	Capacity	-16.08 Kn	Passing Percentage	1374.36 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k_2 for Long Term Loads = 2

Deflection under Dead and Live Load = 6.56 mm Limit by Woolcock et al, 1999 Span/240 = 15.83 mm

Deflection under Dead and Service Wind = 8.86 mm Limit by Woolcock et al, 1999 Span/100 = 38.00 mm

Reactions

Maximum downward = 1.59 kn Maximum upward = -1.17 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Intermediate Design Sides

Intermediate Spacing = 3000 mm Intermediate Span = 3150 mm Try Intermediate 2x150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_4 = 1 K_5 = 1 K_8 Downward = 1.00

K_8 Upward = 1.00 S_1 Downward = 9.63 S_1 Upward = 0.57

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.71 Kn-m	Capacity	4.2 Kn-m	Passing Percentage	245.61 %
$V_{0.9D-WnUp}$	2.17 Kn	Capacity	24.12 Kn	Passing Percentage	1111.52 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 23.3 mm Limit by Woolcock et al, 1999 Span/100 = 31.50 mm

Reactions

Maximum = 2.17 kn

Girt Design Front and Back

Girt's Spacing = 900 mm Girt's Span = 4000 mm Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_4 = 1 K_5 = 1 K_8 Downward = 1.00

K_8 Upward = 0.92 S_1 Downward = 9.63 S_1 Upward = 14.36

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	Capacity
-----------------	----------

	1.66 Kn-m		1.94 Kn-m	Passing Percentage	116.87 %
V _{0.9D-WnUp}	1.66 Kn	Capacity	12.06 Kn	Passing Percentage	726.51 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 29.29 mm

Limit by Woolcock et al, 1999 Span/100 = 40.00 mm

Sag during installation = 15.52 mm

Reactions

Maximum = 1.66 kn

Girt Design Sides

Girt's Spacing = 900 mm

Girt's Span = 3000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.79 S1 Downward =9.63 S1 Upward =17.59

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	0.93 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	177.42 %
V _{0.9D-WnUp}	1.24 Kn	Capacity	12.06 Kn	Passing Percentage	972.58 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 9.27 mm

Limit by Woolcock et al. 1999 Span/100 = 30.00 mm

Sag during installation =4.91 mm

Reactions

Maximum = 1.24 kn

End Pole Design

Geometry For End Bay Pole

Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3450 mm
Area	27598 mm ²	As	20698.2421875 mm ²
I _x	60639381 mm ⁴	Z _x	646820 mm ³
I _y	60639381 mm ⁴	Z _y	646820 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 12 m²

Pole Shed App Ver 01 2022

Dead	3.00 Kn	Live	3.00 Kn
Wind Down	7.44 Kn	Snow	0.00 Kn
Moment Wind	4.27 Kn-m		
Phi	0.8	K8	0.75
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	297.59 Kn	PhiMnx Wind	14.07 Kn-m	PhiVnx Wind	49.01 Kn
PhiNcx Dead	178.56 Kn	PhiMnx Dead	8.44 Kn-m	PhiVnx Dead	29.41 Kn

Checks

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.35 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.14 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 13.80 \text{ mm} < 35.91 \text{ mm}$$

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

$$\text{Total Area over Pole} = 12 \text{ m}^2$$

Moment Wind =	4.27 Kn-m
Shear Wind =	1.58 Kn

Pile Properties

Safety Factory	0.55	
Hu =	4.89 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	7.84 Kn-m	Ultimate Moment Capacity of Pile

Checks

$$\text{Applied Forces/Capacities} = 0.54 < 1 \text{ OK}$$

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				

$$K_p = (1 + \sin(30)) / (1 - \sin(30))$$

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	4.27 Kn-m
Shear Wind =	1.58 Kn

Pile Properties

Safety Factor	0.55	
Hu =	4.89 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	7.84 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.54 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1300) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1300)

Skin Friction = 13.65 Kn

Weight of Pile + Pile Skin Friction = 17.45 Kn

Uplift on one Pile = 8.10 Kn

Uplift is ok