

Pole Shed App Ver 01 2022

Job No.: Swain Shed

Address: 102D Maungakawa Road, Cambridge, New Zealand **Date:** 07/02/2025

Latitude: -37.877523

Longitude: 175.512342

Elevation: 76 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.244 m
Wind Region	NZ1	Terrain Category	2.27	Design Wind Speed	37.08 m/s
Wind Pressure	0.82 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Enclosed

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 1.60 m $C_{p,e} = -0.9129$ $p_e = -0.68$ KPa $p_{net} = -0.68$ KPa

For roof $C_{p,e}$ from 1.60 m To 3.20 m $C_{p,e} = -0.8935$ $p_e = -0.66$ KPa $p_{net} = -0.66$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 6.40 m $C_{p,e} = 0.7$ $p_e = 0.52$ KPa $p_{net} = 0.77$ KPa

For side wall $C_{p,e}$ from 0 m To 3.20 m $C_{p,e} =$ $p_e = -0.48$ KPa $p_{net} = -0.48$ KPa

Maximum Upward pressure used in roof member Design = 0.68 KPa

Maximum Downward pressure used in roof member Design = 0.25 KPa

Maximum Wall pressure used in Design = 0.77 KPa

Maximum Racking pressure used in Design = 0.89 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm

Purlin Span = 2950 mm

Try Purlin 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

Pole Shed App Ver 01 2022

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.74 S1 Downward = 10.36 S1 Upward = 18.60

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	0.33 Kn-m	Capacity	0.99 Kn-m	Passing Percentage	300.00 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_{nDn}}	1.1 Kn-m	Capacity	1.32 Kn-m	Passing Percentage	120.00 %
M _{0.9D-W_{nUp}}	-0.45 Kn-m	Capacity	-1.22 Kn-m	Passing Percentage	137.08 %
V _{1.35D}	0.45 Kn	Capacity	6.08 Kn	Passing Percentage	1351.11 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_{nDn}}	0.90 Kn	Capacity	8.10 Kn	Passing Percentage	900.00 %
V _{0.9D-W_{nUp}}	-0.60 Kn	Capacity	-10.13 Kn	Passing Percentage	1688.33 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 7.21 mm Limit by Woolcock et al, 1999 Span/240 = 12.08 mm

Deflection under Dead and Service Wind = 7.51 mm Limit by Woolcock et al, 1999 Span/100 = 29.00 mm

Reactions

Maximum downward = 0.90 kn Maximum upward = -0.60 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 3100 mm Internal Rafter Span = 6250 mm Try Rafter 2x240x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 1.00 S1 Downward = 6.71 S1 Upward = 6.71

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	5.11 Kn-m	Capacity	19.9 Kn-m	Passing Percentage	389.43 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_{nDn}}	10.22 Kn-m	Capacity	26.54 Kn-m	Passing Percentage	259.69 %

Pole Shed App Ver 01 2022

M _{0.9D-WnUp}	-6.89 Kn-m	Capacity	-33.18 Kn-m	Passing Percentage	481.57 %
V _{1.35D}	3.27 Kn	Capacity	36.82 Kn	Passing Percentage	1125.99 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	6.54 Kn	Capacity	49.08 Kn	Passing Percentage	750.46 %
V _{0.9D-WnUp}	-4.41 Kn	Capacity	-61.36 Kn	Passing Percentage	1391.38 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 16.03 mm Limit by Woolcock et al, 1999 Span/240 = 26.67 mm

Deflection under Dead and Service Wind = 18.555 mm Limit by Woolcock et al, 1999 Span/100 = 64.00 mm

Reactions

Maximum downward = 6.54 kn Maximum upward = -4.41 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K₁₁ = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K₁₁ = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 29.11 Kn > -4.41 Kn

Rafter Design External

External Rafter Load Width = 1550 mm External Rafter Span = 3016 mm Try Rafter 240x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K₁ Short term = 1 K₁ Medium term = 0.8 K₁ Long term = 0.6 K₄ = 1 K₅ = 1 K₈ Downward = 0.94

Pole Shed App Ver 01 2022

K8 Upward =0.94 S1 Downward =13.82 S1 Upward =13.82

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	0.59 Kn-m	Capacity	2.73 Kn-m	Passing Percentage	462.71 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	1.36 Kn-m	Capacity	3.64 Kn-m	Passing Percentage	267.65 %
M _{0.9D-W_nUp}	-0.80 Kn-m	Capacity	-4.55 Kn-m	Passing Percentage	568.75 %
V _{1.35D}	0.79 Kn	Capacity	10.42 Kn	Passing Percentage	1318.99 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	1.58 Kn	Capacity	13.89 Kn	Passing Percentage	879.11 %
V _{0.9D-W_nUp}	-1.06 Kn	Capacity	-17.37 Kn	Passing Percentage	1638.68 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 2.27 mm Limit by Woolcock et al, 1999 Span/240= 13.33 mm

Deflection under Dead and Service Wind = 2.36 mm Limit by Woolcock et al, 1999 Span/100 = 32.00 mm

Reactions

Maximum downward =1.58 kn Maximum upward = -1.06 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts =

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K₁₁ = 14.9 f_{pj} = 12.9 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K₁₁ = 2.0 f_{cj} = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k₁ x k₄ x k₅ x f_s x b x d_s (Eq 4.12) = -17.01 kn > -1.06 Kn

Single Shear Capacity under short term loads = -0.00 Kn > -1.06 Kn

Girt Design Front and Back

Girt's Spacing = 900 mm

Girt's Span = 3100 mm

Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.71 S1 Downward =10.36 S1 Upward =19.23

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	0.83 Kn-m	Capacity	1.17 Kn-m	Passing Percentage	140.96 %
V _{0.9D-WnUp}	1.07 Kn	Capacity	10.13 Kn	Passing Percentage	946.73 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 12.09 mm Limit by Woolcock et al, 1999 Span/100 = 31.00 mm

Sag during installation = 6.91 mm

Reactions

Maximum = 1.07 kn

Girt Design Sides

Girt's Spacing = 900 mm

Girt's Span = 3200 mm

Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.69 S1 Downward =10.36 S1 Upward =19.54

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	0.89 Kn-m	Capacity	1.14 Kn-m	Passing Percentage	128.09 %
V _{0.9D-WnUp}	1.11 Kn	Capacity	10.13 Kn	Passing Percentage	912.61 %

Pole Shed App Ver 01 2022

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 13.72 mm Limit by Woolcock et al. 1999 Span/100 = 32.00 mm

Sag during installation = 7.85 mm

Reactions

Maximum = 1.11 kn

Middle Pole Design

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	3182 mm
Area	20729 mm ²	As	15546.6796875 mm ²
Ix	34210793 mm ⁴	Zx	421056 mm ³
Iy	34210793 mm ⁴	Zy	421056 mm ³
Lateral Restraint	3400 mm c/c		

Loads

Total Area over Pole = 9.92 m²

Dead	2.48 Kn	Live	2.48 Kn
Wind Down	2.48 Kn	Snow	0.00 Kn
Moment wind	5.43 Kn-m		
Phi	0.8	K8	0.63
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	186.64 Kn	PhiMnx Wind	7.65 Kn-m	PhiVnx Wind	36.81 Kn
PhiNcx Dead	111.98 Kn	PhiMnx Dead	4.59 Kn-m	PhiVnx Dead	22.09 Kn

Checks

$$(M_x/\phi M_{nx}) + (N/\phi N_{cx}) = 0.75 < 1 \text{ OK}$$

$$(M_x/\phi M_{nx})^2 + (N/\phi N_{cx}) = 0.54 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 24.87 \text{ mm} < 31.82 \text{ mm}$$

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma 18 Kn/m³ Friction angle 30 deg Cohesion 0 Kn/m³

$$K_0 = (1 - \sin(30)) / (1 + \sin(30))$$

$$K_p = (1 + \sin(30)) / (1 - \sin(30))$$

Geometry For Middle Bay Pole

Ds = 0.6 mm Pile Diameter
L = 1300 mm Pile embedment length
f1 = 2433 mm Distance at which the shear force is applied
f2 = 0 mm Distance of top soil at rest pressure

Loads

Moment Wind = 5.43 Kn-m
Shear Wind = 2.23 Kn

Pile Properties

Safety Factory 0.55
Hu = 5.24 Kn Ultimate Lateral Strength of the Pile, Short pile
Mu = 7.65 Kn-m Ultimate Moment Capacity of Pile

Checks

$$\text{Applied Forces/Capacities} = 0.71 < 1 \text{ OK}$$

End Pole Design

Geometry For End Bay Pole

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level) Dry Use Height 3044 mm

Pole Shed App Ver 01 2022

Area	20729 mm ²	As	15546.6796875 mm ²
Ix	34210793 mm ⁴	Zx	421056 mm ³
Iy	34210793 mm ⁴	Zy	421056 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 4.96 m²

Dead	1.24 Kn	Live	1.24 Kn
Wind Down	1.24 Kn	Snow	0.00 Kn
Moment Wind	1.81 Kn-m		
Phi	0.8	K8	0.73
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	218.68 Kn	PhiMnx Wind	8.96 Kn-m	PhiVnx Wind	36.81 Kn
PhiNcx Dead	131.21 Kn	PhiMnx Dead	5.37 Kn-m	PhiVnx Dead	22.09 Kn

Checks

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.22 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.06 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 8.43 \text{ mm} < 32.36 \text{ mm}$$

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	2433 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 4.96 m²

Pole Shed App Ver 01 2022

Moment Wind = 1.81 Kn-m
Shear Wind = 0.74 Kn

Pile Properties

Safety Factory 0.55
Hu = 5.24 Kn Ultimate Lateral Strength of the Pile, Short pile
Mu = 7.65 Kn-m Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.24 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma 18 Kn/m³ Friction angle 30 deg Cohesion 0 Kn/m³
K0 = $(1 - \sin(30)) / (1 + \sin(30))$
Kp = $(1 + \sin(30)) / (1 - \sin(30))$

Geometry For End Bay Pole

Ds = 0.6 mm Pile Diameter
L = 1300 mm Pile embedment length
f1 = 2433 mm Distance at which the shear force is applied
f2 = 0 mm Distance of top soil at rest pressure

Loads

Moment Wind = 1.81 Kn-m
Shear Wind = 0.74 Kn

Pile Properties

Safety Factory 0.55
Hu = 5.24 Kn Ultimate Lateral Strength of the Pile, Short pile
Mu = 7.65 Kn-m Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.24 < 1 OK

Uplift Check

Pole Shed App Ver 01 2022

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1300) x Ks(1.5) x $0.5 \times \tan(30) \times \pi \times \text{Dia of Pile}(0.6) \times \text{Height of Pile}(1300)$

Skin Friction = 13.65 Kn

Weight of Pile + Pile Skin Friction = 17.91 Kn

Uplift on one Pile = 4.51 Kn

Uplift is ok