First Page

Job No.: KJ2352   **Address:** 15 James St, Coalgate, New Zealand   **Date:** 14/08/2024

Latitude: -43.482971   **Longitude:** 171.967803   **Elevation:** 236 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N4	Ground Snow Load	1.21 KPa	Roof Snow Load	0.71 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.59 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	36.95 m/s
Wind Pressure	0.82 KPa	Lee Zone	YES	Ultimate Snow ARI	50 Years
Wind Category	Medium	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Gable Open

For roof $C_{p,i}$ = -0.3

For roof $C_{P,e}$ from 0 m To 3 m C_{pe} = -0.9 p_e = -0.64 KPa p_{net} = -0.64 KPa

For roof $C_{P,e}$ from 3 m To 6.0 m C_{pe} = -0.5 p_e = -0.36 KPa p_{net} = -0.36 KPa

For wall Windward $C_{p,i}$ = -0.3   side Wall $C_{p,i}$ = -0.3

For wall Windward and Leeward $C_{P,e}$ from 0 m To 7.3 m C_{pe} = 0.7 p_e = 0.53 KPa p_{net} = 0.77 KPa

For side wall $C_{P,e}$ from 0 m To 3 m C_{pe} = p_e = -0.48 KPa p_{net} = -0.48 KPa

Maximum Upward pressure used in roof member Design = 0.64 KPa

Maximum Downward pressure used in roof member Design = 0.40 KPa

Maximum Wall pressure used in Design = 0.77 KPa

Maximum Racking pressure used in Design = 0.79 KPa

Design Summary

Rafter Design Internal

Internal Rafter Load Width = 4751 mm   Internal Rafter Span = 3500 mm   Try Rafter 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =6.81   S1 Upward =6.81

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	2.46 Kn-m	Capacity	10.08 Kn-m	Passing Percentage	**409.76 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	7.35 Kn-m	Capacity	13.44 Kn-m	Passing Percentage	**182.86 %**
$M_{0.9D-WnUp}$	-3.02 Kn-m	Capacity	-16.8 Kn-m	Passing Percentage	**556.29 %**
$V_{1.35D}$	2.81 Kn	Capacity	28.94 Kn	Passing Percentage	**1029.89 %**

Second page

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	8.40 Kn	Capacity	38.6 Kn	Passing Percentage	**459.52 %**
$V_{0.9D-WnUp}$	-3.45 Kn	Capacity	-48.24 Kn	Passing Percentage	**1398.26 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 2.44 mm   Limit by Woolcock et al, 1999 Span/240 = 15.21 mm
Deflection under Dead and Service Wind = 3.165 mm   Limit by Woolcock et al, 1999 Span/100 = 36.50 mm

Reactions

Maximum downward =8.40 kn   Maximum upward = -3.45 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 100 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 21.67 Kn > -3.45 Kn

Girt Design Front and Back

Girt's Spacing = 900 mm   Girt's Span = 4751 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.87   S1 Downward =9.63   S1 Upward =15.65

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.96 Kn-m	Capacity	1.84 Kn-m	Passing Percentage	**93.88 %**
$V_{0.9D-WnUp}$	1.65 Kn	Capacity	12.06 Kn	Passing Percentage	**730.91 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 93.79 mm   Limit by Woolcock et al, 1999 Span/100 = 47.51 mm
Sag during installation = 30.89 mm

Reactions

Maximum = 1.65 kn

Girt Design Sides

Girt's Spacing = 900 mm   Girt's Span = 3650 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.70   S1 Downward =9.63   S1 Upward =19.40

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.15 Kn-m	Capacity	1.47 Kn-m	Passing Percentage	**127.83 %**
$V_{0.9D-WnUp}$	1.26 Kn	Capacity	12.06 Kn	Passing Percentage	**957.14 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 32.67 mm   Limit by Woolcock et al. 1999 Span/100 = 36.50 mm
Sag during installation =10.76 mm

Reactions

Maximum = 1.26 kn

Middle Pole Design

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	3340 mm
Area	20729 mm2	As	15546.6796875 mm2
Ix	34210793 mm4	Zx	421056 mm3
Iy	34210793 mm4	Zx	421056 mm3
Lateral Restraint	1300 mm c/c		

Loads

Total Area over Pole = 17.34115 m2

Dead	4.34 Kn	Live	4.34 Kn
Wind Down	6.94 Kn	Snow	12.31 Kn
Moment wind	6.03 Kn-m	Moment snow	3.43 Kn-m
Phi	0.8	K8	1.00
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use

fb =	36.3 MPa		fs =		2.96 MPa
fc =	18 MPa		fp =		7.2 MPa
ft =	22 MPa		E =		9257 MPa

Capacities

PhiNcx Wind	298.50 Kn	PhiMnx Wind	12.23 Kn-m	PhiVnx Wind	36.81 Kn
PhiNcx Dead	179.10 Kn	PhiMnx Dead	7.34 Kn-m	PhiVnx Dead	22.09 Kn
PhiNcx Snow	238.80 Kn	PhiMnx Snow	9.78 Kn-m	PhiVnx Snow	29.45 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.57 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.32 < 1 OK

Deflection at top under service lateral loads = 32.09 mm < 33.40 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3		Friction angle	30 deg	Cohesion 0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	2693 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	6.03 Kn-m	Moment Snow =	Kn-m
Shear Wind =	2.24 Kn	Shear Snow =	3.43 Kn

Pile Properties

Safety Factory	0.55	
Hu =	4.90 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	7.83 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.77 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level)		Dry Use	Height 3290 mm
Area		20729 mm2	As 15546.6796875 mm2

Ix		34210793 mm4	Zx	421056 mm3
Iy		34210793 mm4	Zx	421056 mm3
Lateral Restraint		mm c/c		

Loads

Total Area over Pole = 8.670575 m2

Dead	2.17 Kn	Live	2.17 Kn
Wind Down	3.47 Kn	Snow	6.16 Kn
Moment Wind	3.02 Kn-m	Moment snow	1.72 Kn-m
Phi	0.8	K8	0.66
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
f_b =	36.3 MPa	f_s =	2.96 MPa
f_c =	18 MPa	f_p =	7.2 MPa
f_t =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	196.48 Kn	PhiMnx Wind	8.05 Kn-m	PhiVnx Wind	36.81 Kn
PhiNcx Dead	117.89 Kn	PhiMnx Dead	4.83 Kn-m	PhiVnx Dead	22.09 Kn
PhiNcx Snow	157.18 Kn	PhiMnx Snow	6.44 Kn-m	PhiVnx Snow	29.45 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.44 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.20 < 1 OK

Deflection at top under service lateral loads = 17.20 mm < 35.81 mm

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	2693 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 8.670575 m2

Moment Wind =	3.02 Kn-m	Moment Snow =	1.72 Kn-m
Shear Wind =	1.12 Kn	Shear Snow =	1.72 Kn

Pile Properties

Safety Factory	0.55	
Hu =	4.90 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	7.83 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.38 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma 18 Kn/m3 Friction angle 30 deg Cohesion 0 Kn/m3

$K0 =$ (1-sin(30)) / (1+sin(30))

$Kp =$ (1+sin(30)) / (1-sin(30))

Geometry For End Bay Pole

$Ds =$ 0.6 mm Pile Diameter

$L =$ 1300 mm Pile embedment length

$f1 =$ 2693 mm Distance at which the shear force is applied

$f2 =$ 0 mm Distance of top soil at rest pressure

Loads

Moment Wind = 3.02 Kn-m Moment Snow = 1.72 Kn-m

Shear Wind = 1.12 Kn Shear Snow = 1.72 Kn

Pile Properties

Safety Factory 0.55

$Hu =$ 4.90 Kn Ultimate Lateral Strength of the Pile, Short pile

$Mu =$ 7.83 Kn-m Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.38 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1300) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1300)

Skin Friction = 13.65 Kn

Weight of Pile + Pile Skin Friction = 17.91 Kn

Uplift on one Pile = 7.20 Kn

Uplift is ok

Last Page