

Job No.: DAYNA JURY**Address:** 120 Mamaku Road, BRIXTON, New Zealand**Date:** 05/07/2024**Latitude:** -39.018706**Longitude:** 174.240409**Elevation:** 13.5 m**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4.15 m
Wind Region	NZ2	Terrain Category	2.27	Design Wind Speed	40.75 m/s
Wind Pressure	1 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Gable Enclosed

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 4.15 m $C_{p,e} = -0.9$ $p_e = -0.81$ KPa $p_{net} = -0.81$ KPa

For roof $C_{p,e}$ from 4.15 m To 8.30 m $C_{p,e} = -0.5$ $p_e = -0.45$ KPa $p_{net} = -0.45$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 19.2 m $C_{p,e} = 0.7$ $p_e = 0.63$ KPa $p_{net} = 0.93$ KPa

For side wall $C_{p,e}$ from 0 m To 4.15 m $C_{p,e} =$ $p_e = -0.58$ KPa $p_{net} = -0.58$ KPa

Maximum Upward pressure used in roof member Design = 0.81 KPa

Maximum Downward pressure used in roof member Design = 0.48 KPa

Maximum Wall pressure used in Design = 0.93 KPa

Maximum Racking pressure used in Design = 1.08 KPa

Design Summary**Purlin Design**

Purlin Spacing = 900 mm

Purlin Span = 4650 mm

Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.44 S1 Downward = 11.27 S1 Upward = 25.48

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.82 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	271.95 %
$M_{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}$	2.01 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	147.76 %
$M_{0.9D-W_nUp}$	-1.42 Kn-m	Capacity	-1.66 Kn-m	Passing Percentage	116.90 %
$V_{1.35D}$	0.71 Kn	Capacity	9.65 Kn	Passing Percentage	1359.15 %

Pole Shed App Ver 01 2022

V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	1.63 Kn	Capacity	12.86 Kn	Passing Percentage	788.96 %
V _{0.9D-W_nUp}	-1.22 Kn	Capacity	-16.08 Kn	Passing Percentage	1318.03 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 14.10 mm Limit by Woolcock et al, 1999 Span/240 = 19.17 mm

Deflection under Dead and Service Wind = 17.39 mm Limit by Woolcock et al, 1999 Span/100 = 46.00 mm

Reactions

Maximum downward = 1.63 kn Maximum upward = -1.22 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 4800 mm Internal Rafter Span = 11850 mm Try Rafter 2x450x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K₁ Short term = 1 K₁ Medium term = 0.8 K₁ Long term = 0.6 K₄ = 1 K₅ = 1 K₈ Downward = 1.00

K₈ Upward = 1.00 S₁ Downward = 6.68 S₁ Upward = 6.68

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	28.44 Kn-m	Capacity	91.56 Kn-m	Passing Percentage	321.94 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	65.72 Kn-m	Capacity	122.08 Kn-m	Passing Percentage	185.76 %
M _{0.9D-W_nUp}	-49.29 Kn-m	Capacity	-152.6 Kn-m	Passing Percentage	309.60 %
V _{1.35D}	9.60 Kn	Capacity	96.64 Kn	Passing Percentage	1006.67 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	22.18 Kn	Capacity	128.86 Kn	Passing Percentage	580.97 %
V _{0.9D-W_nUp}	-16.64 Kn	Capacity	-161.08 Kn	Passing Percentage	968.03 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 33.245 mm Limit by Woolcock et al, 1999 Span/240 = 50.00 mm

Deflection under Dead and Service Wind = 45.56 mm Limit by Woolcock et al, 1999 Span/100 = 120.00 mm

Reactions

Maximum downward = 22.18 kn Maximum upward = -16.64 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6 \text{ fpj} = 22.7 \text{ Mpa}$ for Rafter with effective thickness = 126 mm

For Parallel to grain loading

$K_{11} = 2.0 \text{ fcj} = 36.1 \text{ Mpa}$ for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -16.64 Kn

Rafter Design External

External Rafter Load Width = 2400 mm

External Rafter Span = 5841 mm

Try Rafter 300x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_1 Medium term = 0.8 K_1 Long term = 0.6 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 0.88

K_8 Upward = 0.88 S_1 Downward = 15.50 S_1 Upward = 15.50

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.45 Kn-m	Capacity	13.69 Kn-m	Passing Percentage	396.81 %
$M_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	7.98 Kn-m	Capacity	18.26 Kn-m	Passing Percentage	228.82 %
$M_{0.9D-W_nUp}$	-5.99 Kn-m	Capacity	-22.82 Kn-m	Passing Percentage	380.97 %
$V_{1.35D}$	2.37 Kn	Capacity	23.01 Kn	Passing Percentage	970.89 %
$V_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	5.47 Kn	Capacity	30.68 Kn	Passing Percentage	560.88 %
$V_{0.9D-W_nUp}$	-4.10 Kn	Capacity	-38.35 Kn	Passing Percentage	935.37 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k_2 for Long Term Loads = 2

Deflection under Dead and Live Load = 10.91 mm

Limit by Woolcock et al, 1999 Span/240 = 25.00 mm

Deflection under Dead and Service Wind = 13.45 mm

Limit by Woolcock et al, 1999 Span/100 = 60.00 mm

Reactions

Maximum downward = 5.47 kn Maximum upward = -4.10 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6 \text{ fpj} = 22.7 \text{ Mpa}$ for Rafter with effective thickness = 45 mm

For Parallel to grain loading

$K_{11} = 2.0$ $f_{c,j} = 36.1$ Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

$V = \phi_i \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s \dots\dots\dots$ (Eq 4.12) = -40.07 kn > -4.10 Kn

Single Shear Capacity under short term loads = -21.83 Kn > -4.10 Kn

Intermediate Design Sides

Intermediate Spacing = 3000 mm

Intermediate Span = 3650 mm

Try Intermediate 2x250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 0.97

K_8 Upward = 1.00 S_1 Downward = 12.68 S_1 Upward = 0.81

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	2.32 Kn-m	Capacity	11.66 Kn-m	Passing Percentage	502.59 %
$V_{0.9D-WnUp}$	2.55 Kn	Capacity	40.2 Kn	Passing Percentage	1576.47 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 9.165 mm

Limit by Woolcock et al, 1999 Span/100 = 36.50 mm

Reactions

Maximum = 2.55 kn

Girt Design Front and Back

Girt's Spacing = 900 mm

Girt's Span = 4800 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 0.75 S_1 Downward = 11.27 S_1 Upward = 18.41

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	2.41 Kn-m	Capacity	2.79 Kn-m	Passing Percentage	115.77 %
$V_{0.9D-WnUp}$	2.01 Kn	Capacity	16.08 Kn	Passing Percentage	800.00 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 25.90 mm

Limit by Woolcock et al, 1999 Span/100 = 48.00 mm

Sag during installation = 32.19 mm

Reactions

Maximum = 2.01 kn

Girt Design Sides

Girt's Spacing = 1300 mm

Girt's Span = 3000 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.64 S1 Downward =11.27 S1 Upward =20.58

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	1.36 Kn-m	Capacity	2.40 Kn-m	Passing Percentage	176.47 %
V _{0.9D-WnUp}	1.81 Kn	Capacity	16.08 Kn	Passing Percentage	888.40 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 5.71 mm

Limit by Woolcock et al. 1999 Span/100 = 30.00 mm

Sag during installation =4.91 mm

Reactions

Maximum = 1.81 kn

Middle Pole Design

Geometry

225 SED H5 (Minimum 250 dia. at Floor Level)	Dry Use	Height	3350 mm
Area	44279 mm ²	As	33209.1796875 mm ²
I _x	156100441 mm ⁴	Z _x	1314530 mm ³
I _y	156100441 mm ⁴	Z _y	1314530 mm ³
Lateral Restraint	3350 mm c/c		

Loads

Total Area over Pole = 28.8 m²

Dead	7.20 Kn	Live	7.20 Kn
Wind Down	13.82 Kn	Snow	0.00 Kn
Moment wind	16.70 Kn-m		
Phi	0.8	K8	0.93
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
---------	----------	--------	---------

Pole Shed App Ver 01 2022

fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	594.12 Kn	PhiMnx Wind	35.57 Kn-m	PhiVnx Wind	78.64 Kn
PhiNcx Dead	356.47 Kn	PhiMnx Dead	21.34 Kn-m	PhiVnx Dead	47.18 Kn

Checks

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.52 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.27 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 22.57 \text{ mm} < 33.50 \text{ mm}$$

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1700 mm	Pile embedment length
f1 =	3113 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	16.70 Kn-m
Shear Wind =	5.36 Kn

Pile Properties

Safety Factory	0.55	
Hu =	9.10 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	17.02 Kn-m	Ultimate Moment Capacity of Pile

Checks

$$\text{Applied Forces/Capacities} = 0.98 < 1 \text{ OK}$$

End Pole Design

Geometry For End Bay Pole

Geometry

225 SED H5 (Minimum 250 dia. at Floor Level)	Dry Use	Height	3850 mm
Area	44279 mm ²	As	33209.1796875 mm ²
Ix	156100441 mm ⁴	Zx	1314530 mm ³

Pole Shed App Ver 01 2022

Iy	156100441 mm ⁴	Zx	1314530 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 14.4 m²

Dead	3.60 Kn	Live	3.60 Kn
Wind Down	6.91 Kn	Snow	0.00 Kn
Moment Wind	5.57 Kn-m		
Phi	0.8	K8	0.85
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	542.44 Kn	PhiMnx Wind	32.48 Kn-m	PhiVnx Wind	78.64 Kn
PhiNcx Dead	325.47 Kn	PhiMnx Dead	19.49 Kn-m	PhiVnx Dead	47.18 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.20 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.06 < 1$ OK

Deflection at top under service lateral loads = 9.30 mm < 41.40 mm

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	3113 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 14.4 m²

Moment Wind =	5.57 Kn-m
Shear Wind =	1.79 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.52 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	12.04 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.46 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	3113 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	5.57 Kn-m
Shear Wind =	1.79 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.52 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	12.04 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.46 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1700) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1700)

Skin Friction = 23.34 Kn

Weight of Pile + Pile Skin Friction = 27.24 Kn

Uplift on one Pile = 16.85 Kn

Uplift is ok