

Pole Shed App Ver 01 2022

**Job No.:** 230309

**Address:** 3 Omarama Ave, Omarama, New Zealand

**Date:** 3/15/2023

**Latitude:** -44.487411

**Longitude:** 169.965057

**Elevation:** 435.5 m

**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	KPa	Roof Live Point Load	Kn
Snow Zone	N4	Ground Snow Load	1.89 KPa	Roof Snow Load	1.32 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.6 m
Wind Region	NZ2	Terrain Category	2.32	Design Wind Speed	39.61 m/s
Wind Pressure	0.94 KPa	Lee Zone	YES	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Mono Open

For roof  $C_{p,i} = 0.6524$

For roof  $C_{p,e}$  from 0 m To 1.65 m  $C_{p,e} = -0.94$   $p_e = -0.51$  KPa  $p_{net} = -0.94$  KPa

For roof  $C_{p,e}$  from 1.65 m To 3.30 m  $C_{p,e} = -0.88$   $p_e = -0.48$  KPa  $p_{net} = -0.91$  KPa

For wall Windward  $C_{p,i} = 0.6524$  side Wall  $C_{p,i} = -0.5616$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 18 m  $C_{p,e} = 0.7$   $p_e = 0.59$  KPa  $p_{net} = 1.16$  KPa

For side wall  $C_{p,e}$  from 0 m To 3.30 m  $C_{p,e} =$   $p_e = -0.55$  KPa  $p_{net} = 0.02$  KPa

Maximum Upward pressure used in roof member Design = 0.94 KPa

Maximum Downward pressure used in roof member Design = 0.74 KPa

Maximum Wall pressure used in Design = 1.16 KPa

Maximum Racking pressure used in Design = 1.01 KPa

**Design Summary**

**Purlin Design**

Purlin Spacing = 900 mm

Purlin Span = 4350 mm

Try Purlin 250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

condition after installation)

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 0.97

K8 Upward = 0.38    S1 Downward = 12.68    S1 Upward = 27.71

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

M <sub>1.35D</sub>	0.72 Kn-m	Capacity	3.40 Kn-m	Passing Percentage	<b>472.22 %</b>
M <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	3.45 Kn-m	Capacity	4.53 Kn-m	Passing Percentage	<b>131.30 %</b>
M <sub>0.9D-W<sub>n</sub>Up</sub>	-1.52 Kn-m	Capacity	-2.21 Kn-m	Passing Percentage	<b>225.51 %</b>
V <sub>1.35D</sub>	0.66 Kn	Capacity	12.06 Kn	Passing Percentage	<b>1827.27 %</b>
V <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	3.17 Kn	Capacity	16.08 Kn	Passing Percentage	<b>507.26 %</b>
V <sub>0.9D-W<sub>n</sub>Up</sub>	-1.40 Kn	Capacity	-20.10 Kn	Passing Percentage	<b>1435.71 %</b>

#### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 5.51 mm    Limit by Woolcock et al, 1999 Span/ = 17.20 mm

Deflection under Dead and Service Wind = 7.99 mm    Limit by Woolcock et al, 1999 Span/ = 28.67 mm

#### Reactions

Maximum downward = 3.17 kn    Maximum upward = -1.40 kn

Number of Blocking = 0    if 0 then no blocking required, if 1 then one midspan blocking required

#### Rafter Design Internal

Internal Rafter Load Width = 4500 mm    Internal Rafter Span = 2850 mm    Try Rafter 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 1.00

K8 Upward = 1.00    S1 Downward = 6.81    S1 Upward = 6.81

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

Pole Shed App Ver 01 2022

M <sub>1.35D</sub>	1.54 Kn-m	Capacity	10.08 Kn-m	Passing Percentage	<b>654.55 %</b>
M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	7.40 Kn-m	Capacity	13.44 Kn-m	Passing Percentage	<b>181.62 %</b>
M <sub>0.9D-WnUp</sub>	-3.27 Kn-m	Capacity	-16.8 Kn-m	Passing Percentage	<b>513.76 %</b>
V <sub>1.35D</sub>	2.16 Kn	Capacity	28.94 Kn	Passing Percentage	<b>1339.81 %</b>
V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	10.39 Kn	Capacity	38.6 Kn	Passing Percentage	<b>371.51 %</b>
V <sub>0.9D-WnUp</sub>	-4.58 Kn	Capacity	-48.24 Kn	Passing Percentage	<b>1053.28 %</b>

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 1.055 mm      Limit by Woolcock et al, 1999 Span/ = 12.00 mm

Deflection under Dead and Service Wind = 1.7 mm      Limit by Woolcock et al, 1999 Span/ = 20.00 mm

**Reactions**

Maximum downward = 10.39 kn    Maximum upward = -4.58 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K<sub>11</sub> = 14.9 f<sub>pj</sub> = 12.9 Mpa for Rafter with effective thickness = 100 mm

For Parallel to grain loading

K<sub>11</sub> = 2.0 f<sub>cj</sub> = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 32.51 Kn > -4.58 Kn

**Rafter Design External**

External Rafter Load Width = 2250 mm      External Rafter Span = 2815 mm      Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

### Pole Shed App Ver 01 2022

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 0.94

K8 Upward = 0.94    S1 Downward = 13.93    S1 Upward = 13.93

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>1.35D</sub>	0.75 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	<b>629.33 %</b>
M <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	3.61 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	<b>174.52 %</b>
M <sub>0.9D-W<sub>n</sub>Up</sub>	-1.59 Kn-m	Capacity	-7.87 Kn-m	Passing Percentage	<b>494.97 %</b>
V <sub>1.35D</sub>	1.07 Kn	Capacity	14.47 Kn	Passing Percentage	<b>1352.34 %</b>
V <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	5.13 Kn	Capacity	19.30 Kn	Passing Percentage	<b>376.22 %</b>
V <sub>0.9D-W<sub>n</sub>Up</sub>	-2.26 Kn	Capacity	-24.12 Kn	Passing Percentage	<b>1067.26 %</b>

#### **Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 1.17 mm    Limit by Woolcock et al, 1999 Span/ = 12.00 mm

Deflection under Dead and Service Wind = 1.70 mm    Limit by Woolcock et al, 1999 Span/ = 20.00 mm

#### **Reactions**

Maximum downward = 5.13 kn    Maximum upward = -2.26 kn

#### **Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V =  $\phi \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s$  ..... (Eq 4.12) = -25.20 kn > -2.26 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -2.26 Kn

### **Girt Design Front and Back**

Girt's Spacing = 850 mm

Girt's Span = 4500 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.78    S1 Downward =11.27    S1 Upward =17.82

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>Wind+Snow</sub>	2.84 Kn-m	Capacity	2.90 Kn-m	Passing Percentage	<b>102.11 %</b>
V <sub>0.9D-WnUp</sub>	2.52 Kn-m	Capacity	16.08 Kn-m	Passing Percentage	<b>638.10 %</b>

#### **Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 50.40 mm    Limit by Woolcock et al, 1999 Span/ = 30.00 mm  
Sag during installation = 24.86 mm

#### **Reactions**

Maximum = 2.52 kn

### **Girt Design Sides**

Girt's Spacing = 1100 mm

Girt's Span = 3000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.79    S1 Downward =9.63    S1 Upward =17.59

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>Wind+Snow</sub>	1.63 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	<b>101.23 %</b>
------------------------	-----------	----------	-----------	--------------------	-----------------

Pole Shed App Ver 01 2022

V <sub>0.9D-WnUp</sub>	2.18 Kn-m	Capacity	12.06 Kn-m	Passing Percentage	<b>553.21 %</b>
------------------------	-----------	----------	------------	--------------------	-----------------

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 30.54 mm    Limit by Woolcock et al. 1999 Span/100 = 20.00 mm  
Sag during installation = 4.91 mm

**Reactions**

Maximum = 2.18 kn

**Middle Pole Design**

**Geometry**

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3300 mm
Area	27598 mm <sup>2</sup>	As	20698.2421875 mm <sup>2</sup>
I <sub>x</sub>	60639381 mm <sup>4</sup>	Z <sub>x</sub>	646820 mm <sup>3</sup>
I <sub>y</sub>	60639381 mm <sup>4</sup>	Z <sub>y</sub>	646820 mm <sup>3</sup>
Lateral Restraint	3400 mm c/c		

**Loads**

Total Area over Pole = 13.5 m<sup>2</sup>

Dead	3.38 Kn	Live	3.38 Kn
Wind Down	9.99 Kn	Snow	17.82 Kn
Moment wind	7.34 Kn-m	Moment snow	5.09 Kn-m
Phi	0.8	K <sub>8</sub>	0.76
K <sub>1</sub> snow	0.8	K <sub>1</sub> Dead	0.6
K <sub>1</sub> wind	1		

**Material**

Peeling	Steaming	Normal	Dry Use
f <sub>b</sub> =	36.3 MPa	f <sub>s</sub> =	2.96 MPa
f <sub>c</sub> =	18 MPa	f <sub>p</sub> =	7.2 MPa
f <sub>t</sub> =	22 MPa	E =	9257 MPa

**Capacities**

PhiN <sub>Cx</sub> Wind	302.65 Kn	PhiM <sub>Nx</sub> Wind	14.30 Kn-m	PhiV <sub>Nx</sub> Wind	49.01 Kn
-------------------------	-----------	-------------------------	------------	-------------------------	----------

Pole Shed App Ver 01 2022

PhiNcx Dead	181.59 Kn	PhiMnx Dead	8.58 Kn-m	PhiVnx Dead	29.41 Kn
PhiNcx Snow	242.12 Kn	PhiMnx Snow	11.44 Kn-m	PhiVnx Snow	39.21 Kn

**Checks**

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.61 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.36 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 21.84 \text{ mm} < 44.00 \text{ mm}$$

**Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

**Geometry For Middle Bay Pole**

Ds =	0.6 mm	Pile Diameter
L =	1350 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

Moment Wind =	7.34 Kn-m	Moment Snow =	Kn-m
Shear Wind =	2.72 Kn	Shear Snow =	5.09 Kn

**Pile Properties**

Safety Factory	0.55	
Hu =	5.41 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.70 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

$$\text{Applied Forces/Capacities} = 0.94 < 1 \text{ OK}$$

**End Pole Design**

**Geometry For End Bay Pole**

Pole Shed App Ver 01 2022

**Geometry**

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3300 mm
Area	27598 mm <sup>2</sup>	As	20698.2421875 mm <sup>2</sup>
I <sub>x</sub>	60639381 mm <sup>4</sup>	Z <sub>x</sub>	646820 mm <sup>3</sup>
I <sub>y</sub>	60639381 mm <sup>4</sup>	Z <sub>y</sub>	646820 mm <sup>3</sup>
Lateral Restraint	mm c/c		

**Loads**

Total Area over Pole = 6.75 m<sup>2</sup>

Dead	1.69 Kn	Live	1.69 Kn
Wind Down	5.00 Kn	Snow	8.91 Kn
Moment Wind	3.67 Kn-m	Moment snow	2.55 Kn-m
Phi	0.8	K <sub>8</sub>	0.79
K <sub>1</sub> snow	0.8	K <sub>1</sub> Dead	0.6
K <sub>1</sub> wind	1		

**Material**

Peeling	Steaming	Normal	Dry Use
f <sub>b</sub> =	36.3 MPa	f <sub>s</sub> =	2.96 MPa
f <sub>c</sub> =	18 MPa	f <sub>p</sub> =	7.2 MPa
f <sub>t</sub> =	22 MPa	E =	9257 MPa

**Capacities**

PhiN <sub>cx</sub> Wind	312.90 Kn	PhiM <sub>nx</sub> Wind	14.79 Kn-m	PhiV <sub>nx</sub> Wind	49.01 Kn
PhiN <sub>cx</sub> Dead	187.74 Kn	PhiM <sub>nx</sub> Dead	8.87 Kn-m	PhiV <sub>nx</sub> Dead	29.41 Kn
PhiN <sub>cx</sub> Snow	250.32 Kn	PhiM <sub>nx</sub> Snow	11.83 Kn-m	PhiV <sub>nx</sub> Snow	39.21 Kn

**Checks**

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.29 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.11 < 1 \text{ OK}$$

Deflection at top under service lateral loads = 11.88 mm < 47.88 mm

D <sub>s</sub> =	0.6 mm	Pile Diameter
L =	1350 mm	Pile embedment length
f <sub>l</sub> =	2700 mm	Distance at which the shear force is applied



Pole Shed App Ver 01 2022

f2 = 0 mm Distance of top soil at rest pressure

**Loads**

Total Area over Pole = 6.75 m<sup>2</sup>

Moment Wind =	3.67 Kn-m	Moment Snow =	2.55 Kn-m
Shear Wind =	1.36 Kn	Shear Snow =	2.55 Kn

**Pile Properties**

Safety Factory	0.55	
Hu =	5.41 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.70 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

Applied Forces/Capacities = 0.47 < 1 OK

**Drained Lateral Strength of End pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

**Geometry For End Bay Pole**

Ds =	0.6 mm	Pile Diameter
L =	1350 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

Moment Wind =	3.67 Kn-m	Moment Snow =	2.55 Kn-m
Shear Wind =	1.36 Kn	Shear Snow =	2.55 Kn

**Pile Properties**

Safety Factory	0.55	
Hu =	5.41 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.70 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

Applied Forces/Capacities =  $0.47 < 1$  OK

**Uplift Check**

Density of Concrete =  $24 \text{ Kn/m}^3$

Density of Timber Pole =  $5 \text{ Kn/m}^3$

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

$K_s$  (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil (18) x Height of Pile (1350) x  $K_s$  (1.5) x  $0.5 \times \tan(30) \times \pi \times \text{Dia of Pile} (0.6) \times \text{Height of Pile} (1350)$

Skin Friction =  $14.72 \text{ Kn}$

Weight of Pile + Pile Skin Friction =  $18.67 \text{ Kn}$

Uplift on one Pile =  $9.65 \text{ Kn}$

Uplift is ok