First Page

Job No.: Central Demolition   **Address:** Turners Rd Extension Feilding,Feilding,New Zealand   **Date:** 22/05/2024

Latitude: -40.254541   **Longitude:** 175.550567   **Elevation:** 53.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N1	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	3	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	8 m
Wind Region	NZ2	Terrain Category	1.88	Design Wind Speed	40.58 m/s
Wind Pressure	0.99 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono   Open

For roof Cp,i = 0.5355

For roof CP,e from 0 m To 3.75 m Cpe = -1.1   pe = -0.77 KPa   pnet = -1.19 KPa

For roof CP,e from 3.75 m To 7.50 m Cpe = -0.8   pe = -0.56 KPa   pnet = -0.98 KPa

For wall Windward Cp,i = 0.5355   side Wall Cp,i = -0.52

For wall Windward and Leeward   CP,e   from 0 m To 38.40 m   Cpe = 0.7   pe = 0.62 KPa   pnet = 1.13 KPa

For side wall   CP,e   from 0 m To 7.50 m   Cpe =   pe = -0.58 KPa   pnet = -0.07 KPa

Maximum Upward pressure used in roof member Design = 1.19 KPa

Maximum Downward pressure used in roof member Design = 0.69 KPa

Maximum Wall pressure used in Design = 1.13 KPa

Maximum Racking pressure used in Design = 1.06 KPa

Design Summary

Purlin Design

Purlin Spacing = 850 mm   Purlin Span = 4650 mm   Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.77   S1 Downward =11.27   S1 Upward =18.02

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.78 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	**285.90 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	2.27 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	**130.84 %**
$M_{0.9D-WnUp}$	-2.22 Kn-m	Capacity	-2.86 Kn-m	Passing Percentage	**128.83 %**
$V_{1.35D}$	0.67 Kn	Capacity	9.65 Kn	Passing Percentage	**1440.30 %**

Second page

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.96 Kn	Capacity	12.86 Kn	Passing Percentage	**656.12 %**
$V_{0.9D-WnUp}$	-1.91 Kn	Capacity	-16.08 Kn	Passing Percentage	**841.88 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 13.31 mm   Limit by Woolcock et al, 1999 Span/240 = 19.17 mm
Deflection under Dead and Service Wind = 18.75 mm   Limit by Woolcock et al, 1999 Span/100 = 46.00 mm

Reactions

Maximum downward =1.96 kn   Maximum upward = -1.91 kn

Number of Blocking = 1   if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 4800 mm   Internal Rafter Span = 9850 mm   Try Rafter 2x450x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =9.45   S1 Upward =9.45

Shear Capacity of timber =5.3 MPa   Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	19.65 Kn-m	Capacity	65.4 Kn-m	Passing Percentage	**332.82 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	57.63 Kn-m	Capacity	87.2 Kn-m	Passing Percentage	**151.31 %**
$M_{0.9D-WnUp}$	-56.18 Kn-m	Capacity	-109 Kn-m	Passing Percentage	**194.02 %**
$V_{1.35D}$	7.98 Kn	Capacity	69.04 Kn	Passing Percentage	**865.16 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	23.40 Kn	Capacity	92.04 Kn	Passing Percentage	**393.33 %**
$V_{0.9D-WnUp}$	-22.81 Kn	Capacity	-115.06 Kn	Passing Percentage	**504.43 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 22.445 mm   Limit by Woolcock et al, 1999 Span/240 = 41.67 mm
Deflection under Dead and Service Wind = 35.125 mm   Limit by Woolcock et al, 1999 Span/100 = 100.00 mm

Reactions

Maximum downward =23.40 kn   Maximum upward = -22.81 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 4

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 58.22 Kn > -22.81 Kn

Rafter Design External

External Rafter Load Width = 2400 mm   External Rafter Span = 9850 mm   Try Rafter 450x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.72

K8 Upward =0.72   S1 Downward =19.04   S1 Upward =19.04

Shear Capacity of timber =5.3 MPa   Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	9.82 Kn-m	Capacity	23.45 Kn-m	Passing Percentage	**238.80 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	28.82 Kn-m	Capacity	31.26 Kn-m	Passing Percentage	**108.47 %**
$M_{0.9D-WnUp}$	-28.09 Kn-m	Capacity	-39.08 Kn-m	Passing Percentage	**139.12 %**
$V_{1.35D}$	3.99 Kn	Capacity	34.52 Kn	Passing Percentage	**865.16 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	11.70 Kn	Capacity	46.02 Kn	Passing Percentage	**393.33 %**
$V_{0.9D-WnUp}$	-11.41 Kn	Capacity	-57.53 Kn	Passing Percentage	**504.21 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 24.94 mm   Limit by Woolcock et al, 1999 Span/240= 41.67 mm
Deflection under Dead and Service Wind = 35.12 mm   Limit by Woolcock et al, 1999 Span/100 = 100.00 mm

Reactions

Maximum downward =11.70 kn   Maximum upward = -11.41 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 4

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 45 mm

Pole Shed App Ver 01 2022

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds .... (Eq 4.12) = -65.11 kn > -11.41 Kn

Single Shear Capacity under short term loads = -29.11 Kn > -11.41 Kn

Girt Design Front and Back

Girt's Spacing = 1300 mm　　　　　　Girt's Span = 4800 mm　　　　　　Try Girt 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1　　K4 =1　　K5 =1　　K8 Downward =0.94

K8 Upward =0.54　　S1 Downward =13.93　　S1 Upward =22.75

Shear Capacity of timber =3 MPa　　Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	4.23 Kn-m	Capacity	4.56 Kn-m	Passing Percentage	**107.80 %**
$V_{0.9D-WnUp}$	3.53 Kn	Capacity	24.12 Kn	Passing Percentage	**683.29 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 13.47 mm　　　　　　Limit by Woolcock et al, 1999 Span/100 = 48.00 mm
Sag during installation = 32.19 mm

Reactions

Maximum = 3.53 kn

Girt Design Sides

Girt's Spacing = 0 mm　　　　　　Girt's Span = 5000 mm　　　　　　Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1　　K4 =1　　K5 =1　　K8 Downward =NaN

K8 Upward =NaN　　S1 Downward =NaN　　S1 Upward =NaN

Shear Capacity of timber =3 MPa　　Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	**NaN %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	**NaN %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm　　　　　　Limit by Woolcock et al. 1999 Span/100 = 50.00 mm

Sag during installation =NaN mm

Reactions

Maximum = 0.00 kn

Middle Pole Design

Geometry

350 SED H5 (Minimum 375 dia. at Floor Level)		Dry Use	Height	7550 mm
Area		103154 mm2	As	77365.4296875 mm2
Ix		847191750 mm4	Zx	4674161 mm3
Iy		847191750 mm4	Zx	4674161 mm3
Lateral Restraint		1300 mm c/c		

Loads

Total Area over Pole = 24 m2

Dead	6.00 Kn	Live	6.00 Kn
Wind Down	16.56 Kn	Snow	0.00 Kn
Moment wind	60.90 Kn-m		
Phi	0.8	K8	1.00
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	1485.42 Kn	PhiMnx Wind	135.74 Kn-m	PhiVnx Wind	183.20 Kn
PhiNcx Dead	891.25 Kn	PhiMnx Dead	81.44 Kn-m	PhiVnx Dead	109.92 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.47 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.22 < 1 OK

Deflection at top under service lateral loads = 65.91 mm < 75.50 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3		Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))					
Kp =	(1+sin(30)) / (1-sin(30))					

Pole Shed App Ver 01 2022

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	2600 mm	Pile embedment length
f1 =	6000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =   60.90 Kn-m

Shear Wind =   10.15 Kn

Pile Properties

Safety Factory	0.55	
Hu =	18.21 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	64.20 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.95 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

300 SED H5 (Minimum 325 dia. at Floor Level)	Dry Use	Height	7550 mm
Area	76660 mm2	As	57495.1171875 mm2
Ix	467896461 mm4	Zx	2994537 mm3
Iy	467896461 mm4	Zx	2994537 mm3
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 24 m2

Dead	6.00 Kn	Live	6.00 Kn
Wind Down	16.56 Kn	Snow	0.00 Kn
Moment Wind	30.45 Kn-m		
Phi	0.8	K8	0.49
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	538.38 Kn	PhiMnx Wind	42.41 Kn-m	PhiVnx Wind	136.15 Kn

PhiNcx Dead	323.03 Kn	PhiMnx Dead	25.45 Kn-m	PhiVnx Dead	81.69 Kn

Checks

$(Mx/PhiMnx)+(N/phiNcx) = 0.77 < 1$ OK

$(Mx/PhiMnx)^2+(N/phiNcx) = 0.57 < 1$ OK

Deflection at top under service lateral loads = 63.06 mm < 79.80 mm

Ds =	0.6 mm	Pile Diameter
L =	2000 mm	Pile embedment length
f1 =	6000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 24 m2

Moment Wind =	30.45 Kn-m
Shear Wind =	5.08 Kn

Pile Properties

Safety Factory	0.55	
Hu =	8.91 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	30.81 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.99 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3		Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))					
Kp =	(1+sin(30)) / (1-sin(30))					

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	2000 mm	Pile embedment length
f1 =	6000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	30.45 Kn-m
Shear Wind =	5.08 Kn

Pile Properties

Safety Factory	0.55	
Hu =	8.91 Kn	Ultimate Lateral Strength of the Pile, Short pile

Mu =   30.81 Kn-m   Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.99 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(2600) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(2600)

Skin Friction = 54.60 Kn

Weight of Pile + Pile Skin Friction = 57.47 Kn

Uplift on one Pile = 23.16 Kn

Uplift is ok

Last Page