Job Number:

Issue:

BWhite Consulting Ltd

PRODUCER STATEMENT-PS1-DESIGN

ISSUED BY: **BWhite Consulting Ltd (Design Engineer: Bevan White)**

TO BE SUPPLIED TO: **Southland District Council** IN RESPECT OF: **Proposed NEW Farm Shed**

AT: **10 Kowhai Lane, Oban, New Zealand**

LEGAL DESCRIPTION

We have been engaged by **Ezequote Pty Ltd** to provide **Specific Structural Engineering Design** services in respect of the requirements of Clause(s) **B1** of the Building Code for part only (as specified in the attachment to this statement), of the proposed building work.

☐ ALL ☑ Part only as specified: Purlins, Rafters, Girts, Poles, Columns, Pole embedment and all connections

The design has been prepared in accordance with compliance documents to NZ Building Code issued by Ministry of Business, Innovation & Employment Clauses **B1/VM1 and B1/VM4**

The proposed building work covered by the producer statement is described on **Ezequote** drawings title **EHB 06** and numbered **A101-A114 Rev-1** dated **19/01/02024** together with the following specfication, and other documents set out in the schedule attached to this statement: **Design Featured Report Dated 24/01/2024 and numbered "Second Page"**

On behalf of BWhite Consulting Ltd, and subject to:

1. Site verification of the following design assumptions: **an Ultimate foundation bearing pressure of 300 kPa in accordance with NZS3604:2011**
2. **The building has a design life of 50 years and am Importance Level 1**
3. **Unless specifically noted, compliance of the drawings to None-Specific codes such as NZS3604 and NZS4229 have not been checked by this practice**
4. **This Certificate does not cover any other building code clause including weather tightness**
5. **Inspections of the building to be completed by Southland District Council. As BWhite Consulting Ltd are not undertaking inspections, we cannot issue a producer Statement-PS4- Construction Review.**
6. **This Producer Statement- Design is valid for a building consent issued within 1 year from the date of issue**
7. All proprietary products meeting their performance specification requirements

I believe on reasonable grounds that a) the building, if constructed in accordance with the drawings, specifications, and other documents provided or listed in the attached schedule, will comply with the relevant provisions of the Building Code and that b), the presons who have undertaken the design have the necessary competency to do so. I also recommend the follow level of construction monitoring/observation:

☑ CM1 ☐ CM2 ☐ CM3 ☐ CM4 ☐ CM5 or as per agreement with owner/developer **(stated above)**

I, **Bevan White** am CPEng **108276** I am Member of Engineering New Zealand and hold the following qualification: **BE.Civil**

BWhite Consulting Ltd holds a current policy of Professional Indemnity Insurance no less than $200,000.

Signed by **Bevan White** on behalf of **BWhite Consulting Ltd** Dated: **24/01/2024**

Email: bwhitecpeng@gmail.com Phone: 0211-979786

This form is to accompany Form 2 of the Building(Forms) Regulations 2004 for the application of a Building Consent

Date: 24/01/2024

18B Jules Crescent,

BWhite Consulting Ltd

Pole Shed App Ver 01 2022

Bell Block New Plymouth 4312

New Zealand File No:

DESIGN FEATURES SUMMARY FOR PROPOSED NEW FARM SHED 10 KOWHAI LANE, OBAN, NEW ZEALAND

Site Specific Loads

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N5	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	D
Importance Level	1	Ultimate wind & EQ ARI	100 Years	Max Height	3.9 m
Wind Region	NZ4	Terrain Category	3.0	Design Wind Speed	39.97 m/s
Wind Pressure	0.96 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years

Timber

Sawn Timber to be graded to the properties of SG6 and SG8 or better as mentioned on plans, with moisture content of 18% or less for dry and 25% or less for wet.

The following standards have been used in the design of this structure

- NZS 3603:1993 Timber Structures Standard
- NZS 3604:2011 Timber Framed Buildings. Standards New Zealand, 2011
- NZS 3404:1997 Steel Structures
- AS/NZS 1170 2003 Structural Design Actions
- AS/NZS 1170.2 2021 Structural Design Actions-Wind Action
- Branz. "Engineering Basis of NZS 3604". April 2013

Yours Faithfully

BWhite CONSULTING LTD

Bevan White

Director | BE Civil . CMengNZ CPEng

Email: bwhitecpeng@gmail.com Contact: 0211 979 786

Job No.: EHB 06 **Address:** 10 Kowhai Lane, Oban, New Zealand **Date:** 24/01/2024

Latitude: -46.897257 **Longitude:** 168.122623 **Elevation:** 25 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N5	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	D
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.9 m
Wind Region	NZ4	Terrain Category	3.0	Design Wind Speed	39.97 m/s
Wind Pressure	0.96 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Second page

Shed Type = Mono Enclosed

For roof Cp,i = -0.3

For roof CP,e from 0 m To 3.30 m Cpe = -0.9 pe = -0.78 KPa pnet = -0.78 KPa

For roof CP,e from 3.30 m To 6.60 m Cpe = -0.5 pe = -0.43 KPa pnet = -0.43 KPa

For wall Windward Cp,i = -0.3 side Wall Cp,i = -0.3

For wall Windward and Leeward CP,e from 0 m To 8.50 m Cpe = 0.7 pe = 0.60 KPa pnet = 0.89 KPa

For side wall CP,e from 0 m To 3.30 m Cpe = pe = -0.56 KPa pnet = -0.56 KPa

Maximum Upward pressure used in roof member Design = 0.78 KPa

Maximum Downward pressure used in roof member Design = 0.45 KPa

Maximum Wall pressure used in Design = 0.89 KPa

Maximum Racking pressure used in Design = 1.03 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm Purlin Span = 4350 mm Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.47 S1 Downward =11.27 S1 Upward =24.64

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.72 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	**309.72 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.98 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	**150.00 %**
$M_{0.9D-WnUp}$	-1.18 Kn-m	Capacity	-1.76 Kn-m	Passing Percentage	**149.15 %**
$V_{1.35D}$	0.66 Kn	Capacity	9.65 Kn	Passing Percentage	**1462.12 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.82 Kn	Capacity	12.86 Kn	Passing Percentage	**706.59 %**
$V_{0.9D-WnUp}$	-1.09 Kn	Capacity	-16.08 Kn	Passing Percentage	**1475.23 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 10.76 mm Limit by Woolcock et al, 1999 Span/240 = 17.92 mm

Deflection under Dead and Service Wind = 13.01 mm Limit by Woolcock et al, 1999 Span/100 = 43.00 mm

Reactions

Maximum downward =1.82 kn Maximum upward = -1.09 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 4500 mm Internal Rafter Span = 4100 mm Try Rafter 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =6.81 S1 Upward =6.81

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.19 Kn-m	Capacity	10.08 Kn-m	Passing Percentage	**315.99 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	8.79 Kn-m	Capacity	13.44 Kn-m	Passing Percentage	**152.90 %**
$M_{0.9D-WnUp}$	-5.25 Kn-m	Capacity	-16.8 Kn-m	Passing Percentage	**320.00 %**
$V_{1.35D}$	3.11 Kn	Capacity	28.94 Kn	Passing Percentage	**930.55 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	8.58 Kn	Capacity	38.6 Kn	Passing Percentage	**449.88 %**
$V_{0.9D-WnUp}$	-5.12 Kn	Capacity	-48.24 Kn	Passing Percentage	**942.19 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 4.25 mm Limit by Woolcock et al, 1999 Span/240 = 17.71 mm

Deflection under Dead and Service Wind = 5.705 mm Limit by Woolcock et al, 1999 Span/100 = 42.50 mm

Reactions

Maximum downward =8.58 kn Maximum upward = -5.12 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 100 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 21.67 Kn > -5.12 Kn

Rafter Design External

External Rafter Load Width = 2250 mm External Rafter Span = 4092 mm Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.94

K8 Upward =0.94 S1 Downward =13.93 S1 Upward =13.93

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	1.59 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	**296.86 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	4.38 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	**143.84 %**
$M_{0.9D-WnUp}$	-2.61 Kn-m	Capacity	-7.87 Kn-m	Passing Percentage	**301.53 %**
$V_{1.35D}$	1.55 Kn	Capacity	14.47 Kn	Passing Percentage	**933.55 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	4.28 Kn	Capacity	19.30 Kn	Passing Percentage	**450.93 %**
$V_{0.9D-WnUp}$	-2.55 Kn	Capacity	-24.12 Kn	Passing Percentage	**945.88 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 4.72 mm Limit by Woolcock et al, 1999 Span/240= 17.71 mm

Deflection under Dead and Service Wind = 5.70 mm Limit by Woolcock et al, 1999 Span/100 = 42.50 mm

Reactions

Maximum downward =4.28 kn Maximum upward = -2.55 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds ..... (Eq 4.12) = -25.20 kn > -2.55 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -2.55 Kn

Girt Design Front and Back

Girt's Spacing = 1200 mm Girt's Span = 2250 mm Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.89 S1 Downward =9.63 S1 Upward =15.23

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.68 Kn-m	Capacity	1.87 Kn-m	Passing Percentage	**275.00 %**
$V_{0.9D-WnUp}$	1.20 Kn-m	Capacity	12.06 Kn-m	Passing Percentage	**1005.00 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 6.46 mm Limit by Woolcock et al, 1999 Span/100 = 22.50 mm
Sag during installation = 1.55 mm

Reactions

Maximum = 1.20 kn

Girt Design Sides

Girt's Spacing = 600 mm Girt's Span = 4250 mm Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.91 S1 Downward =9.63 S1 Upward =14.80

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.21 Kn-m	Capacity	1.91 Kn-m	Passing Percentage	**157.85 %**
$V_{0.9D-WnUp}$	1.13 Kn-m	Capacity	12.06 Kn-m	Passing Percentage	**1067.26 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 41.12 mm Limit by Woolcock et al. 1999 Span/100 = 42.50 mm
Sag during installation =19.78 mm

Reactions

Maximum = 1.13 kn

Middle Pole Design

Geometry

200x200 SG8 Dry	Dry Use	Height	3500 mm
Area	40000 mm2	As	30000 mm2
Ix	133333333 mm4	Zx	1333333 mm3
Iy	133333333 mm4	Zx	1333333 mm3
Lateral Restraint	3500 mm c/c		

Loads

Total Area over Pole = 19.125 m2

Dead	4.78 Kn	Live	4.78 Kn
Wind Down	8.61 Kn	Snow	12.05 Kn
Moment wind	8.79 Kn-m	Moment snow	2.63 Kn-m
Phi	0.8	K8	0.79
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Shaving	Steaming	Normal	Dry Use
fb =	14 MPa	fs =	3 MPa
fc =	18 MPa	fp =	8.9 MPa
ft =	6 MPa	E =	8000 MPa

Capacities

PhiNcx Wind	456.12 Kn	PhiMnx Wind	11.83 Kn-m	PhiVnx Wind	72.00 Kn
PhiNcx Dead	273.67 Kn	PhiMnx Dead	7.10 Kn-m	PhiVnx Dead	43.20 Kn
PhiNcx Snow	364.90 Kn	PhiMnx Snow	9.46 Kn-m	PhiVnx Snow	57.60 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.80 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.61 < 1 OK

Deflection at top under service lateral loads = 15.81 mm < 35.00 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2925 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	8.79 Kn-m	Moment Snow =	Kn-m
Shear Wind =	3.01 Kn	Shear Snow =	2.63 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.65 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.80 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.90 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 19.69 Kn

Uplift on one Pile = 10.61 Kn

Uplift is ok