Job No.: EHB 128 - 1   **Address:** 57 Blackmore Road, Garston, New Zealand   **Date:** 11/01/2024

Latitude: -45.474083   **Longitude:** 168.68633   **Elevation:** 326 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N5	Ground Snow Load	0.95 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	6.5 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	41.27 m/s
Wind Pressure	1.02 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono   Enclosed

For roof $C_{p,i}$ = 0.6722

For roof $C_{p,e}$ from 0 m To 15.85 m C_{pe} = -0.6948 p_e = -0.64 KPa p_{net} = -1.39 KPa

For roof $C_{p,e}$ from m To m C_{pe} = p_e = KPa p_{net} = KPa

For wall Windward $C_{p,i}$ = 0.6722   side Wall $C_{p,i}$ = -0.5984

For wall Windward and Leeward $C_{p,e}$ from 0 m To 5 m C_{pe} = 0.7 p_e = 0.64 KPa p_{net} = 1.30 KPa

For side wall $C_{p,e}$ from 0 m To 5 m C_{pe} = p_e = 0.64 KPa p_{net} = 1.30 KPa

Maximum Upward pressure used in roof member Design = 1.39 KPa

Maximum Downward pressure used in roof member Design = 0.39 KPa

Maximum Wall pressure used in Design = 0.3 KPa

Maximum Racking pressure used in Design = 0.92 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm   Purlin Span = 4850 mm   Try Purlin 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.87   S1 Downward =9.63   S1 Upward =15.73

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.89 Kn-m	Capacity	1.26 Kn-m	Passing Percentage	**141.57 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	2.46 Kn-m	Capacity	1.68 Kn-m	Passing Percentage	**68.29 %**
$M_{0.9D-WnUp}$	-3.08 Kn-m	Capacity	-1.83 Kn-m	Passing Percentage	**59.42 %**

First Page

$V_{1.35D}$	0.74 Kn	Capacity	7.24 Kn	Passing Percentage	**978.38 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	2.03 Kn	Capacity	9.65 Kn	Passing Percentage	**475.37 %**
$V_{0.9D-WnUp}$	-2.54 Kn	Capacity	-12.06 Kn	Passing Percentage	**474.80 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

$k2$ for Long Term Loads = 2

Deflection under Dead and Live Load = 39.62 mm   Limit by Woolcock et al, 1999 Span/240 = 20.00 mm

Deflection under Dead and Service Wind = 45.89 mm   Limit by Woolcock et al, 1999 Span/100 = 48.00 mm

Reactions

Maximum downward = 2.03 kn   Maximum upward = -2.54 kn

Number of Blocking = 1   if 0 then no blocking required, if 1 then one midspan blocking required

Intermediate Design Sides

Intermediate Spacing = 1993.6908517350157 mm   Intermediate Span = 5861 mm   Try Intermediate 2x250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

$K1$ Short term = 1 $K4$ =1 $K5$ =1 $K8$ Downward =0.97

$K8$ Upward =1.00 $S1$ Downward =12.68 $S1$ Upward =1.02

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	4.07 Kn-m	Capacity	11.66 Kn-m	Passing Percentage	**286.49 %**
$V_{0.9D-WnUp}$	2.78 Kn-m	Capacity	40.2 Kn-m	Passing Percentage	**1446.04 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 54.465 mm   Limit by Woolcock et al, 1999 Span/100 = 58.61 mm

Reactions

Maximum = 2.78 kn

Girt Design Front and Back

Girt's Spacing = 900 mm   Girt's Span = 2500 mm   Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

$K1$ Short term = 1 $K4$ =1 $K5$ =1 $K8$ Downward =1.00

$K8$ Upward =0.73 $S1$ Downward =11.27 $S1$ Upward =18.79

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

Second page

$M_{Wind+Snow}$	0.44 Kn-m	Capacity	2.72 Kn-m	Passing Percentage	**618.18 %**
$V_{0.9D-WnUp}$	0.71 Kn-m	Capacity	16.08 Kn-m	Passing Percentage	**2264.79 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 1.91 mm   Limit by Woolcock et al, 1999 Span/100 = 25.00 mm
Sag during installation = 2.37 mm

Reactions

Maximum = 0.71 kn

Girt Design Sides

Girt's Spacing = 900 mm   Girt's Span = 1994 mm   Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.83   S1 Downward =11.27   S1 Upward =16.78

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.28 Kn-m	Capacity	3.08 Kn-m	Passing Percentage	**1100.00 %**
$V_{0.9D-WnUp}$	0.57 Kn-m	Capacity	16.08 Kn-m	Passing Percentage	**2821.05 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 0.77 mm   Limit by Woolcock et al. 1999 Span/100 = 19.94 mm
Sag during installation =0.96 mm

Reactions

Maximum = 0.57 kn

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(2701) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(2701)

Skin Friction = 58.92 Kn

Weight of Pile + Pile Skin Friction = 65.11 Kn

Uplift on one Pile = 46.02 Kn

Uplift is ok

Last Page