

Job No.: 412miranda-rob**Address:** 43 Baigent Road, Miranda, New Zealand**Date:** 09/07/2024**Latitude:** -37.209371**Longitude:** 175.318714**Elevation:** 49 m**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.6 m
Wind Region	NZ1	Terrain Category	2.0	Design Wind Speed	41.57 m/s
Wind Pressure	1.04 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Enclosed

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 3.65 m $C_{p,e} = -0.9$ $p_e = -0.84$ KPa $p_{net} = -0.84$ KPa

For roof $C_{p,e}$ from 3.65 m To 7.30 m $C_{p,e} = -0.5$ $p_e = -0.47$ KPa $p_{net} = -0.47$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 7.50 m $C_{p,e} = 0.7$ $p_e = 0.65$ KPa $p_{net} = 0.96$ KPa

For side wall $C_{p,e}$ from 0 m To 3.65 m $C_{p,e} =$ $p_e = -0.61$ KPa $p_{net} = -0.61$ KPa

Maximum Upward pressure used in roof member Design = 0.84 KPa

Maximum Downward pressure used in roof member Design = 0.50 KPa

Maximum Wall pressure used in Design = 0.96 KPa

Maximum Racking pressure used in Design = 1.12 KPa

Design Summary**Purlin Design**

Purlin Spacing = 850 mm

Purlin Span = 4850 mm

Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.43 S1 Downward = 11.27 S1 Upward = 26.03

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.84 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	265.48 %
$M_{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}$	2.08 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	142.79 %
$M_{0.9D-W_nUp}$	-1.54 Kn-m	Capacity	-1.59 Kn-m	Passing Percentage	103.25 %
$V_{1.35D}$	0.70 Kn	Capacity	9.65 Kn	Passing Percentage	1378.57 %

Pole Shed App Ver 01 2022

V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	1.65 Kn	Capacity	12.86 Kn	Passing Percentage	779.39 %
V _{0.9D-WnUp}	-1.27 Kn	Capacity	-16.08 Kn	Passing Percentage	1266.14 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 15.78 mm Limit by Woolcock et al, 1999 Span/240 = 20.00 mm

Deflection under Dead and Service Wind = 19.73 mm Limit by Woolcock et al, 1999 Span/100 = 48.00 mm

Reactions

Maximum downward = 1.65 kn Maximum upward = -1.27 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 5000 mm Internal Rafter Span = 7350 mm Try Rafter 2x360x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K₁ Short term = 1 K₁ Medium term = 0.8 K₁ Long term = 0.6 K₄ = 1 K₅ = 1 K₈ Downward = 1.00

K₈ Upward = 1.00 S₁ Downward = 8.40 S₁ Upward = 8.40

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	11.40 Kn-m	Capacity	43.44 Kn-m	Passing Percentage	381.05 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	27.01 Kn-m	Capacity	57.92 Kn-m	Passing Percentage	214.44 %
M _{0.9D-WnUp}	-20.76 Kn-m	Capacity	-72.42 Kn-m	Passing Percentage	348.84 %
V _{1.35D}	6.20 Kn	Capacity	55.22 Kn	Passing Percentage	890.65 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	14.70 Kn	Capacity	73.64 Kn	Passing Percentage	500.95 %
V _{0.9D-WnUp}	-11.30 Kn	Capacity	-92.04 Kn	Passing Percentage	814.51 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 14.45 mm Limit by Woolcock et al, 1999 Span/240 = 31.25 mm

Deflection under Dead and Service Wind = 20.07 mm Limit by Woolcock et al, 1999 Span/100 = 75.00 mm

Reactions

Maximum downward = 14.70 kn Maximum upward = -11.30 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6$ fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

$K_{11} = 2.0$ fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -11.30 Kn

Rafter Design External

External Rafter Load Width = 2500 mm

External Rafter Span = 3566 mm

Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_1 Medium term = 0.8 K_1 Long term = 0.6 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 0.94

K_8 Upward = 0.94 S_1 Downward = 13.93 S_1 Upward = 13.93

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	1.34 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	352.24 %
$M_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	3.18 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	198.11 %
$M_{0.9D-W_nUp}$	-2.44 Kn-m	Capacity	-7.87 Kn-m	Passing Percentage	322.54 %
$V_{1.35D}$	1.50 Kn	Capacity	14.47 Kn	Passing Percentage	964.67 %
$V_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	3.57 Kn	Capacity	19.30 Kn	Passing Percentage	540.62 %
$V_{0.9D-W_nUp}$	-2.74 Kn	Capacity	-24.12 Kn	Passing Percentage	880.29 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k_2 for Long Term Loads = 2

Deflection under Dead and Live Load = 3.18 mm

Limit by Woolcock et al, 1999 Span/240 = 15.63 mm

Deflection under Dead and Service Wind = 3.97 mm

Limit by Woolcock et al, 1999 Span/100 = 37.50 mm

Reactions

Maximum downward = 3.57 kn Maximum upward = -2.74 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 14.9$ fpj = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

$K_{11} = 2.0$ $f_{c,j} = 36.1$ Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

$V = \phi_i \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s \dots\dots\dots$ (Eq 4.12) = -25.20 kn > -2.74 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -2.74 Kn

Girt Design Front and Back

Girt's Spacing = 1300 mm

Girt's Span = 5000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 0.86 S_1 Downward = 9.63 S_1 Upward = 16.05

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	3.90 Kn-m	Capacity	1.80 Kn-m	Passing Percentage	46.15 %
$V_{0.9D-WnUp}$	3.12 Kn	Capacity	12.06 Kn	Passing Percentage	386.54 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 107.79 mm

Limit by Woolcock et al, 1999 Span/100 = 50.00 mm

Sag during installation = 37.90 mm

Reactions

Maximum = 3.12 kn

Girt Design Sides

Girt's Spacing = 1300 mm

Girt's Span = 3750 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 0.69 S_1 Downward = 9.63 S_1 Upward = 19.66

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	2.19 Kn-m	Capacity	1.44 Kn-m	Passing Percentage	65.75 %
$V_{0.9D-WnUp}$	2.34 Kn	Capacity	12.06 Kn	Passing Percentage	515.38 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 34.11 mm

Limit by Woolcock et al. 1999 Span/100 = 37.50 mm

Sag during installation = 11.99 mm

Reactions

Maximum = 2.34 kn

Middle Pole Design

Geometry

200 UNI H5	Dry Use	Height	3640 mm
Area	31400 mm ²	As	23550 mm ²
Ix	78500000 mm ⁴	Zx	785000 mm ³
Iy	78500000 mm ⁴	Zy	785000 mm ³
Lateral Restraint	3640 mm c/c		

Loads

Total Area over Pole = 18.75 m²

Dead	4.69 Kn	Live	4.69 Kn
Wind Down	9.38 Kn	Snow	0.00 Kn
Moment wind	13.57 Kn-m		
Phi	0.8	K8	0.76
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Shaving	Steaming	Normal	Dry Use
fb =	34.325 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	20.75 MPa	E =	8793 MPa

Capacities

PhiNcx Wind	342.89 Kn	PhiMnx Wind	16.35 Kn-m	PhiVnx Wind	55.77 Kn
PhiNcx Dead	205.73 Kn	PhiMnx Dead	9.81 Kn-m	PhiVnx Dead	33.46 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.89 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.74 < 1$ OK

Deflection at top under service lateral loads = 36.21 mm < 36.40 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Pole Shed App Ver 01 2022

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1600 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	13.57 Kn-m
Shear Wind =	5.03 Kn

Pile Properties

Safety Factory	0.55	
Hu =	8.49 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	13.91 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.98 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

175 UNI H5	Dry Use	Height	3300 mm
Area	24041 mm ²	As	18030.46875 mm ²
Ix	46015259 mm ⁴	Zx	525889 mm ³
Iy	46015259 mm ⁴	Zy	525889 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 9.375 m²

Dead	2.34 Kn	Live	2.34 Kn
Wind Down	4.69 Kn	Snow	0.00 Kn
Moment Wind	4.52 Kn-m		
Phi	0.8	K8	0.73
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Shaving	Steaming	Normal	Dry Use
fb =	34.325 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	20.75 MPa	E =	8793 MPa

Capacities

PhiNcx Wind	251.50 Kn	PhiMnx Wind	10.49 Kn-m	PhiVnx Wind	42.70 Kn
-------------	-----------	-------------	------------	-------------	----------

PhiNcx Dead	150.90 Kn	PhiMnx Dead	6.29 Kn-m	PhiVnx Dead	25.62 Kn
-------------	-----------	-------------	-----------	-------------	----------

Checks

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.47 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.22 < 1 \text{ OK}$$

Deflection at top under service lateral loads = 20.31 mm < 35.91 mm

Ds =	0.6 mm	Pile Diameter
L =	1600 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 9.375 m²

Moment Wind =	4.52 Kn-m
Shear Wind =	1.68 Kn

Pile Properties

Safety Factory	0.55	
Hu =	8.49 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	13.91 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.33 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile**Assumed Soil Properties**

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1600 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	4.52 Kn-m
Shear Wind =	1.68 Kn

Pile Properties

Safety Factory	0.55	
Hu =	8.49 Kn	Ultimate Lateral Strength of the Pile, Short pile

Mu = 13.91 Kn-m Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.33 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1600) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1600)

Skin Friction = 20.68 Kn

Weight of Pile + Pile Skin Friction = 25.09 Kn

Uplift on one Pile = 11.53 Kn

Uplift is ok