<u>Pole Shed App Ver 01 2022</u>

Pole Shed App Ver 01 2022

Job No.: Lisa Welch and Daniel Mouatt		**Address:** Lot 10 DP 535188 Te Kapua Rise, Puketapu, New Zealand		**Date:** 17/04/2025	
Latitude: -39.483081		**Longitude:** 176.817103		**Elevation:** 29.5 m	

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N1	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	3	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	5.67 m
Wind Region	NZ2	Terrain Category	1.78	Design Wind Speed	37.68 m/s
Wind Pressure	0.85 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono Open

For roof Cp,i = -0.3

For roof CP,e from 0 m To 2.68 m Cpe = -1.035 pe = -0.77 KPa pnet = -0.77 KPa

For roof CP,e from 2.68 m To 5.35 m Cpe = -0.8325 pe = -0.62 KPa pnet = -0.62 KPa

For wall Windward Cp,i = -0.3 side Wall Cp,i = -0.3

For wall Windward and Leeward CP,e from 0 m To 12 m Cpe = 0.7 pe = 0.53 KPa pnet = 0.78 KPa

For side wall CP,e from 0 m To 5.35 m Cpe = pe = -0.49 KPa pnet = -0.49 KPa

Maximum Upward pressure used in roof member Design = 0.77 KPa

Maximum Downward pressure used in roof member Design = 0.33 KPa

Maximum Wall pressure used in Design = 0.78 KPa

Maximum Racking pressure used in Design = 0.89 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm	Purlin Span = 6040 mm	Try Purlin 240x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.94

K8 Upward =0.45   S1 Downward =13.82   S1 Upward =25.21

Shear Capacity of timber =5.3 MPa   Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	1.39 Kn-m	Capacity	9.37 Kn-m	Passing Percentage	**674.10 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	3.72 Kn-m	Capacity	12.49 Kn-m	Passing Percentage	**335.75 %**
$M_{0.9D-WnUp}$	-2.24 Kn-m	Capacity	-7.53 Kn-m	Passing Percentage	**336.16 %**
$V_{1.35D}$	0.92 Kn	Capacity	18.41 Kn	Passing Percentage	**2001.09 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.83 Kn	Capacity	24.54 Kn	Passing Percentage	**1340.98 %**
$V_{0.9D-WnUp}$	-1.48 Kn	Capacity	-30.68 Kn	Passing Percentage	**2072.97 %**

Deflections

Modulus of Elasticity = 12100 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 19.88 mm	Limit by Woolcock et al, 1999 Span/240 = 24.96 mm
Deflection under Dead and Service Wind = 15.99 mm	Limit by Woolcock et al, 1999 Span/100 = 59.90 mm

Reactions

Maximum downward =1.83 kn   Maximum upward = -1.48 kn

Number of Blocking = 1   if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 6190 mm   Internal Rafter Span = 8050 mm   Try Rafter 2x360x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =8.40   S1 Upward =8.40

Shear Capacity of timber =5.3 MPa   Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	16.92 Kn-m	Capacity	43.44 Kn-m	Passing Percentage	**256.74 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	33.85 Kn-m	Capacity	57.92 Kn-m	Passing Percentage	**171.11 %**

$M_{0.9D-WnUp}$	-27.33 Kn-m	Capacity	-72.42 Kn-m	Passing Percentage	**264.98 %**
$V_{1.35D}$	8.41 Kn	Capacity	55.22 Kn	Passing Percentage	**656.60 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	16.82 Kn	Capacity	73.64 Kn	Passing Percentage	**437.81 %**
$V_{0.9D-WnUp}$	-13.58 Kn	Capacity	-92.04 Kn	Passing Percentage	**677.76 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 25.56 mm   Limit by Woolcock et al, 1999 Span/240 = 34.17 mm
Deflection under Dead and Service Wind = 31.48 mm   Limit by Woolcock et al, 1999 Span/100 = 82.00 mm

Reactions

Maximum downward =16.82 kn   Maximum upward = -13.58 kn

Rafter to Pole Connection check

Bolt Size = M16 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 76.25 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 68.64 Kn > -13.58 Kn

Intermediate Design Front and Back

Intermediate Spacing = 3095 mm   Intermediate Span = 4803 mm   Try Intermediate 2x240x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =0.94

K8 Upward =1.00 S1 Downward =13.82 S1 Upward =1.01

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	6.96 Kn-m	Capacity	9.68 Kn-m	Passing Percentage	**139.08 %**
$V_{0.9D-WnUp}$	5.80 Kn	Capacity	-34.74 Kn	Passing Percentage	**598.97 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 29.87 mm Limit byWoolcock et al, 1999 Span/100 = 48.03 mm

Reactions

Maximum = 5.80 kn

Girt Design Front and Back

Girt's Spacing = 900 mm Girt's Span = 3095 mm Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =0.55 S1 Downward =12.23 S1 Upward =22.68

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.84 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	**196.43 %**
$V_{0.9D-WnUp}$	1.09 Kn	Capacity	13.75 Kn	Passing Percentage	**1261.47 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 4.87 mm Limit by Woolcock et al, 1999 Span/100 = 30.95 mm
Sag during installation = 6.87 mm

Reactions

Maximum = 1.09 kn

Girt Design Sides

Girt's Spacing = 900 mm   Girt's Span = 4100 mm   Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =0.75 S1 Downward =12.23 S1 Upward =18.45

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.48 Kn-m	Capacity	2.26 Kn-m	Passing Percentage	**152.70 %**
$V_{0.9D-WnUp}$	1.44 Kn	Capacity	13.75 Kn	Passing Percentage	**954.86 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 14.99 mm Limit by Woolcock et al. 1999 Span/100 = 41.00 mm
Sag during installation =21.15 mm

Reactions

Maximum = 1.44 kn

Middle Pole Design

Geometry

275 SED H5 (Minimum 300 dia. at Floor Level)	Dry Use	Height	5500 mm
Area	64885 mm2	As	48663.8671875 mm2
Ix	335197731 mm4	Zx	2331810 mm3
Iy	335197731 mm4	Zx	2331810 mm3
Lateral Restraint	5500 mm c/c		

Loads

Total Area over Pole = 25.379 m2

Dead	6.34 Kn	Live	6.34 Kn
Wind Down	8.38 Kn	Snow	0.00 Kn
Moment wind	33.13 Kn-m		

Phi	0.8	K8	0.71
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	665.98 Kn	PhiMnx Wind	48.27 Kn-m	PhiVnx Wind	115.24 Kn
PhiNcx Dead	399.59 Kn	PhiMnx Dead	28.96 Kn-m	PhiVnx Dead	69.14 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.72 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.50 < 1 OK

Deflection at top under service lateral loads = 46.78 mm < 55.00 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	2200 mm	Pile embedment length
f1 =	4252 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	33.13 Kn-m
Shear Wind =	7.79 Kn

Pile Properties

Safety Factory	0.55	
Hu =	14.70 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	37.37 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.89 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

225 SED H5 (Minimum 250 dia. at Floor Level)	Dry Use	Height	5470 mm
Area	44279 mm2	As	33209.1796875 mm2
Ix	156100441 mm4	Zx	1314530 mm3
Iy	156100441 mm4	Zx	1314530 mm3
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 12.6895 m2

Dead	3.17 Kn	Live	3.17 Kn
Wind Down	4.19 Kn	Snow	0.00 Kn
Moment Wind	11.04 Kn-m		
Phi	0.8	K8	0.53
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	338.54 Kn	PhiMnx Wind	20.27 Kn-m	PhiVnx Wind	78.64 Kn
PhiNcx Dead	203.12 Kn	PhiMnx Dead	12.16 Kn-m	PhiVnx Dead	47.18 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.58 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.33 < 1 OK

Deflection at top under service lateral loads = 34.43 mm < 56.56 mm

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	4252 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 12.6895 m2

Moment Wind =	11.04 Kn-m
Shear Wind =	2.60 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.23 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	12.86 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.86 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	4252 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	11.04 Kn-m
Shear Wind =	2.60 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.23 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	12.86 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.86 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(2200) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(2200)

Skin Friction = 39.09 Kn

Weight of Pile + Pile Skin Friction = 42.94 Kn

Uplift on one Pile = 13.83 Kn

Uplift is ok