

Job No.: GRAHAM AND JUDIE SIXSMITH **Address:** 32 Bridge Street waiuku, Waiuku, New Zealand
Latitude: -37.278763 **Longitude:** 174.737541

Date: 04/04/2024
Elevation: 9.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4 m
Wind Region	NZ1	Terrain Category	2.0	Design Wind Speed	42.59 m/s
Wind Pressure	1.09 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Enclosed

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 3.80 m $C_{p,e} = -0.9$ $p_e = -0.88$ KPa $p_{net} = -0.88$ KPa

For roof $C_{p,e}$ from 3.80 m To 7.60 m $C_{p,e} = -0.5$ $p_e = -0.49$ KPa $p_{net} = -0.49$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 9 m $C_{p,e} = 0.7$ $p_e = 0.69$ KPa $p_{net} = 1.02$ KPa

For side wall $C_{p,e}$ from 0 m To 3.80 m $C_{p,e} =$ $p_e = -0.64$ KPa $p_{net} = -0.64$ KPa

Maximum Upward pressure used in roof member Design = 0.88 KPa

Maximum Downward pressure used in roof member Design = 0.47 KPa

Maximum Wall pressure used in Design = 1.02 KPa

Maximum Racking pressure used in Design = 1.18 KPa

Design Summary**Purlin Design**

Purlin Spacing = 900 mm Purlin Span = 3850 mm Try Purlin 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 0.98

K8 Upward = 0.46 S1 Downward = 12.23 S1 Upward = 25.13

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.56 Kn-m	Capacity	1.79 Kn-m	Passing Percentage	319.64 %
$M_{1.2D+1.5L, 1.2D+S_n, 1.2D+W_nDn}$	1.56 Kn-m	Capacity	2.38 Kn-m	Passing Percentage	152.56 %
$M_{0.9D-W_nUp}$	-1.09 Kn-m	Capacity	-1.39 Kn-m	Passing Percentage	127.52 %
$V_{1.35D}$	0.58 Kn	Capacity	8.25 Kn	Passing Percentage	1422.41 %
$V_{1.2D+1.5L, 1.2D+S_n, 1.2D+W_nDn}$	1.33 Kn	Capacity	11.00 Kn	Passing Percentage	827.07 %
$V_{0.9D-W_nUp}$	-1.13 Kn	Capacity	-13.75 Kn	Passing Percentage	1216.81 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 8.51 mm

Limit by Woolcock et al, 1999 Span/240 = 15.83 mm

Deflection under Dead and Service Wind = 10.42 mm

Limit by Woolcock et al, 1999 Span/100 = 38.00 mm

Reactions

Second page

Maximum downward = 1.33 kn Maximum upward = -1.13 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 4000 mm

Internal Rafter Span = 8850 mm

Try Rafter 2x360x45 LVL11

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 1.00 S1 Downward = 8.40 S1 Upward = 8.40

Shear Capacity of timber = 5 MPa Bending Capacity of timber = 38 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M1.35D	13.22 Kn-m	Capacity	34.4 Kn-m	Passing Percentage	260.21 %
M1.2D+1.5L 1.2D+Sn 1.2D+WnDn	30.15 Kn-m	Capacity	45.86 Kn-m	Passing Percentage	152.11 %
M0.9D-WnUp	-25.65 Kn-m	Capacity	-57.32 Kn-m	Passing Percentage	223.47 %
V1.35D	5.97 Kn	Capacity	52.1 Kn	Passing Percentage	872.70 %
V1.2D+1.5L 1.2D+Sn 1.2D+WnDn	13.63 Kn	Capacity	69.46 Kn	Passing Percentage	509.61 %
V0.9D-WnUp	-11.59 Kn	Capacity	-86.84 Kn	Passing Percentage	749.27 %

Deflections

Modulus of Elasticity = 9900 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 26.635 mm

Limit by Woolcock et al, 1999 Span/240 = 37.50 mm

Deflection under Dead and Service Wind = 36.25 mm

Limit by Woolcock et al, 1999 Span/100 = 90.00 mm

Reactions

Maximum downward = 13.63 kn Maximum upward = -11.59 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 29.11 Kn > -11.59 Kn

Rafter Design External

External Rafter Load Width = 2000 mm

External Rafter Span = 4304 mm

Try Rafter 290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 0.89

K8 Upward = 0.89 S1 Downward = 15.23 S1 Upward = 15.23

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

Pole Shed App Ver 01 2022

M _{1.35D}	1.56 Kn-m	Capacity	3.78 Kn-m	Passing Percentage	242.31 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	3.57 Kn-m	Capacity	5.04 Kn-m	Passing Percentage	141.18 %
M _{0.9D-WnUp}	-3.03 Kn-m	Capacity	-6.29 Kn-m	Passing Percentage	207.59 %
V _{1.35D}	1.45 Kn	Capacity	12.59 Kn	Passing Percentage	868.28 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	3.31 Kn	Capacity	16.79 Kn	Passing Percentage	507.25 %
V _{0.9D-WnUp}	-2.82 Kn	Capacity	-20.98 Kn	Passing Percentage	743.97 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 6.49 mm

Limit by Woolcock et al, 1999 Span/240 = 18.75 mm

Deflection under Dead and Service Wind = 7.95 mm

Limit by Woolcock et al, 1999 Span/100 = 45.00 mm

Reactions

Maximum downward = 3.31 kn Maximum upward = -2.82 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K₁₁ = 14.9 f_{pj} = 12.9 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K₁₁ = 2.0 f_{cj} = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = $\phi \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s$ (Eq 4.12) = -21.73 kn > -2.82 Kn

Single Shear Capacity under short term loads = -9.75 Kn > -2.82 Kn

Intermediate Design Sides

Intermediate Spacing = 2250 mm

Intermediate Span = 3450 mm

Try Intermediate 2x140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K₁ Short term = 1 K₄ = 1 K₅ = 1 K₈ Downward = 1.00

K₈ Upward = 1.00 S₁ Downward = 10.36 S₁ Upward = 0.64

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	1.71 Kn-m	Capacity	3.3 Kn-m	Passing Percentage	192.98 %
V _{0.9D-WnUp}	1.98 Kn	Capacity	20.26 Kn	Passing Percentage	1023.23 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 38.095 mm

Limit by Woolcock et al, 1999 Span/100 = 34.50 mm

Reactions

Maximum = 1.98 kn

Girt Design Front and Back

Girt's Spacing = 900 mm

Girt's Span = 4000 mm

Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =0.76 S1 Downward =12.23 S1 Upward =18.23

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	1.84 Kn-m	Capacity	2.30 Kn-m	Passing Percentage	125.00 %
V _{0.9D-WnUp}	1.84 Kn	Capacity	13.75 Kn	Passing Percentage	747.28 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 17.76 mm

Limit by Woolcock et al, 1999 Span/100 = 40.00 mm

Sag during installation = 19.16 mm

Reactions

Maximum = 1.84 kn

Girt Design Sides

Girt's Spacing = 1300 mm

Girt's Span = 2250 mm

Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.84 S1 Downward =10.36 S1 Upward =16.38

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	0.84 Kn-m	Capacity	1.39 Kn-m	Passing Percentage	165.48 %
V _{0.9D-WnUp}	1.49 Kn	Capacity	10.13 Kn	Passing Percentage	679.87 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 6.42 mm

Limit by Woolcock et al. 1999 Span/100 = 22.50 mm

Sag during installation =1.92 mm

Reactions

Maximum = 1.49 kn

Middle Pole Design

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3640 mm
Area	35448 mm ²	As	26585.7421875 mm ²
I _x	100042702 mm ⁴	Z _x	941578 mm ³
I _y	100042702 mm ⁴	Z _y	941578 mm ³
Lateral Restraint	3400 mm c/c		

Loads

Total Area over Pole = 18 m²

Dead	4.50 Kn	Live	4.50 Kn
Wind Down	8.46 Kn	Snow	0.00 Kn

Pole Shed App Ver 01 2022

Moment wind	14.12 Kn-m		
Phi	0.8	K 8	0.86
K1 snow	0.8	K 1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	438.78 Kn	PhiMnx Wind	23.50 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	263.27 Kn	PhiMnx Dead	14.10 Kn-m	PhiVnx Dead	37.77 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.64 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.40 < 1$ OK

Deflection at top under service lateral loads = 31.20 mm < 36.40 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1600 mm	Pile embedment length
f1 =	3000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	14.12 Kn-m
Shear Wind =	4.71 Kn

Pile Properties

Safety Factory	0.55	
Hu =	7.93 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	14.27 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.99 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	3800 mm
Area	20729 mm2	As	15546.6796875 mm2
Ix	34210793 mm4	Zx	421056 mm3
Iy	34210793 mm4	Zy	421056 mm3
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 9 m²

Dead	2.25 Kn	Live	2.25 Kn
Wind Down	4.23 Kn	Snow	0.00 Kn
Moment Wind	4.71 Kn-m		
Phi	0.8	K8	0.52
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	154.24 Kn	PhiMnx Wind	6.32 Kn-m	PhiVnx Wind	36.81 Kn
PhiNcx Dead	92.55 Kn	PhiMnx Dead	3.79 Kn-m	PhiVnx Dead	22.09 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.80 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.61 < 1$ OK

Deflection at top under service lateral loads = 33.34 mm < 39.90 mm

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	3000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 9 m²

Moment Wind =	4.71 Kn-m
Shear Wind =	1.57 Kn

Pile Properties

Safety Factory	0.55	
Hu =	4.55 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.02 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.59 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	3000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind = 4.71 Kn-m
Shear Wind = 1.57 Kn

Pile Properties

Safety Factory	0.55	
Hu =	4.55 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.02 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.59 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1600) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1600)

Skin Friction = 20.68 Kn

Weight of Pile + Pile Skin Friction = 24.83 Kn

Uplift on one Pile = 11.79 Kn

Uplift is ok