

Pole Shed App Ver 01 2022

Job No.: 2407032 - 2

Address: 2395a Coastal Highway, Motueka, New Zealand

Date: 16/10/2024

Latitude: -41.148333

Longitude: 173.006631

Elevation: 31.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N3	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	D
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4 m
Wind Region	NZ2	Terrain Category	1.34	Design Wind Speed	48.62 m/s
Wind Pressure	1.42 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Very High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Enclosed

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 2.15 m $C_{p,e} = -1.0733$ $p_e = -1.37$ KPa $p_{net} = -1.37$ KPa

For roof $C_{p,e}$ from 2.15 m To 4.30 m $C_{p,e} = -0.8133$ $p_e = -1.04$ KPa $p_{net} = -1.04$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 6 m $C_{p,e} = 0.7$ $p_e = 0.89$ KPa $p_{net} = 1.32$ KPa

For side wall $C_{p,e}$ from 0 m To 4.30 m $C_{p,e} =$ $p_e = -0.83$ KPa $p_{net} = -0.83$ KPa

Maximum Upward pressure used in roof member Design = 1.37 KPa

Maximum Downward pressure used in roof member Design = 0.69 KPa

Maximum Wall pressure used in Design = 1.32 KPa

Maximum Racking pressure used in Design = 1.31 KPa

Design Summary

Purlin Design

Purlin Spacing = 800 mm

Purlin Span = 4850 mm

Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.75 S1 Downward = 11.27 S1 Upward = 18.41

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	0.79 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	282.28 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	2.33 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	127.47 %
M _{0.9D-W_nUp}	-2.69 Kn-m	Capacity	-2.79 Kn-m	Passing Percentage	125.68 %
V _{1.35D}	0.65 Kn	Capacity	9.65 Kn	Passing Percentage	1484.62 %

Pole Shed App Ver 01 2022

V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	1.92 Kn	Capacity	12.86 Kn	Passing Percentage	669.79 %
V _{0.9D-WnUp}	-2.22 Kn	Capacity	-16.08 Kn	Passing Percentage	724.32 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 14.86 mm Limit by Woolcock et al, 1999 Span/240 = 20.00 mm

Deflection under Dead and Service Wind = 20.92 mm Limit by Woolcock et al, 1999 Span/100 = 48.00 mm

Reactions

Maximum downward = 1.92 kn Maximum upward = -2.22 kn

Number of Blocking = 1 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 5000 mm Internal Rafter Span = 5850 mm Try Rafter 2x360x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K₁ Short term = 1 K₁ Medium term = 0.8 K₁ Long term = 0.6 K₄ = 1 K₅ = 1 K₈ Downward = 1.00

K₈ Upward = 1.00 S₁ Downward = 8.40 S₁ Upward = 8.40

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	7.22 Kn-m	Capacity	43.44 Kn-m	Passing Percentage	601.66 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	21.18 Kn-m	Capacity	57.92 Kn-m	Passing Percentage	273.47 %
M _{0.9D-WnUp}	-24.49 Kn-m	Capacity	-72.42 Kn-m	Passing Percentage	295.71 %
V _{1.35D}	4.94 Kn	Capacity	55.22 Kn	Passing Percentage	1117.81 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	14.48 Kn	Capacity	73.64 Kn	Passing Percentage	508.56 %
V _{0.9D-WnUp}	-16.75 Kn	Capacity	-92.04 Kn	Passing Percentage	549.49 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 5.92 mm Limit by Woolcock et al, 1999 Span/240 = 25.00 mm

Deflection under Dead and Service Wind = 9.26 mm Limit by Woolcock et al, 1999 Span/100 = 60.00 mm

Reactions

Maximum downward = 14.48 kn Maximum upward = -16.75 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6 \text{ fpj} = 22.7 \text{ Mpa}$ for Rafter with effective thickness = 90 mm

For Parallel to grain loading

$K_{11} = 2.0 \text{ fcj} = 36.1 \text{ Mpa}$ for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -16.75 Kn

Rafter Design External

External Rafter Load Width = 2500 mm

External Rafter Span = 5830 mm

Try Rafter 360x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_1 Medium term = 0.8 K_1 Long term = 0.6 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 0.81

K_8 Upward = 0.81 S_1 Downward = 17.01 S_1 Upward = 17.01

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.58 Kn-m	Capacity	17.70 Kn-m	Passing Percentage	494.41 %
$M_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	10.52 Kn-m	Capacity	23.60 Kn-m	Passing Percentage	224.33 %
$M_{0.9D-W_nUp}$	-12.16 Kn-m	Capacity	-29.50 Kn-m	Passing Percentage	242.60 %
$V_{1.35D}$	2.46 Kn	Capacity	27.61 Kn	Passing Percentage	1122.36 %
$V_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	7.21 Kn	Capacity	36.82 Kn	Passing Percentage	510.68 %
$V_{0.9D-W_nUp}$	-8.34 Kn	Capacity	-46.02 Kn	Passing Percentage	551.80 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k_2 for Long Term Loads = 2

Deflection under Dead and Live Load = 6.58 mm

Limit by Woolcock et al, 1999 Span/240 = 25.00 mm

Deflection under Dead and Service Wind = 9.26 mm

Limit by Woolcock et al, 1999 Span/100 = 60.00 mm

Reactions

Maximum downward = 7.21 kn Maximum upward = -8.34 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6 \text{ fpj} = 22.7 \text{ Mpa}$ for Rafter with effective thickness = 45 mm

For Parallel to grain loading

$K_{11} = 2.0$ $f_{c,j} = 36.1$ Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

$V = \phi_i \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s \dots\dots\dots$ (Eq 4.12) = -50.09 kn > -8.34 Kn

Single Shear Capacity under short term loads = -21.83 Kn > -8.34 Kn

Intermediate Design Sides

Intermediate Spacing = 3000 mm

Intermediate Span = 3551 mm

Try Intermediate 2x200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 1.00 S_1 Downward = 11.27 S_1 Upward = 0.71

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	3.12 Kn-m	Capacity	7.46 Kn-m	Passing Percentage	239.10 %
$V_{0.9D-WnUp}$	3.52 Kn	Capacity	32.16 Kn	Passing Percentage	913.64 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 22.76 mm

Limit by Woolcock et al, 1999 Span/100 = 35.51 mm

Reactions

Maximum = 3.52 kn

Girt Design Front and Back

Girt's Spacing = 700 mm

Girt's Span = 5000 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 0.89 S_1 Downward = 11.27 S_1 Upward = 15.34

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	2.89 Kn-m	Capacity	3.31 Kn-m	Passing Percentage	114.53 %
$V_{0.9D-WnUp}$	2.31 Kn	Capacity	16.08 Kn	Passing Percentage	696.10 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 33.67 mm

Limit by Woolcock et al, 1999 Span/100 = 50.00 mm

Sag during installation = 37.90 mm

Reactions

Maximum = 2.31 kn

Girt Design Sides

Girt's Spacing = 700 mm

Girt's Span = 3000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.79 S1 Downward =9.63 S1 Upward =17.59

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.04 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	158.65 %
$V_{0.9D-WnUp}$	1.39 Kn	Capacity	12.06 Kn	Passing Percentage	867.63 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 10.34 mm

Limit by Woolcock et al. 1999 Span/100 = 30.00 mm

Sag during installation =4.91 mm

Reactions

Maximum = 1.39 kn

End Pole Design

Geometry For End Bay Pole

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3640 mm
Area	35448 mm ²	As	26585.7421875 mm ²
I _x	100042702 mm ⁴	Z _x	941578 mm ³
I _y	100042702 mm ⁴	Z _y	941578 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 15 m²

Dead	3.75 Kn	Live	3.75 Kn
Wind Down	10.35 Kn	Snow	0.00 Kn
Moment Wind	9.80 Kn-m		
Phi	0.8	K8	0.81
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Pole Shed App Ver 01 2022

Peeling	Steaming	Normal	Dry Use
$f_b =$	36.3 MPa	$f_s =$	2.96 MPa
$f_c =$	18 MPa	$f_p =$	7.2 MPa
$f_t =$	22 MPa	$E =$	9257 MPa

Capacities

PhiNcx Wind	413.18 Kn	PhiMnx Wind	22.13 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	247.91 Kn	PhiMnx Dead	13.28 Kn-m	PhiVnx Dead	37.77 Kn

Checks

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.49 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.24 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 23.73 \text{ mm} < 39.90 \text{ mm}$$

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	3000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

$$\text{Total Area over Pole} = 15 \text{ m}^2$$

Moment Wind =	9.80 Kn-m
Shear Wind =	3.27 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.68 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	11.94 Kn-m	Ultimate Moment Capacity of Pile

Checks

$$\text{Applied Forces/Capacities} = 0.82 < 1 \text{ OK}$$

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	3000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Pole Shed App Ver 01 2022

Moment Wind = 9.80 Kn-m
Shear Wind = 3.27 Kn

Pile Properties

Safety Factor	0.55	
Hu =	6.68 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	11.94 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = $0.82 < 1$ OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil (18) x Height of Pile (2200) x Ks (1.5) x 0.5 x tan(30) x π x Dia of Pile (0.6) x Height of Pile (2200)

Skin Friction = 39.09 Kn

Weight of Pile + Pile Skin Friction = 44.13 Kn

Uplift on one Pile = 17.18 Kn

Uplift is ok