



**Job No.:** 511-5024695--Open front**Address:** 241 Grahams Rd, Ashburton, New Zealand**Date:** 14/08/2024**Latitude:** -43.93688**Longitude:** 171.739282**Elevation:** 81.5 m**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N4	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.6 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	38.22 m/s
Wind Pressure	0.88 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Mono Open

For roof  $C_{p,i} = 0.6574$

For roof  $C_{p,e}$  from 0 m To 1.65 m  $C_{p,e} = -0.94$   $p_e = -0.60$  KPa  $p_{net} = -1.11$  KPa

For roof  $C_{p,e}$  from 1.65 m To 3.30 m  $C_{p,e} = -0.88$   $p_e = -0.56$  KPa  $p_{net} = -1.07$  KPa

For wall Windward  $C_{p,i} = 0.6574$  side Wall  $C_{p,i} = -0.5709$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 14.4 m  $C_{p,e} = 0.7$   $p_e = 0.55$  KPa  $p_{net} = 1.09$  KPa

For side wall  $C_{p,e}$  from 0 m To 3.30 m  $C_{p,e} =$   $p_e = -0.51$  KPa  $p_{net} = 0.03$  KPa

Maximum Upward pressure used in roof member Design = 1.11 KPa

Maximum Downward pressure used in roof member Design = 0.70 KPa

Maximum Wall pressure used in Design = 1.09 KPa

Maximum Racking pressure used in Design = 0.94 KPa

**Design Summary****Purlin Design**

Purlin Spacing = 850 mm

Purlin Span = 4650 mm

Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.77 S1 Downward = 11.27 S1 Upward = 18.02

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

$M_{1.35D}$	0.78 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	<b>285.90 %</b>
$M_{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}$	2.3 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	<b>129.13 %</b>
$M_{0.9D-W_nUp}$	-2.03 Kn-m	Capacity	-2.86 Kn-m	Passing Percentage	<b>140.89 %</b>
$V_{1.35D}$	0.67 Kn	Capacity	9.65 Kn	Passing Percentage	<b>1440.30 %</b>

### Pole Shed App Ver 01 2022

V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	1.98 Kn	Capacity	12.86 Kn	Passing Percentage	<b>649.49 %</b>
V <sub>0.9D-WnUp</sub>	-1.75 Kn	Capacity	-16.08 Kn	Passing Percentage	<b>918.86 %</b>

#### **Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 13.31 mm                      Limit by Woolcock et al, 1999 Span/240 = 19.17 mm

Deflection under Dead and Service Wind = 18.86 mm                      Limit by Woolcock et al, 1999 Span/100 = 46.00 mm

#### **Reactions**

Maximum downward = 1.98 kn    Maximum upward = -1.75 kn

Number of Blocking = 1    if 0 then no blocking required, if 1 then one midspan blocking required

#### **Rafter Design Internal**

Internal Rafter Load Width = 4800 mm                      Internal Rafter Span = 5850 mm                      Try Rafter 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K<sub>1</sub> Short term = 1    K<sub>1</sub> Medium term = 0.8    K<sub>1</sub> Long term = 0.6    K<sub>4</sub> = 1    K<sub>5</sub> = 1    K<sub>8</sub> Downward = 1.00

K<sub>8</sub> Upward = 1.00    S<sub>1</sub> Downward = 6.81    S<sub>1</sub> Upward = 6.81

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>1.35D</sub>	4.26 Kn-m	Capacity	10.08 Kn-m	Passing Percentage	<b>236.62 %</b>
M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	10.90 Kn-m	Capacity	13.44 Kn-m	Passing Percentage	<b>123.30 %</b>
M <sub>0.9D-WnUp</sub>	11.69 Kn-m	Capacity	-16.8 Kn-m	Passing Percentage	<b>143.71 %</b>
V <sub>1.35D</sub>	4.13 Kn	Capacity	28.94 Kn	Passing Percentage	<b>700.73 %</b>
V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	10.57 Kn	Capacity	38.6 Kn	Passing Percentage	<b>365.18 %</b>
V <sub>0.9D-WnUp</sub>	15.27 Kn	Capacity	-48.24 Kn	Passing Percentage	<b>315.91 %</b>

#### **Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 45 mm                      Limit by Woolcock et al, 1999 Span/240 = 25.00 mm

Deflection under Dead and Service Wind = 6 mm                      Limit by Woolcock et al, 1999 Span/100 = 60.00 mm

#### **Reactions**

Maximum downward = 10.57 kn    Maximum upward = 15.27 kn

#### **Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

### Pole Shed App Ver 01 2022

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 14.9$   $f_{pj} = 12.9$  Mpa for Rafter with effective thickness = 100 mm

For Parallel to grain loading

$K_{11} = 2.0$   $f_{ej} = 36.1$  Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 32.51 Kn > 15.27 Kn

Prop on Sides = 2 2/SG820050Dry 1000mm Reaction Prop = 18.92 Kn down 20.29 Kn Up

Prop Combined axial and bending ratios  $(M_y/\Phi \times M_{ny}) + (N_c/\Phi \times N_{cy})$  should be less than or equal to 1

For Short Term Load = 0.74 < 1 OK

For Medium Term Load = 0.86 < 1 OK

For Long Term Load = 0.45 < 1 OK

#### **Prop Connection check**

Effective width of Pole used in Calculations = 175 mm -20mm (Margin for chamfer)

Bolt Size = M12 Number of Bolts = 4

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Angle of prop = 45 degree

Prop Connection Capacity under Short term loads: 49.69 Kn > 20.29 Kn OK

Prop Connection Capacity under Medium term loads: 39.75 Kn > 18.92 Kn OK

Prop Connection Capacity under Long term loads: 29.81 Kn > 7.45 Kn OK

#### **Intermediate Design Sides**

Intermediate Spacing = 3000 mm

Intermediate Span = 3150 mm

Try Intermediate 2x200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

$K_1$  Short term = 1  $K_4 = 1$   $K_5 = 1$   $K_8$  Downward = 1.00

$K_8$  Upward = 1.00  $S_1$  Downward = 11.27  $S_1$  Upward = 0.67

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

$M_{Wind+Snow}$	2.03 Kn-m	Capacity	7.46 Kn-m	Passing Percentage	<b>367.49 %</b>
$V_{0.9D-WnUp}$	2.57 Kn	Capacity	32.16 Kn	Passing Percentage	<b>1251.36 %</b>

#### **Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 21.245 mm

Limit by Woolcock et al, 1999 Span/100 = 31.50 mm

**Reactions**

Maximum = 2.57 kn

**Girt Design Front and Back**

Girt's Spacing = 850 mm

Girt's Span = 4800 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.75    S1 Downward =11.27    S1 Upward =18.41

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

$M_{Wind+Snow}$	2.67 Kn-m	Capacity	2.79 Kn-m	Passing Percentage	<b>104.49 %</b>
$V_{0.9D-WnUp}$	2.22 Kn	Capacity	16.08 Kn	Passing Percentage	<b>724.32 %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 45.25 mm

Limit by Woolcock et al, 1999 Span/100 = 48.00 mm

Sag during installation = 32.19 mm

**Reactions**

Maximum = 2.22 kn

**Girt Design Sides**

Girt's Spacing = 1300 mm

Girt's Span = 3000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.79    S1 Downward =9.63    S1 Upward =17.59

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

$M_{Wind+Snow}$	1.59 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	<b>103.77 %</b>
$V_{0.9D-WnUp}$	2.13 Kn	Capacity	12.06 Kn	Passing Percentage	<b>566.20 %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 25.03 mm

Limit by Woolcock et al. 1999 Span/100 = 30.00 mm

Sag during installation =4.91 mm

**Reactions**

Maximum = 2.13 kn

## Middle Pole Design

### Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3300 mm
Area	27598 mm <sup>2</sup>	As	20698.2421875 mm <sup>2</sup>
I <sub>x</sub>	60639381 mm <sup>4</sup>	Z <sub>x</sub>	646820 mm <sup>3</sup>
I <sub>y</sub>	60639381 mm <sup>4</sup>	Z <sub>y</sub>	646820 mm <sup>3</sup>
Lateral Restraint	1300 mm c/c		

### Loads

Total Area over Pole = 14.4 m<sup>2</sup>

Dead	4.70 Kn	Live	3.68 Kn
Wind Down	10.32 Kn	Snow	9.28 Kn
Moment wind	4.64 Kn-m	Moment snow	7.11 Kn-m
Phi	0.8	K <sub>8</sub>	1.00
K <sub>1</sub> snow	0.8	K <sub>1</sub> Dead	0.6
K <sub>1</sub> wind	1		

### Material

Peeling	Steaming	Normal	Dry Use
f <sub>b</sub> =	36.3 MPa	f <sub>s</sub> =	2.96 MPa
f <sub>c</sub> =	18 MPa	f <sub>p</sub> =	7.2 MPa
f <sub>t</sub> =	22 MPa	E =	9257 MPa

### Capacities

PhiN <sub>c</sub> Wind	397.41 Kn	PhiM <sub>n</sub> Wind	18.78 Kn-m	PhiV <sub>n</sub> Wind	49.01 Kn
PhiN <sub>c</sub> Dead	238.44 Kn	PhiM <sub>n</sub> Dead	11.27 Kn-m	PhiV <sub>n</sub> Dead	29.41 Kn
PhiN <sub>c</sub> Snow	317.93 Kn	PhiM <sub>n</sub> Snow	15.03 Kn-m	PhiV <sub>n</sub> Snow	39.21 Kn

### Checks

$$(M_x/\Phi M_n) + (N/\Phi N_c) = 0.72 < 1 \text{ OK}$$

$$(M_x/\Phi M_n)^2 + (N/\Phi N_c) = 0.50 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 32.52 \text{ mm} < 33.00 \text{ mm}$$

## Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

### Assumed Soil Properties

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K <sub>0</sub> =	(1-sin(30)) / (1+sin(30))				
K <sub>p</sub> =	(1+sin(30)) / (1-sin(30))				

### Geometry For Middle Bay Pole

D <sub>s</sub> =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f <sub>l</sub> =	2700 mm	Distance at which the shear force is applied

Pole Shed App Ver 01 2022

$f_2 =$  0 mm Distance of top soil at rest pressure

**Loads**

Moment Wind =	4.64 Kn-m	Moment Snow =	Kn-m
Shear Wind =	4.05 Kn	Shear Snow =	3.88 Kn

**Pile Properties**

Safety Factory	0.55		
$H_u =$	5.96 Kn	Ultimate Lateral Strength of the Pile, Short pile	
$M_u =$	9.63 Kn-m	Ultimate Moment Capacity of Pile	

**Checks**

Applied Forces/Capacities = 0.68 < 1 OK

**End Pole Design**

**Geometry For End Bay Pole**

**Geometry**

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3300 mm
Area	27598 mm <sup>2</sup>	$A_s$	20698.2421875 mm <sup>2</sup>
$I_x$	60639381 mm <sup>4</sup>	$Z_x$	646820 mm <sup>3</sup>
$I_y$	60639381 mm <sup>4</sup>	$Z_y$	646820 mm <sup>3</sup>
Lateral Restraint	mm c/c		

**Loads**

Total Area over Pole = 14.4 m<sup>2</sup>

Dead	3.60 Kn	Live	3.60 Kn
Wind Down	10.08 Kn	Snow	9.07 Kn
Moment Wind	5.47 Kn-m	Moment snow	1.94 Kn-m
$\Phi$	0.8	K8	0.79
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

**Material**

Peeling	Steaming	Normal	Dry Use
$f_b =$	36.3 MPa	$f_s =$	2.96 MPa
$f_c =$	18 MPa	$f_p =$	7.2 MPa
$f_t =$	22 MPa	E =	9257 MPa

**Capacities**

$\Phi H_{Ncx}$ Wind	312.90 Kn	$\Phi H_{Mnx}$ Wind	14.79 Kn-m	$\Phi H_{Vnx}$ Wind	49.01 Kn
$\Phi H_{Ncx}$ Dead	187.74 Kn	$\Phi H_{Mnx}$ Dead	8.87 Kn-m	$\Phi H_{Vnx}$ Dead	29.41 Kn
$\Phi H_{Ncx}$ Snow	250.32 Kn	$\Phi H_{Mnx}$ Snow	11.83 Kn-m	$\Phi H_{Vnx}$ Snow	39.21 Kn

**Checks**

$$(M_x/\phi M_{nx}) + (N/\phi N_{cx}) = 0.43 < 1 \text{ OK}$$

$$(M_x/\phi M_{nx})^2 + (N/\phi N_{cx}) = 0.20 < 1 \text{ OK}$$

Deflection at top under service lateral loads = 17.70 mm < 35.91 mm

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

#### Loads

Total Area over Pole = 14.4 m<sup>2</sup>

Moment Wind =	5.47 Kn-m	Moment Snow =	1.94 Kn-m
Shear Wind =	2.03 Kn	Shear Snow =	1.94 Kn

#### Pile Properties

Safety Factory	0.55	
Hu =	4.89 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	7.84 Kn-m	Ultimate Moment Capacity of Pile

#### Checks

Applied Forces/Capacities = 0.70 < 1 OK

### Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

#### Assumed Soil Properties

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

#### Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

#### Loads

Moment Wind =	5.47 Kn-m	Moment Snow =	1.94 Kn-m
Shear Wind =	2.03 Kn	Shear Snow =	1.94 Kn

#### Pile Properties

Safety Factory	0.55	
Hu =	4.89 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	7.84 Kn-m	Ultimate Moment Capacity of Pile

#### Checks



Applied Forces/Capacities = 0.70 < 1 OK

### **Uplift Check**

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 19.92 Kn

Uplift on one Pile = 12.74 Kn

Uplift is ok