Pole Shed App Ver 01 2022

First Page

Job No.: 2405053 - 3   **Address:** 270 Mt Heslington Road, Brightwater, New Zealand   **Date:** 29/07/2024

Latitude: -41.403304   **Longitude:** 173.101144   **Elevation:** 82 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	5.6 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	40.91 m/s
Wind Pressure	1 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Gable   Enclosed

For roof Cp,i = -0.3

For roof CP,e   from 0 m To 2.67 m Cpe = -0.9272   pe = -0.84 KPa   pnet = -0.84 KPa

For roof CP,e   from 2.67 m To 5.34 m Cpe = -0.8864   pe = -0.80 KPa   pnet = -0.80 KPa

For wall Windward Cp,i = -0.3   side Wall Cp,i = -0.3

For wall Windward and Leeward   CP,e   from 0 m To 19.6 m Cpe = 0.7   pe = 0.63 KPa   pnet = 0.63 KPa

For side wall CP,e   from 0 m To 5.34 m Cpe =   pe = -0.59 KPa   pnet = -0.59 KPa

Maximum Upward pressure used in roof member Design = 0.84 KPa

Maximum Downward pressure used in roof member Design = 0.28 KPa

Maximum Wall pressure used in Design = 0.63 KPa

Maximum Racking pressure used in Design = 0.91 KPa

Design Summary

Girt Design Front and Back

Girt's Spacing = 0 mm   Girt's Span = 2500 mm   Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =NaN

K8 Upward =NaN   S1 Downward =NaN   S1 Upward =NaN

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	**NaN %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	**NaN %**

Deflections

Second page

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm   Limit by Woolcock et al, 1999 Span/100 = 25.00 mm

Sag during installation = NaN mm

Reactions

Maximum = 0.00 kn

Girt Design Sides

Girt's Spacing = 0 mm   Girt's Span = 3500 mm   Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =NaN

K8 Upward =NaN   S1 Downward =NaN   S1 Upward =NaN

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	**NaN %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	**NaN %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm   Limit by Woolcock et al. 1999 Span/100 = 35.00 mm

Sag during installation =NaN mm

Reactions

Maximum = 0.00 kn

Middle Pole Design

Geometry

225 SED H5 (Minimum 250 dia. at Floor Level)	Dry Use	Height	5240 mm
Area	44279 mm2	As	33209.1796875 mm2
Ix	156100441 mm4	Zx	1314530 mm3
Iy	156100441 mm4	Zx	1314530 mm3
Lateral Restraint	5240 mm c/c		

Loads

Total Area over Pole = 35 m2

Dead	8.75 Kn	Live	8.75 Kn
Wind Down	9.80 Kn	Snow	0.00 Kn
Moment wind	14.05 Kn-m		
Phi	0.8	K8	0.57
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming		Normal	Dry Use
fb =	36.3 MPa		fs =	2.96 MPa
fc =	18 MPa		fp =	7.2 MPa
ft =	22 MPa		E =	9257 MPa

Capacities

PhiNcx Wind	364.95 Kn	PhiMnx Wind	21.85 Kn-m	PhiVnx Wind	78.64 Kn
PhiNcx Dead	218.97 Kn	PhiMnx Dead	13.11 Kn-m	PhiVnx Dead	47.18 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.72 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.49 < 1 OK

Deflection at top under service lateral loads = 40.08 mm < 52.40 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3		Friction angle	30 deg	Cohesion	0 Kn/m3

$K0 = $ (1-sin(30)) / (1+sin(30))

$Kp = $ (1+sin(30)) / (1-sin(30))

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1600 mm	Pile embedment length
f1 =	4200 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =		14.05 Kn-m
Shear Wind =		3.34 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.29 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	15.37 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.91 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)   Dry Use   Height   5450 mm

Area	35448 mm2	As	26585.7421875 mm2
Ix	100042702 mm4	Zx	941578 mm3
Iy	100042702 mm4	Zx	941578 mm3
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 17.5 m2

Dead	4.38 Kn	Live	4.38 Kn
Wind Down	4.90 Kn	Snow	0.00 Kn
Moment Wind	7.02 Kn-m		
Phi	0.8	K8	0.44
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming		Normal	Dry Use
f_b =	36.3 MPa		f_s =	2.96 MPa
f_c =	18 MPa		f_p =	7.2 MPa
f_t =	22 MPa		E =	9257 MPa

Capacities

PhiNcx Wind	224.31 Kn	PhiMnx Wind	12.02 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	134.59 Kn	PhiMnx Dead	7.21 Kn-m	PhiVnx Dead	37.77 Kn

Checks

$(M_x/PhiM_{nx})+(N/phiN_{cx})$ = 0.65 < 1 OK

$(M_x/PhiM_{nx})^2+(N/phiN_{cx})$ = 0.40 < 1 OK

Deflection at top under service lateral loads = 33.33 mm < 55.86 mm

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	4200 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 17.5 m2

Moment Wind =	7.02 Kn-m
Shear Wind =	1.67 Kn

Pile Properties

Safety Factory	0.55	
Hu =	3.56 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.58 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.82 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

| Gamma | 18 Kn/m3 | | | Friction angle | 30 deg | Cohesion | 0 Kn/m3 |

$K0 = (1-\sin(30)) / (1+\sin(30))$

$Kp = (1+\sin(30)) / (1-\sin(30))$

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	4200 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	7.02 Kn-m
Shear Wind =	1.67 Kn

Pile Properties

Safety Factory	0.55	
Hu =	3.56 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.58 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.82 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1600) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1600)

Skin Friction = 20.68 Kn

Weight of Pile + Pile Skin Friction = 24.34 Kn

Uplift on one Pile = 21.52 Kn

Uplift is ok

Last Page