



CITY OF SABETHA MUNICIPAL POWER PLANT

EVERGY INTERCONNECTION

DATE/TIME	KW	KV	PF	AMPS			VOLTAGE			Hz	TAP
				1	2	3	1	2	3		
12/19/2025 00:00:00	6063	734	0.99	275	279	278	7.34	7.36	7.31	60.0	-2
12/19/2025 01:00:00	5926	735	0.99	268	270	273	7.35	7.38	7.33	60.0	-2
12/19/2025 02:00:00	5739	737	0.99	260	261	264	7.36	7.39	7.34	60.0	-2
12/19/2025 03:00:00	5496	734	0.99	248	250	257	7.33	7.37	7.31	60.01	-1
12/19/2025 04:00:00	5303	733	0.99	240	243	246	7.32	7.35	7.31	60.0	-1
12/19/2025 05:00:00	5102	733	0.99	230	234	238	7.33	7.36	7.32	60.0	-1
12/19/2025 06:00:00	4987	734	0.99	225	228	232	7.33	7.37	7.32	60.0	-1
12/19/2025 07:00:00	4929	732	0.99	221	226	231	7.32	7.35	7.31	60.0	-1
12/19/2025 08:00:00	4977	732	0.99	224	230	232	7.31	7.34	7.3	60.0	-1
12/19/2025 09:00:00	5066	736	0.99	228	231	235	7.35	7.39	7.35	60.0	-1
12/19/2025 10:00:00	5472	734	0.99	248	251	254	7.33	7.37	7.33	60.0	-1
12/19/2025 11:00:00	6091	735	0.98	278	280	283	7.34	7.37	7.33	59.99	0
12/19/2025 12:00:00	6644	735	0.98	303	306	309	7.35	7.38	7.33	60.0	0
12/19/2025 13:00:00	7361	733	0.98	338	340	345	7.33	7.36	7.31	60.01	0
12/19/2025 14:00:00	7498	736	0.98	343	346	350	7.36	7.38	7.33	60.01	1
12/19/2025 15:00:00	7366	735	0.98	338	338	345	7.34	7.38	7.32	60.0	1
12/19/2025 16:00:00	7297	736	0.98	337	334	339	7.36	7.39	7.34	60.01	1
12/19/2025 17:00:00	7029	738	0.98	325	319	324	7.37	7.4	7.35	60.01	1
12/19/2025 18:00:00	6820	738	0.99	314	312	312	7.38	7.4	7.35	60.01	1
12/19/2025 19:00:00	6631	739	0.99	305	303	303	7.39	7.41	7.37	60.01	0
12/19/2025 20:00:00	6386	734	0.99	294	292	295	7.34	7.36	7.31	60.01	-1
12/19/2025 21:00:00	5974	733	0.99	275	273	277	7.33	7.36	7.31	60.0	0
12/19/2025 22:00:00	5898	734	0.99	270	269	273	7.34	7.37	7.32	60.0	-2
12/19/2025 23:00:00	5951	734	0.99	273	271	276	7.34	7.37	7.31	60.0	-1
12/20/2025 00:00:00	5718	736	0.99	260	262	263	7.36	7.38	7.33	60.0	0

DAILY READING	
KWH IN	
TOTAL GENERATION	
TOTAL KW	
KWH OUT	