



CITY OF SABETHA MUNICIPAL POWER PLANT

EVERGY INTERCONNECTION

DATE/TIME	KW	KV	PF	AMPS			VOLTAGE			Hz	TAP
				1	2	3	1	2	3		
12/17/2025 00:00:00	5638	735	0.99	258	259	258	7.34	7.37	7.34	59.98	0
12/17/2025 01:00:00	5530	735	0.99	252	253	255	7.34	7.37	7.34	59.98	0
12/17/2025 02:00:00	5359	736	0.99	245	245	245	7.35	7.38	7.35	59.99	0
12/17/2025 03:00:00	5176	739	0.99	235	235	237	7.37	7.41	7.37	59.99	0
12/17/2025 04:00:00	4953	735	0.99	224	227	228	7.35	7.38	7.34	59.98	0
12/17/2025 05:00:00	4672	737	0.99	211	213	216	7.35	7.39	7.35	59.98	0
12/17/2025 06:00:00	4573	737	0.99	207	208	211	7.36	7.4	7.36	59.98	0
12/17/2025 07:00:00	4548	738	0.99	207	207	208	7.37	7.4	7.37	59.98	0
12/17/2025 08:00:00	4540	735	0.99	206	208	208	7.34	7.37	7.35	59.98	0
12/17/2025 09:00:00	4624	734	0.99	210	211	213	7.32	7.36	7.33	59.98	0
12/17/2025 10:00:00	4807	732	0.99	219	220	224	7.3	7.34	7.31	60.0	-2
12/17/2025 11:00:00	5545	732	0.99	254	256	258	7.3	7.34	7.31	60.0	0
12/17/2025 12:00:00	6422	733	0.98	295	298	300	7.32	7.35	7.32	60.0	0
12/17/2025 13:00:00	6926	732	0.98	318	323	326	7.31	7.34	7.31	60.01	0
12/17/2025 14:00:00	7096	734	0.98	327	330	332	7.33	7.36	7.33	60.01	0
12/17/2025 15:00:00	6997	732	0.98	322	325	328	7.31	7.35	7.31	60.0	0
12/17/2025 16:00:00	7056	732	0.98	327	329	330	7.31	7.34	7.31	60.01	0
12/17/2025 17:00:00	6878	735	0.98	316	318	321	7.34	7.37	7.34	60.02	0
12/17/2025 18:00:00	6530	738	0.98	297	300	303	7.37	7.4	7.36	60.0	0
12/17/2025 19:00:00	6697	734	0.98	309	312	310	7.33	7.37	7.32	60.0	0
12/17/2025 20:00:00	6467	734	0.98	299	299	301	7.33	7.37	7.32	60.0	0
12/17/2025 21:00:00	6025	736	0.98	279	276	277	7.35	7.38	7.33	59.98	0
12/17/2025 22:00:00	5816	737	0.99	269	263	268	7.36	7.39	7.34	59.99	-1
12/17/2025 23:00:00	5459	734	0.99	251	248	249	7.34	7.36	7.31	60.01	-1
12/18/2025 00:00:00	5431	734	0.99	246	247	252	7.34	7.37	7.31	60.0	-1

DAILY READING	
KWH IN	
TOTAL GENERATION	
TOTAL KW	
KWH OUT	