



CITY OF SABETHA MUNICIPAL POWER PLANT

EVERGY INTERCONNECTION

DATE/TIME	kW	KV	PF	AMPS			VOLTAGE			Hz	TAP
				1	2	3	1	2	3		
12/11/2025 00:00:00	6031	736	0.99	274	274	279	7.34	7.39	7.36	60.0	-1
12/11/2025 01:00:00	5762	735	0.99	262	264	265	7.33	7.38	7.35	60.0	-1
12/11/2025 02:00:00	5589	732	0.99	257	255	257	7.29	7.35	7.33	60.0	-2
12/11/2025 03:00:00	5398	732	0.99	245	246	252	7.28	7.35	7.33	60.0	-1
12/11/2025 04:00:00	5234	734	0.99	236	241	242	7.3	7.37	7.34	60.0	-1
12/11/2025 05:00:00	5012	733	0.99	228	229	232	7.3	7.37	7.34	60.0	-1
12/11/2025 06:00:00	4933	736	0.99	223	226	228	7.33	7.39	7.36	60.0	-1
12/11/2025 07:00:00	4857	737	0.99	218	222	225	7.34	7.41	7.37	60.0	-1
12/11/2025 08:00:00	4848	737	0.99	219	222	223	7.34	7.4	7.37	60.0	-1
12/11/2025 09:00:00	4861	734	0.99	221	222	225	7.31	7.38	7.34	60.0	-1
12/11/2025 10:00:00	4985	735	0.99	228	227	230	7.32	7.38	7.35	60.0	-1
12/11/2025 11:00:00	5672	732	0.99	258	260	265	7.3	7.36	7.31	60.0	-1
12/11/2025 12:00:00	6560	734	0.98	300	301	306	7.32	7.38	7.33	60.0	1
12/11/2025 13:00:00	6904	735	0.98	316	317	323	7.33	7.38	7.34	60.01	1
12/11/2025 14:00:00	6981	736	0.98	319	321	326	7.33	7.39	7.35	60.0	0
12/11/2025 15:00:00	7037	737	0.98	321	322	328	7.35	7.4	7.36	60.0	0
12/11/2025 16:00:00	7145	732	0.98	328	331	334	7.29	7.35	7.32	60.01	0
12/11/2025 17:00:00	6949	734	0.98	318	321	323	7.31	7.37	7.34	60.01	0
12/11/2025 18:00:00	6499	732	0.99	298	300	301	7.29	7.35	7.33	60.01	-1
12/11/2025 19:00:00	6747	736	0.98	308	313	313	7.33	7.39	7.36	60.01	0
12/11/2025 20:00:00	6332	734	0.98	289	294	294	7.32	7.37	7.34	60.0	-1
12/11/2025 21:00:00	5932	732	0.99	271	274	274	7.29	7.34	7.32	59.99	-1
12/11/2025 22:00:00	5673	733	0.99	259	259	262	7.3	7.36	7.34	60.0	-1

				AMPS			VOLTAGE				
DATE/TIME	kW	KV	PF	1	2	3	1	2	3	Hz	TAP
12/11/2025 23:00:00	5585	733	0.99	252	257	258	7.29	7.36	7.32	60.0	-1
12/12/2025 00:00:00	5549	735	0.99	251	253	255	7.32	7.38	7.35	60.0	-1

DAILY READING	
KWH IN	
TOTAL GENERATION	
TOTAL KW	
KWH OUT	