

12/16/2025 15:10:41



# CITY OF SABETHA MUNICIPAL POWER PLANT

## EVERGY INTERCONNECTION

DATE/TIME	KW	KV	PF	AMPS			VOLTAGE			Hz	TAP
				1	2	3	1	2	3		
12/15/2025 00:00:00	6313	738	0.99	284	286	292	7.36	7.41	7.36	59.99	-1
12/15/2025 01:00:00	6171	739	0.99	274	282	286	7.38	7.42	7.36	60.0	-1
12/15/2025 02:00:00	6061	739	0.99	270	277	278	7.38	7.42	7.37	60.01	-1
12/15/2025 03:00:00	5905	736	0.99	265	272	271	7.36	7.39	7.34	60.01	-2
12/15/2025 04:00:00	5691	735	0.99	258	260	262	7.34	7.38	7.33	60.0	-1
12/15/2025 05:00:00	5450	737	0.99	247	248	251	7.36	7.39	7.35	60.0	-1
12/15/2025 06:00:00	5298	737	0.99	238	241	245	7.36	7.4	7.35	60.0	-1
12/15/2025 07:00:00	5290	737	0.99	238	241	245	7.36	7.4	7.35	60.01	-1
12/15/2025 08:00:00	5314	736	0.99	239	243	246	7.35	7.39	7.34	60.0	-1
12/15/2025 09:00:00	5416	735	0.99	246	246	250	7.34	7.39	7.34	60.0	-1
12/15/2025 10:00:00	5697	734	0.99	259	260	264	7.33	7.38	7.32	60.0	-2
12/15/2025 11:00:00	6421	733	0.99	294	295	298	7.32	7.36	7.3	60.0	-1
12/15/2025 12:00:00	7241	737	0.98	330	331	338	7.36	7.4	7.34	60.0	1
12/15/2025 13:00:00	7631	735	0.98	346	352	358	7.34	7.38	7.32	60.01	0
12/15/2025 14:00:00	7780	732	0.98	355	361	365	7.31	7.36	7.3	60.01	1
12/15/2025 15:00:00	7584	735	0.98	344	352	354	7.34	7.39	7.33	60.01	1
12/15/2025 16:00:00	7584	734	0.98	347	353	352	7.32	7.37	7.33	60.01	1
12/15/2025 17:00:00	7215	736	0.98	328	335	334	7.33	7.39	7.35	60.01	1
12/15/2025 18:00:00	6895	735	0.99	313	320	319	7.32	7.38	7.34	60.02	1
12/15/2025 19:00:00	6863	734	0.98	313	321	315	7.32	7.37	7.34	60.01	0
12/15/2025 20:00:00	6526	736	0.99	299	301	300	7.35	7.38	7.34	60.01	-1
12/15/2025 21:00:00	6173	737	0.99	283	282	283	7.36	7.39	7.36	60.0	-1
12/15/2025 22:00:00	5979	738	0.99	273	270	276	7.37	7.41	7.37	59.99	-1
12/15/2025 23:00:00	5925	736	0.99	270	270	270	7.35	7.38	7.35	60.0	-1
12/16/2025 00:00:00	5834	736	0.99	267	266	264	7.36	7.38	7.35	60.0	-1

DAILY READING	
KWH IN	
TOTAL GENERATION	
TOTAL KW	
KWH OUT	