



## CITY OF SABETHA MUNICIPAL POWER PLANT

### EVERGY INTERCONNECTION

DATE/TIME	kW	KV	PF	AMPS			VOLTAGE			Hz	TAP
				1	2	3	1	2	3		
12/4/2025 00:00:00	6516	735	0.99	297	297	301	7.34	7.38	7.33	60.0	-1
12/4/2025 01:00:00	6381	737	0.99	292	288	294	7.35	7.4	7.35	60.0	-1
12/4/2025 02:00:00	6168	737	0.99	279	281	285	7.36	7.4	7.35	60.0	-1
12/4/2025 03:00:00	5828	737	0.99	264	265	269	7.36	7.4	7.36	60.0	-1
12/4/2025 04:00:00	5569	733	0.99	256	253	257	7.31	7.35	7.32	60.0	-2
12/4/2025 05:00:00	5297	732	0.99	243	241	246	7.3	7.34	7.31	60.0	-2
12/4/2025 06:00:00	5147	732	0.99	234	235	238	7.31	7.34	7.31	60.0	-2
12/4/2025 07:00:00	5113	731	0.99	233	234	238	7.28	7.33	7.3	60.0	-2
12/4/2025 08:00:00	5082	730	0.99	231	232	237	7.28	7.33	7.3	60.0	-2
12/4/2025 09:00:00	5247	731	0.99	241	238	244	7.28	7.33	7.31	60.0	-1
12/4/2025 10:00:00	5542	731	0.99	254	251	259	7.29	7.33	7.31	60.0	-1
12/4/2025 11:00:00	6353	736	0.99	291	288	296	7.34	7.38	7.36	60.0	0
12/4/2025 12:00:00	7188	732	0.98	331	330	338	7.3	7.34	7.31	60.0	0
12/4/2025 13:00:00	8012	733	0.98	370	370	376	7.32	7.36	7.32	60.0	2
12/4/2025 14:00:00	8226	734	0.98	381	377	387	7.32	7.36	7.33	60.0	2
12/4/2025 15:00:00	7883	737	0.98	363	361	368	7.35	7.39	7.36	60.01	2
12/4/2025 16:00:00	7724	738	0.98	353	355	360	7.36	7.41	7.36	60.0	2
12/4/2025 17:00:00	7534	737	0.98	346	344	353	7.35	7.4	7.36	60.01	1
12/4/2025 18:00:00	7006	737	0.99	321	320	324	7.36	7.4	7.36	60.0	0
12/4/2025 19:00:00	7181	734	0.98	332	332	334	7.32	7.37	7.32	60.0	0
12/4/2025 20:00:00	6959	736	0.98	317	321	323	7.35	7.4	7.35	60.0	0
12/4/2025 21:00:00	6656	736	0.99	306	303	308	7.35	7.4	7.35	60.0	0
12/4/2025 22:00:00	6290	734	0.99	288	286	293	7.32	7.37	7.32	60.0	-1

				AMPS			VOLTAGE				
DATE/TIME	kW	KV	PF	1	2	3	1	2	3	Hz	TAP
12/4/2025 23:00:00	6288	738	0.99	283	287	291	7.36	7.42	7.36	60.01	-1
12/5/2025 00:00:00	6415	737	0.99	293	292	295	7.36	7.4	7.35	60.01	-1

DAILY READING	
KWH IN	
TOTAL GENERATION	
TOTAL KW	
KWH OUT	