

PID Tuner (Simulink23210715P2/Sistema: Hipotenso/PID Controller)
PID TUNER
Plant
Type PIDF
Form Parallel
Options
Domain
Time
Add Plot
PLANT
CONTROLLER
DESIGN
0.03188
Reset Design
Show Parameters
Update Block
RESULTS
Plant List
Name
Class
Plant
ss
Preview
Show
Controller Parameters
Tuned
Block
P
1.8756
1.8756
I
77.1277
77.1277
D
-0.0038798
-0.0038798
N
89.2345
89.2345
Performance and Robustness
Tuned
Block
Rise time
0.0246 seconds
0.0246 seconds
Settling time
0.0832 seconds
0.0832 seconds
Overshoot
7.95 %
7.95 %
Peak
1.08
1.08
Gain margin
Inf dB @ NaN rad/s
Inf dB @ NaN rad/s
Phase margin
69 deg @ 62.7 rad/s
69 deg @ 62.7 rad/s
Closed-loop stability
Stable
Stable
Close
Tuned response
Block response
0
0.05
0.1
0.15
0.2
0.25
Time (seconds)
Controller Parameters: P = 1.876, I = 77.13, D = -0.00388, N = 89.23