

AMENDMENT NO. 1 SEPTEMBER 2024
TO
IS 15683 : 2018 PORTABLE FIRE EXTINGUISHERS — PERFORMANCE AND
CONSTRUCTION — SPECIFICATION
(First Revision)

(Page 1, clause 3.6) — Substitute the following for the existing:

‘3.6 Maximum Service Pressure (P_{ms}) — Equilibrium pressure developed in a normally charged and pressurized extinguisher which is conditioned at $60\text{ }^{\circ}\text{C} \pm 5\text{ }^{\circ}\text{C}$ for at least 18 h.’

[Page 2, clause 5.3.2(d)] — Substitute the following for the existing:

‘Carbon dioxide extinguishers : - 5 percent to 0 percent by mass;’

[Page 2, clause 5.3.3(c)] — Insert the following at the end:

‘NOTE — For Class D fire, only 9 kg capacity of fire extinguisher shall be used.’

[Page 11, Table 7, col (4), title] — Substitute ‘litre’ for ‘l’.

(Page 11, clause 8.5.1, line 3) — Substitute ‘9 kg’ for ‘10 kg’.

(Page 17, clause 9.2.4, line 3) — Substitute ‘500 cycles’ for ‘5 000 cycles’.

(Page 18, clause 9.4.2) — Insert the following at the end:

‘Hook shall be capable of withstanding a static load of five times the fully charged mass of extinguisher when tested in accordance with 9.4.4.’

(Page 19, clause 9.5.6) — Insert the following at the end:

‘9.5.7 Minimum torque value for tightening the cap of extinguisher shall be declared by the manufacturer and it shall be mentioned in the operation manual.’

(Page 21, clause 9.11.2) — Substitute the following for the existing:

‘9.11.2 Calibration/Checking/Verification Test for Pressure Gauges and Indicators

The error of a pressure gauge at the indicated service pressure (P_s) shall not exceed ± 4 percent of the service pressure. The error at the upper and lower limits of the operable range shall not exceed ± 4 percent of the service pressure for powder and water-based extinguisher gauges and ± 8 percent of the charging pressure for clean agent extinguisher gauges. At the zero-pressure mark, the error shall not exceed - 0 percent to + 12 percent of the service pressure (P_s). At the maximum indicated pressure, the error shall not exceed ± 15 percent of the service pressure (P_s). Calibrate pressure gauge from a NABL accredited lab or in-house with the help of dead weight gauge tester or a piping apparatus with a calibrated master gauge.’

(Page 21, clause 10.1, line 2) — Substitute the following for the existing:

‘A small band of distinguishing colour of approx 5 percent/prominent of surface area shall be painted or labelled (as per IS 17917) for different type of extinguishers as given below:’

Amendment No. 1 to IS 15683 : 2018

(Page 25, Annex A) — Substitute the following for the existing:

<i>IS No.</i>	<i>Title</i>
IS 4308 : 2019	Dry chemical powders for fire fighting — BC, ABC and D types — Specification (<i>third revision</i>)
IS 17917 : 2022	Pressure sensitive adhesive films for general industrial applications — Specification’.

(CED 22)

Publication, BIS, New Delhi