

AMENDMENT NO. 1 FEBRUARY 2014
TO
IS 15773 : 2008 SODIUM DICHLOROISOCYANURATE —
SPECIFICATION

(Page 3, Table 1) — Substitute the following for the existing table:

Table 1 Toxic Substances
(Clause 4.3)

Sl No.	Element	Limit in PPM, mg/kg of Product	Method of Test, Ref to
(1)	(2)	(3)	(4)
i)	Arsenic (As) , <i>Max</i>	10	IS 3025 (Part 37)
ii)	Cadmium (Cd), <i>Max</i>	1	IS 3025 (Part 41)
iii)	Chromium (Cr), <i>Max</i>	6	Annex J of IS 13428
iv)	Mercury (Hg), <i>Max</i>	0.02	IS 3025 (Part 48)
v)	Nickel (Ni), <i>Max</i>	3	Annex L of IS 13428
vi)	Lead (Pb) , <i>Max</i>	4	IS 3025 (Part 47)
vii)	Antimony (Sb), <i>Max</i>	5	Annex G of IS 13428 or IS 15303 ¹⁾
viii)	Selenium (Se), <i>Max</i>	1	IS 3025 (Part 56) or IS 15303 ¹⁾

NOTES

1 Cyanide which does not exist in a strong oxidizing medium such as sodium dichloroisocyanurate is not a relevant toxic substance. Pesticides and polycyclic aromatic hydrocarbons are not by-products of the manufacturing process.

2 If a change in the production process or raw materials leads to significant quantities of other impurities or by-products being present, this shall be notified to the user.

3 In case of dispute, the method indicated by '1)' shall be the reference method.

(Page 8, clause **F-2.1**, Line 2) — Substitute 'emergency use (see Note)' for 'emergency use'.

Amendment No. 1 to IS 15773 : 2008

(Page 8, clause F-2.1) — Substitute the following note at the end:

NOTE — For sodium dichloroisocyanurate the following conditions apply:

- a) Where circumstances are such that the water being treated is not grossly contaminated and a controlled contact time of less than 15 min between dosing and taking it into use can be maintained, not more than 10 mg/l of sodium dichloroisocyanurate compound shall be applied and not more than 1 mg/l of free residual chlorine shall be present at the end of the relevant contact time. It is recommended that consumers shall be exposed to such waters containing chloro-isocyanurates for only as long as is required to restore conventional treatment, or for no more than 90 days in any period of a year, whichever is applicable;
- b) Under circumstances where water sources may be grossly contaminated, to ensure inactivation of most likely harmful organisms, up to 20 mg/l sodium dichloroisocyanurate may be added, with a recommended contact time of 15 min before use.
- c) It is recommended that consumption of water dosed at this rate of treatment shall be for only as long as is necessary before it is possible to effect control of the residual chlorine after contact to 1 mg/l, and then to follow the requirements set out in condition a); and
- d) It shall be necessary for specific groups of consumers to be exposed to water containing chloro-isocyanurates for periods greater than 90 days either continuously or in a year, it is recommended that independent medical advice be obtained from a person who is not under the water undertaker.