

AMENDMENT NO. 5 MARCH 2025

TO

**IS 15778 : 2007 CHLORINATED POLYVINYL CHLORIDE (CPVC) PIPES FOR
POTABLE HOT AND COLD WATER DISTRIBUTION SUPPLIES —
SPECIFICATION**

(Second cover page, foreword, last para) — Substitute “IS 2 : 2022 ‘Rules for rounding off numerical values (*second revision*)’” for “IS 2 : 1960 ‘Rules for rounding off numerical values (*revised*)’”.

(Page 3, clause 6.3.3) — Insert the following at the end:

‘**6.4** The addition of the manufacturer's own rework material is permissible. The maximum quantity of the rework material used shall be not more than 5 percent. No other rework material shall be used.’

[Page 6, Table 3, Sl No. (i), col (5) (see also Amendment No.3)] — Substitute ‘41.6 MPa’ for ‘43.0 MPa’.

(CED 50)

Price Group 1
Publication, BIS, New Delhi