

AMENDMENT NO. 3 DECEMBER 2020

TO

IS 15778 : 2007 CHLORINATED POLYVINYL CHLORIDE (CPVC) PIPES FOR POTABLE HOT AND COLD WATER DISTRIBUTION SUPPLIES — SPECIFICATION

(Page 2, Table 1, Note, line 2) — Substitute ‘+82 °C’ for ‘+90 °C’.

(Page 2, Table 1, Note, line 4) — Substitute ‘82 °C’ for ‘90 °C’.

[Page 6, Table 3, Sl No. (i), col 3] — Substitute ‘27’ for ‘20’.

(Page 6, clause 12.1) — Insert the following new clause:

‘12.1.1 The lot number/batch number shall include the details of production in the following manner:

Year	Month	Day	Machine No.	Shift
XXXX	XX	XX	XXX	X

(Page 6, clause 12.2) — Substitute the following for the existing clause:

‘12.2 BIS Certification Marking

12.2.1 Each pipe conforming to the requirements of this standard may be certified as per the conformity assessment schemes under the provisions of the *Bureau of Indian Standards Act, 2016* and the Rules and Regulations framed thereunder, and the pipe may be marked with the Standard Mark.’