

AMENDMENT NO. 2 DECEMBER 2021

TO

IS 15785 : 2007 INSTALLATION AND MAINTENANCE OF LIFT WITHOUT CONVENTIONAL MACHINE ROOM — CODE OF PRACTICE

(Page 5, Clause 5.3) — Substitute the following for the existing clause:

‘5.3 Emergency Alarm Devices

5.3.1 An intercom system, or similar device, powered by the emergency supply shall be installed between inside the car and the place from which the emergency operation is carried out, if the travel exceeds 30 m or a direct acoustic communication between the car and the place from which the emergency operation is carried out is not possible.

5.3.2 If an external battery is used as standby supply as electrical means of emergency operation as mentioned in **5.2.1**, it shall additionally have,

- a) suitable audio alarm with visual indication (‘Low Battery’); or
- b) voice annunciation in the lift car. This alarm shall operate before the battery charge becomes too low for successful completion of the emergency rescue operation.’