

**AMENDMENT NO. 1 DECEMBER 2016
TO
IS 12288 : 1987 CODE OF PRACTICE FOR USE AND
LAYING OF DUCTILE IRON PIPE**

[*Page 10, clause 8.3 (b)*] — Substitute the following for the existing:

‘b) The maximum static pressure plus 0.5 N/mm^2 , and’

(CED 24)

Publication Unit, BIS, New Delhi, India