

**AMENDMENT NO. 1 MARCH 2007
TO
IS 12432 (PART 3) : 2002 APPLICATION OF SPRAY
APPLIED INSULATION — CODE OF PRACTICE**

PART 3 POLYURETHANE/POLYISOCYANURATE

(Page 3, clause 6.11) — Substitute the following for the existing clause:

6.11 General

6.11.1 In all cases of overdeck insulation where there is a parapet wall or an upstand around the roof, effectiveness of junction between roof and vertical portion would be ensured by continuing the treatment to a vertical extension of 0.5 m, *Min* around the roof perimeter. Such extra area are to be measured.

6.11.2 For treatments on vertical areas of overdeck insulation, a multiplication factor of 1.2 shall be applied to the actual area to account for rebound losses/over thickness.

6.11.3 To account for excess rebound losses in underdeck PUR/PIR Spray in-situ application, measured area shall be subject to a multiplication factor of 1.4.

6.11.4 Spray treatment is applied as a continuous treatment and hence no deductions shall be made in measurements for cutouts having area of one square metre or less.'

(Page 4, clause 6.12) — Delete the clause.

(Page 4, clause 6.12.1) — Delete the clause.

(Page 4, clause 6.12.2) — Delete the clause.

(CHD 27)