

22:3/T-22

**AMENDMENT NO. 1 JANUARY 2001
TO
IS 12717 : 1989 FIRE FIGHTING EQUIPMENT — HIGH
CAPACITY PORTABLE PUMP SET (1 100-1 600 l/min) —
FUNCTIONAL REQUIREMENTS**

(Page 1, clause 3.1) — Insert the following new clause after 3.1:

'3.2 Weight

The total weight of the unit with fuel shall not exceed 130 kg.'

(CED 22)

Reprography Unit, BIS, New Delhi, India