

AMENDMENT NO. 1 SEPTEMBER 2000
TO
IS 13369 : 1992 STATIONARY LEAD-ACID BATTERIES
(WITH TUBULAR POSITIVE PLATES) IN MONOBLOC
CONTAINER — SPECIFICATION

(*Page 2, clause 6.2, line 4*) — Add the following after 'containers':

'For transparent/translucent containers, level indicator is not necessary, but maximum and minimum electrolyte level lines shall be clearly marked on the containers.'

(*Page 2, Table 1, col 2*) — Substitute '120' for '125' against 12 V batteries.

(*Page 5, clause 11.5.5, line 5*) — Substitute '5 hours' for '6 hour rate'.

(*Page 5, clause 11.7.3, lines 2 and 4*) — Substitute '11.7.2' for '11.7.3' and '1.80 V' for '1.85 V' respectively.

(ETD 11)