

AMENDMENT NO. 1 DECEMBER 2025
TO
IS 13630 (PART 15) : 2019 CERAMIC TILES — METHODS OF TEST, SAMPLING
AND BASIS FOR ACCEPTANCE
PART 15 SAMPLING AND BASIS FOR ACCEPTANCE
(First Revision)

[Page 1, clause 2, entry pertaining to ‘IS 2500 (Part 2) : 1965’] — Delete.

(Page 1, clause 2) — Substitute the following with the existing entries against concerned Indian Standards:

<i>‘IS No.</i>	<i>Title</i>
IS 2500 (Part 1) : 2000/ ISO 2859-1: 1999	Sampling procedures for inspection by attributes : Part 1 Sampling schemes indexed by acceptance quality limit (AQL) for lot-by-lot inspection <i>(third revision)</i>
IS 13712 : 2019	Ceramic tiles — Definitions, classifications, characteristics and marking <i>(second revision)’</i>

(Page 1, clause 2) — Insert the following new entries at appropriate place:

<i>‘IS No.</i>	<i>Title</i>
IS/ISO 3951-1 : 2022	Sampling procedures for inspection by variables: Part 1 Specification for single sampling plans indexed by acceptance quality limit (AQL) for lot-by-lot inspection for a single quality characteristic and a single AQL <i>(first Revision)</i>
IS 13630	Ceramic tiles — Methods of test, sampling and basis for acceptance:
(Part 1) : 2019	Determination of dimensions and surface quality <i>(second revision)</i>
(Part 2) : 2019	Determination of water absorption and bulk density <i>(second revision)</i>
(Part 3) : 2019	Determination of moisture expansion using boiling water <i>(second revision)</i>
(Part 4) : 2019	Determination of linear thermal expansion <i>(second revision)</i>
(Part 5) : 2019	Determination of resistance to thermal shock <i>(second revision)</i>
(Part 6) : 2019	Determination of modulus of rupture and breaking strength <i>(second revision)</i>
(Part 7) : 2019	Determination of stain and chemical resistance of unglazed tiles <i>(second revision)</i>
(Part 8) : 2019	Determination of stain and chemical resistance of glazed tiles <i>(second revision)</i>
(Part 9) : 2019	Determination of crazing resistance of glazed tiles <i>(second revision)</i>
(Part 10) : 2019	Determination of frost resistance <i>(second revision)</i>
(Part 11) : 2019	Determination of resistance of surface abrasion of glazed tiles <i>(second revision)</i>
(Part 12) : 2019	Determination of resistance to deep abrasion unglazed tiles <i>(second revision)</i>
(Part 13) : 2019	Determination of scratch hardness of surface according to Mohs’ scale <i>(second revision)</i>

Price Group 2

Amendment No. 1 to IS 13630 (Part 15) : 2019

(Part 14) : 2019	Determination of impact resistance by measurement of coefficient of restitution (<i>first revision</i>)
(Part 16) : 2019	Determination of lead and cadmium given off by glazed tiles
IS 18433	Measurement of surface frictional properties — Method of test
(Part 1) : 2023	Pendulum test
(Part 2) : 2023	Ramp test'

(Page 4, Table 1) — Delete the row on Small colour differences.

[Page 4, Table 1, col (12)] — Substitute 'Part 16' for 'Part 17' in the row on Lead and cadmium release.

Amendment No. 1 to IS 13630 (Part 15) : 2019

(Page 4, Table 1) — Substitute the following row for the existing row on Slip resistance/Coefficient of friction:

‘Properties	Sample Size		Inspection by Attribute, if Required				Inspection by Average Value, if Required				Test Method as Per IS 13630
			Initial Sample		Initial + Second Samples		Initial Sample		Initial + Second Samples		
	Initial Number	Second Number	Acceptance Number, Ac ₁	Rejection Number, Re ₁	Acceptance Number, Ac ₂	Rejection Number, Re ₂	Acceptable if	Second Sample to be Drawn if	Acceptable if	Rejection Justified if	
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)
Slip resistance/Coefficient of friction — Measurement of surface frictional properties of tiles intended for use on floors ¹²⁾	—	—	Attribution by manufacturer’s declaration								Manufacturer to declare as per IS 18433 (Part 1) ¹³⁾ or IS 18433 (Part 2) ¹⁴⁾

(Page 4, Table 1, footnote 2) — Substitute the following for the existing:

²⁾ At least 1 m² with a minimum of 30 tiles. Whatever the number of tiles in 1 m², the test sample should be rounded to the nearest 10 tiles above. Conformity to acceptable quality level (AQL) 2.5 percent in accordance with IS 2500 (Part 1) and IS/ISO 3951-1 is an acceptable alternative to the procedure in Table 1.’

(Page 4, Table 1, footnote) — Insert the following footnotes after footnote 11:

¹²⁾ IS 18433 (Part 2) shall be preferred for slip-resistance classification.

¹³⁾ IS 18433 (Part 1), Table 1 Classification of slip potential of the surface and typical applications.

¹⁴⁾ IS 18433 (Part 2), Table 3 and Table 4 on slip resistance classification.’

(CED 05)

Publication, BIS, New Delhi