

**AMENDMENT NO.1 SEPTEMBER 1991  
TO  
IS 2542 ( Part 1 / Sec 8 ) : 1978 METHODS OF TEST FOR  
GYPSUM PLASTER, CONCRETE AND PRODUCTS**

**PART 1 PLASTER AND CONCRETE**

**Section 8 Freedom from Coarse Particles**

*( First Revision )*

*( Page 29, clause 3.1 )* — Substitute the following for the existing clause :

**'3.1 Sift 100 g of plaster continuously for 5 minutes on a 1.18 mm or 90  $\mu$ m  
IS Sieve, as required, and the residue on the sieve weighed and reported.**

**( CED 21 )**

---

Reprography Unit, BIS, New Delhi, India