

AMENDMENT NO. 3 MAY 2026
TO
IS 2553 (PART 1) : 2018 SAFETY GLASS — SPECIFICATION
PART 1 ARCHITECTURAL, BUILDING AND GENERAL USES
(Fourth Revision)

(Page 3, clause 5.2.2.1) — Insert the following at the end:

‘NOTE — This test is not applicable for curved toughened safety glasses.’

(Page 3, clause 5.2.2.2) — Insert the following at the end:

‘NOTE — This test is not applicable for curved toughened safety glasses.’

(Amendment No. 1, Page 1, clause 5.2.2.3) — Insert the following at the end:

‘NOTE — The test given from 5.2.2.3.1 to 5.2.2.3.3 are not applicable on spherically curved toughened glasses such as glass lids. For such glasses, the requirements given in 5.2.2.3.4 shall be applicable.’

(Amendment No. 1, Page 1, clause 5.2.2.3.3) — Insert the following at the end:

‘5.2.2.3.4 Dimensional requirements specific for spherically curved toughened glasses

The spherically curved toughened glass shall satisfy the dimensional requirements as given below:

a) *Depth of curvature or crown height, H*

Place glass on hard flat surface and measure the vertical height (*see* Fig. 20) from base to apex using any calibrated ruler, thread or depth gauge in millimeters. The measured height shall lie within the ± 1.5 mm of the nominal height as declared by the manufacturer.




FIG. 20 SPHERICALLY CURVED GLASS

b) *Diameter of base, D*

Using any calibrated ruler or vernier, measure across widest horizontal span at 3 locations spaced at 120°. The difference between any two readings shall not differ by more than 1.5 mm.

Price Group 1

Amendment No. 3 to IS 2553 (Part 1) : 2018

(Page 4, clause 5.2.4) — Insert the following at the end:

‘NOTE — This test is not applicable for curved toughened safety glasses.’

(Page 7, clause 5.2.8.2) — Insert the following at the end:

‘NOTE — This test is not applicable for curved toughened safety glasses.’

(Page 8, clause 5.2.8.3) — Insert the following at the end:

‘NOTE — This test is not applicable for curved toughened safety glasses.’

(Page 16, Annex B, title) — Substitute the following for the existing:

‘B-1 OPTICAL DISTORTION’

(CHD 10)

Publication, BIS, New Delhi