

AMENDMENT NO. 1 JUNE 1981
TO
IS : 4700 - 1968 QUALITY TOLERANCES FOR
WATER FOR FERMENTATION INDUSTRY

Addendum

[Page 4, Table 2, Sl No. (xxi)] — Add the following new matte
under respective columns after Sl No. (xxi) :

'(1)	(2)	(3)	(4)
xxii)	Cadmium (as Cd), mg/1, <i>Max</i>	0.01	<i>See</i> <i>Note</i>
xxiii)	Mercury (as Hg), mg/1, <i>Max</i>	0.001	<i>See</i> <i>Note</i>

NOTE — Methods of test for these characteristics are under preparation, till then methods of test as given in Standard Methods for the examination of water and wastewater, 1975. American Public Health Association; American Water Works Association; and Water Pollution Control Federation, USA, shall be followed.'

(CDC 26)

Printed at Prabhat Offset Press, New Delhi-2